

### CALIBRATION CERTIFICATE

Tested For: CPS Australia P/L Address: 109 Welland Ave  
Welland SA 5007

Certificate Number: 7905-1  
Equipment: ABM Easy Flow Hood Manufacturer: CPS  
Model: 200 Serial Number: -  
Calibration Range: 70 to 500 L/S in 1 L/S digits

Test Specification: As per manufacturer's accuracy specifications

Ambient Temperature: 20 °C ± 2 °C Ambient Humidity: 45 %RH +/- 5%RH

The measurements reported herein have been calibrated using standards traceable to National and/or International Standards, (NML, NIST, NPL), or derived by the ratio type of self-calibration techniques.


<u>Equipment Used / Calibration Traceability</u>	<u>Serial Number</u>	<u>Certificate Number</u>
Reference Anemometer	T95451504005	AV208747

### CALIBRATION TEST RESULTS

Test Description	Units	Reference reading	Instrument Under Test (as received)	Instrument Under Test (as left)	Tolerance	Pass/Fail
Air Volume Supply	L/S	71	71	71	N/A	-
		107	107	107		-
		200	200	200		-
		303	302	302		-
		406	403	403		-
		508	507	507		-
Air Volume Return		72	72	72		-
		109	109	109		-
		196	196	196		-
		307	308	308		-
		409	411	411		-
		508	513	513		-

#### Remarks

Test was performed using the regular test speed function.

<u>Service Engineer Name:</u> Richard Imierowicz	<u>Calibration Date:</u> 18/12/2017
<u>Signed:</u> 	<u>Next Calibration Due:</u> 18/12/2018

Certificate Number: 7905-1

Page: 1 of 1

The details given on this certificate and appended sheet(s) shall not be reproduced except in full, without written approval from ASG X-Technologies.