

CERTIFICATE OF CALIBRATION COMPLIANCE

This is to certify that the CPS Refrigerant Room Monitors models listed below have been individually calibrated by the sensor manufacturer to respond to the published minimum refrigerant levels. The sensor manufacturer uses the following equipment to maintain accuracy on a volumetric method to determine minimum response level:

Gas concentration meter CGT-7000
NDIR Methane meter
Gas test chamber with the automatic gas injection syringe

CPS Refrigerant Room Monitor models covered by this certificate:

RM12
RM22
RM134
RM404
RM407
RM407A
RM502
RM507



Vice President of Engineering
CPS Products, Inc.

August 10, 2018

Date.

CPS WORLD HEADQUARTERS

1010 East 31st Street,
Hialeah, Florida 33013, USA
Tel: 305-687-4121, 1-800-277-3808
Fax: 305-687-3743
E-mail: info@cpsproducts.com
Website: www.cpsproducts.com