

# Emission Test Certificate

Monday 15<sup>th</sup> June 2020

Supplier: Godfrey Hirst Australia (7 Factories Road, Geelong, VIC 3220, Australia)

Sample Description: GH Engineered Timber 1900 x 190 x 14/3

Date Tested: June 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

## Emission Data (24 hours):

Global GreenTag	GH Engineered Timber 1900 x 190 x 14/3
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.020 mg/m <sup>2</sup> /hr
4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m <sup>2</sup> /hr	4-phenylcyclohexene Emission Rate: <0.003 mg/m <sup>2</sup> /hr
Formaldehyde Emission Rate Limit: <0.1 mg/m <sup>2</sup> /hr	Formaldehyde Emission Rate: <0.004 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Luke Morley  
BSc(Tech)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

V2006002