

Catalog Number: Item Description: UPC Code:

U3802 60A NONFUSIBLE DISCONNECT 784572586918

Brand Name:	Milbank
Туре:	Air Conditioner Disconnect
Special Features:	10 Horse Power
Application:	Metering Accessory
Standard:	UL Listed
Voltage Rating:	Up to 240 Volts Alternating Current
Amperage Rating:	60 Ampere
Interrupt Rating:	10,000 Ampere Interrupting Capacity
Number Of Poles:	2
Trip Type:	None
Connection:	Pullout
Enclosure:	Type 3R, Painted Steel
Mounting:	Surface Mount
Conduit Connection:	Knockouts



Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.