

Catalog Number: Item Description: UPC Code:

U5925-O-200-KK-ALT 200A RL MTR PED 8 CRT 784572596542

Brand Name:	Milbank		
Туре:	Ringless N	Neter Socket	
Application:	Meter Soc Center	ket With Main And Load	
Standard:	UL Listed		
Voltage Rating:	Up to 240	Volts Alternating Current	
Amperage Rating:	200 Ampe	ere Continuous	
Phase:	1 Phase		
Frequency Rating:	60 Hertz		
Number Of Cutouts:	1		
Cutout Size:	200 Ampere Main Breaker		
Cable Entry:	Undergro	und	
Terminal:	Lay in Line Side and Single Mechanical Load Side		
Mounting:	Pedestal		
Enclosure:	Type 3R, G90 Galvanized Steel with Powder Coat Finish		
Additional Specifications:		Number of Jaws:4 Terminal	
		Hub Opening and Closing Plate	s:Plain Top
		Equipment Ground:Ground Bar	





Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.

Bypass Provision:Horn Bypass

Number Positions:1 Position

FEATURE TABLE			
ITEM	QTY	DESCRIPTION	
А	4	U/L MNTG.EMBOSS	
В	1	5/16 SOLID K.O.	
С	1	1/4, 1/2 CONC. K.O.	
D	1	1/2, 3/4 CONC. K.O.	
Е	2	1/2, 3/4, 1 CONC. K.O.	
F	3	<sup>3</sup> ⁄ <sub>4</sub> , 1, 1 <sup>1</sup> ⁄ <sub>4</sub> , 1 <sup>1</sup> ⁄ <sub>2</sub> , 2 CONC. K.O.	
G	3	1, 1½, 2, 2½ CONC. K.O.	
	A B C D E F	A 4   B 1   C 1   D 1   E 2   F 3	







Version:

All dimensions are +/- 1/16". Drawing views are not to scale.

Utility requirements for this equipment may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.