

Catalog Number: Item Description: UPC Code: UQFP-125 125A 2P PLUG-IN CB 10K 784572146501

Brand Name:	Milbank
Туре:	Thermal Magnetic
Application:	Current Interrupting Device
Standard:	UL Listed
Voltage Rating:	240 Volts Alternating Current
Amperage Rating:	125 Ampere
Frequency Rating:	60 Hertz
Phase:	1 Phase
Frame:	F-Frame
Trip Type:	Thermal Magnetic
Interrupt Rating:	10,000 Ampere Interrupting Capacity
Number Of Poles:	2
Actuator:	Lever
Material:	Non-Metallic
Operating Temperature:	40 Degrees Celsius



Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.