

Date : November 16, 2004
 Sample ID : Varicel M-Pak, 90%

Test Requested by : AAF International
 Manufacturer : AAF International

Test Type : Loading
 Test Aerosol : Ashrae 52.1 Dust
 Flow: 2000 cfm
 Size: 24x24x6

Arrestance: **99.9%**
 Holding Capacity @ 1.2": **175.8 grams**
 Holding Capacity @ 1.5": **215.8 grams**
 Holding Capacity @ 1.8": **248.8 grams**

Dust Fed	Pressure Drop (" H ₂ O)
0.00	0.535
146.0	1.000
176.0	1.200
216.0	1.500
249.0	1.800

Dust Fed	%Arrestance
73	99.9
161	99.9
196	99.9
232.5	99.9

