


REVISIONS

AAF PART NUMBER	NOMINAL SIZE	WIDTH (inches)	HEIGHT (inches)	DEPTH (inches)	WIDTH (mm)	HEIGHT (mm)	DEPTH (mm)	DESCRIPTION	TARGET GASSES
443-863-001	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MA Galvanized Box	Acidic
443-319-001	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MA Galvanized Box	Acidic
443-863-002	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MB Galvanized Box	Bases
443-319-002	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MB Galvanized Box	Bases
443-863-003	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MC Galvanized Box	Condensible
443-319-003	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MC Galvanized Box	Condensible
443-863-004	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MD Galvanized Box	Dopants
443-319-004	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MD Galvanized Box	Dopants
443-863-011	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MA Galvanized SH	Acidic
443-319-011	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MA Galvanized SH	Acidic
443-863-012	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MB Galvanized SH	Bases
443-319-012	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MB Galvanized SH	Bases
443-863-013	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MC Galvanized SH	Condensible
443-319-013	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MC Galvanized SH	Condensible
443-863-014	24 x 24 x 12	23.30	23.30	11.50	592	592	292	AstroSorb-B MD Galvanized SH	Dopants
443-319-014	24 x 12 x 12	23.30	11.50	11.50	592	292	292	AstroSorb-B MD Galvanized SH	Dopants

GENERAL NOTES:

- Materials of Construction
 - Media:
 - Activated Carbon
 - Impregnated Activated Carbon
 - Ion Exchange Resin
 - Frame:
 - Galvanized Steel or Anodized Aluminum
 - Sealant:
 - Urethane
- Dimensions
 - Nominal Depth = 12
 - For face dimensions see table
 - Tolerance
 - (A x B) + 1mm / - 2mm
 - (C) ± 1.5mm
- EPDM Gasket available



SALES/SUBMITTAL DRAWING

APPROVAL BLOCK

☐ OKAY AS IS

☐ OKAY WITH REVISIONS NOTED

SIGNATURE: _____ DATE: _____

FORM I297 REV. 5/00

DRAWN GAC	DATE 07OCT2024	CHECKED GC	DATE 08OCT2024	APPR. ---	DATE -----	DRAWING NO. 3190108	REV
 P.O. Box 35690 Louisville, KY. 40232-5690 www.aafintl.com						SHEET 1 OF 1	

FILTER ASSEMBLY, ASTROSORB - B
(BOX & SH FILTER) (SUBMITTAL)