



REVISIONS

AAF PART NUMBER	NOMINAL SIZE	WIDTH (inches)	HEIGHT (inches)	DEPTH (inches)	WIDTH (mm)	HEIGHT (mm)	DEPTH (mm)	DESCRIPTION	TARGET GASSES
445-863-001	24 x 24 x 12	23.30	23.30	12.00	592	592	305	AstroSorb-V MA V-Bank Filter	Acidic
445-319-001	24 x 12 x 12	23.30	11.65	12.00	592	296	305	AstroSorb-V MA V-Bank Filter	Acidic
445-863-002	24 x 24 x 12	23.30	23.30	12.00	592	592	305	AstroSorb-V MB V-Bank Filter	Bases
445-319-002	24 x 12 x 12	23.30	11.65	12.00	592	296	305	AstroSorb-V MB V-Bank Filter	Bases
445-863-003	24 x 24 x 12	23.30	23.30	12.00	592	592	305	AstroSorb-V MC V-Bank Filter	Condensable
445-319-003	24 x 12 x 12	23.30	11.65	12.00	592	296	305	AstroSorb-V MC V-Bank Filter	Condensable
445-863-004	24 x 24 x 12	23.30	23.30	12.00	592	592	305	AstroSorb-V MD V-Bank Filter	Dopants
445-319-004	24 x 12 x 12	23.30	11.65	12.00	592	296	305	AstroSorb-V MD V-Bank Filter	Dopants



GENERAL NOTES:

1. Materials of Construction
 - a. Media:
 - Activated Carbon
 - Impregnated Activated Carbon,
 - Ion Exchange Resin
 - b. Frame:

Injection molded high impact polystyrene and extruded Acrylonitrile Butadiene Styrene (ABS)
 - c. Sealant:

Urethane
2. Dimensions
 - a. Nominal Depth = 12
 - b. For face dimensions see table
 - c. Tolerance

(A x B) + 1mm / - 2mm

(C) ± 1.5mm
3. EPDM Gasket available

SALES/SUBMITTAL DRAWING

APPROVAL BLOCK

☐ OKAY AS IS

☐ OKAY WITH REVISIONS NOTED

SIGNATURE: _____ DATE: _____

FORM I297 REV. 5/00

DRAWN GAC	DATE 07OCT2024	CHECKED GC	DATE 08OCT2024	APPR. ---	DATE -----			
 P.O. Box 35690 Louisville, KY. 40232-5690 www.aafintl.com		FILTER ASSEMBLY, ASTROSORB - V (V-BANK FILTER) (SUBMITTAL)				DRAWING NO.		REV
						3190112		
						SHEET 1 OF 1		