


REVISIONS

AAF PART NUMBER	NOMINAL SIZE	WIDTH (inches)	HEIGHT (inches)	DEPTH (inches)	WIDTH (mm)	HEIGHT (mm)	DEPTH (mm)	DESCRIPTION	TARGET GASSES
Tray Holding Frame									
446-846-100	12 x 24 x 18	12.00	24.00	17.72	305	610	450	AstroSorb-T Tray Holding Frame	All
446-319-100	24 x 12 x 18	24.00	12.00	17.72	610	305	450	AstroSorb-T Tray Holding Frame	All
446-863-100	24 x 24 x 18	24.00	24.00	17.72	610	610	450	AstroSorb-T Tray Holding Frame	All
Tray (Empty)									
447-294-900	12 x 17 x 1	11.69	0.90	16.54	297	23	420	AstroSorb-T Tray	All
447-777-900	24 x 17 x 1	23.75	0.90	16.54	603	23	420	AstroSorb-T Tray	All



HEIGHT

WIDTH

DEPTH

AIR FLOW

HEIGHT

WIDTH

DEPTH

AIR FLOW

GENERAL NOTES:

1. Materials of Construction
 - a. Media:
Mini carbon granulate
 - b. Frame:
Anodized Aluminum or Stainless Steel
2. Dimensions
 - a. Nominal Depth
Tray = 1"
Frame = 18"
 - b. For face dimensions see table
 - c. Tolerance
(A x B) + 1mm / - 2mm
(C) ± 1.5mm

SALES/SUBMITTAL DRAWING

APPROVAL BLOCK

☐ OKAY AS IS

☐ OKAY WITH REVISIONS NOTED

SIGNATURE: _____ DATE: _____

FORM I297 REV. 5/00

DRAWN GAC	DATE 07OCT2024	CHECKED GC	DATE 08OCT2024	APPR. ---	DATE -----			
 P.O. Box 35690 Louisville, KY. 40232-5690 www.aafintl.com		FILTER ASSEMBLY, ASTROSORB - T (TRAY & TRAY HOLDING FRAME) (SUBMITTAL)				DRAWING NO.		REV
						3190111		
						SHEET 1 OF 1		