


REVISIONS

Ⓐ REVISED ACTUAL SIZE FOR 12x24, 16x16, 18x24, 20x24
 WAS 11 1/2 x 23 1/2, 15 3/4 x 15 3/4, 17 1/2 x 23 1/2, 19 1/2 x 23 1/2
 GAC 02FEB2026 - GC 02FEB2026 - AH 03FEB2026

FILTER	PLEATS PER LINEAR FOOT	RATED INITIAL RESISTANCE (W.G.)			RECOMMENDED FINAL RESISTANCE (W.G.)	ASHRAE 52.2 MERV	CONTINUOUS OPERATING TEMPERATURE LIMITS	
		300 FPM	500 FPM	625 FPM			180° F	82° C
2" PREpleat M10 SC	10	0.18"	0.28"	0.39"	1.0"	10	180° F	82° C
MODEL NUMBER	NOMINAL A x B (INCHES)	ACTUAL A x B (INCHES)	RATED AIRFLOW			PLEATS PER FILTER	GROSS MEDIA AREA (sq. ft.)	
			300 FPM	500 FPM	625 FPM			
80055.021020	10 x 20	9 1/2 x 19 1/2	400	700	900	8	3.9	
80055.021212	12 x 12	11 3/8 x 11 3/8	300	500	625	10	2.9	
80055.021220	12 x 20	11 1/2 x 19 1/2	500	850	1050	10	4.9	
80055.021224	12 x 24	11 3/8 x 23 3/8	600	1000	1250	10	5.8	
80055.021420	14 x 20	13 1/2 x 19 1/2	600	1000	1150	12	5.8	
80055.021425	14 x 25	13 1/2 x 24 1/2	750	1200	1500	12	7.3	
80055.021520	15 x 20	14 1/2 x 19 1/2	650	1050	1300	13	6.3	
80055.021616	16 x 16	15 1/2 x 15 1/2	550	900	1100	14	5.4	
80055.021620	16 x 20	15 1/2 x 19 1/2	650	1100	1400	14	6.8	
80055.021625	16 x 25	15 1/2 x 24 1/2	850	1400	1750	14	8.5	
80055.021824	18 x 24	17 3/8 x 23 3/8	900	1500	1900	15	8.8	
80055.021825	18 x 25	17 1/2 x 24 1/2	950	1550	1950	15	9.1	
80055.022020	20 x 20	19 1/2 x 19 1/2	850	1400	1750	17	8.3	
80055.022024	20 x 24	19 3/8 x 23 3/8	1000	1650	2100	17	9.9	
80055.022025	20 x 25	19 1/2 x 24 1/2	1050	1750	2150	17	10.3	
80055.022424	24 x 24	23 3/8 x 23 3/8	1200	2000	2500	20	11.7	
80055.022525	25 x 25	24 1/2 x 24 1/2	1300	2150	2400	21	12.8	



Specifications:

- 1 MERV 10 per ASHRAE Standard 52.2
- 2 Frame - High wet strength 24 point beverage board.
- 3 Media - 100% synthetic.
- 4 Support Grid - Single dimension expanded metal bonded 100% to media.
- 5 Adhesive - White glue utilized to attach straps to media and media to the frame
- 6 UL Certified

FORM I297 REV. 5/00

DRAWN GAC	DATE 12APR2024	CHECKED GC	DATE 18APR2024	APPR. AH	DATE 19APR2024
--------------	-------------------	---------------	-------------------	-------------	-------------------



P.O. Box 35690
 Louisville, KY.
 40232-5690
www.aafintl.com

FILTER ASSEMBLY, 2" PREpleat
 M10 SC (SALES)

DRAWING NO.	REV
3189327	A
SHEET 1 OF 1	