

## **M9134E-AE OPERATING INSTRUCTIONS**

### **ACSI M1520M-AE**

Mortise lock with Authorized Egress (AE) Monitoring, also referred to as Request to Exit or RX Switch.

#### **AE – AUTHORIZED EGRESS**

The AE switch monitors the use of the INSIDE trim when the OUTSIDE trim is locked

#### **ELECTRICAL SPECIFICATIONS**

SPDT Mechanical Switch

<u>VOLTAGE</u>	<u>CURRENT</u>
125 VAC	1 AMP
30 VDC	0.5 AMP

NOTE: Mainly used as a dry contact monitoring switch

#### WIRING DIAGRAM

**YELLOW WIRE** – Common  
**RED WIRE** – Normally Open  
**GRAY WIRE** – Normally Closed

