

Certificate No: TAE00004AW

TYPE APPROVAL CERTIFICATE

| This is to certify: | |
|---|---|
| That the UPS | |
| with type designation(s) RT DELTA | |
| Anda-Olsen AS Ålesund, Norway | |
| is found to comply with DNV GL rules for classification – Ships, offshore units, an | d high speed and light craft |
| Application: | |
| Products approved by this certificate are accepted for insta | Illation on all vessels classed by DNV. |
| Issued at Høvik on 2021-07-13 | |
| This Certificate is valid until 2026-07-12. | for DNV |
| DNV local station: Ålesund | |
| Approval Engineer: Nicolay Horn | |
| | Marta Alonso Pontes |
| | Head of Section |

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.

Form code: TA 251

Revision: 2021-03

www.dnv.com

Page 1 of 3



Page 1 of 3

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job ld: **262.1-034743-1** Certificate No: **TAE00004AW**

Product description

DELTA RT: UPS for general emergency equipment, equipped with battery.

| Model | RT 1K | RT 2K | RT 3K | |
|-------------------------------|---|--|--------------------------------------|--|
| Rating | 1 kVA / 0.9 kW | 2 kVA / 1.8 kW | 3 kVA / 2.7 kW | |
| Input | | | | |
| Nominal Voltage (V) | 200 / 208 / 220/ 230 /240 (200 & 208 derated to 90 %) | | | |
| Voltage range | 175 -200 (full range) / 120 – 175 (70 – 100 % load) | | | |
| Frequency (Hz) | 40 -70 | | | |
| Power factor | 0.9 | 0.9 | | |
| Output | | | | |
| Output voltage (V) | 200 / 208 / 220/ 230 /240 (200 & 208 derated to 90 %) | | | |
| Frequency (Hz) | 50 / 60 ± 0.05 | 50 / 60 ± 0.05 | | |
| Voltage harmonic distortion | 3 % (linear load) | 3 % (linear load) | | |
| Overload capacity | < 105 % continues / 105 | < 105 % continues / 105 - 125% 1 min / 125 - 150% 15 sec. | | |
| Batteries | | | | |
| Туре | 2 x NH 12-120 | 4 x NH 12-120 | 6 x NH 12-120 | |
| Battery voltage (V) | 24 DC | 48 DC | 72 DC | |
| Typical backup time | 20 min full load, 30 min 75% load | 20 min full load, 30 min 75% load | 20 min full load, 30 min 75% load | |
| Charge current (A) | 4 A (up to 8) | | | |
| Recharge time | 6 hours to 90 % | | | |
| Environmental conditions | | | | |
| Operating temperature | 0 to +50°C (When the op | 0 to +50°C (When the operating temperature is 40 -50 °C derate to 80 % | | |
| Relative humanity | 5 to 95 % (non condensing) | | | |
| Dimensions | , | | | |
| Overall dimensions (HxWxD) mm | 790 x 600 x 750 (Small), 995 x 600 x 750 (Large) | | | |
| <u> </u> | <u> </u> | <u>-</u> | | |

| Classification according to DNV GL-CG-0339 | | |
|--|------|--|
| Temperature class | A | |
| Vibration class | A | |
| Humidity class | Α | |
| Enclosure class | IP23 | |
| EMC class | Α | |

Application/Limitation

End user is responsible for correct enclosure protection (IP) with respect to location.

To be installed in climatically controlled areas.

Type Approval documentation

Tests carried out

Type tests in accordance with IEC 62040-1 and 3, EMC (Class A), Vibration, Damp heat (Class A no condensation) and Dry heat (Class A) in accordance with DNVGL-CG-0339 December 2019.

Marking of product

ANDA Olsen - RT DELTA - technical data

Form code: TA 251 Revision: 2021-03 www.dnv.com Page 2 of 3



Job Id: **262.1-034743-1** Certificate No: **TAE00004AW**

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the periodical assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routines (RT) checked (if not available tests, RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment shall be performed at 2 and 3.5 year and at renewal.

END OF CERTIFICATE

Form code: TA 251 Revision: 2021-03 www.dnv.com Page 3 of 3