

CITY OF BALTIMORE

BRANDON M. SCOTT, Mayor



DEPARTMENT OF PUBLIC WORKS

Khalil Zaied, Director
Abel Wolman Municipal Building, 6th Floor
200 N. Holliday Street
Baltimore, Maryland 21202

September 25, 2025

[REDACTED]
Glenmore Avenue
Baltimore, Maryland 21214

Dear Consumer:

Drinking water samples were collected from 3206 Glenmore Avenue on 9/17/25:
sample source (bathroom) and analyzed at the Montebello Laboratory.

The results are as follows:

CHEMICAL:

Chlorine mg/L	0.05
pH, units	7.55
Ammonia, mg/L	0.0145
Iron, mg/L	0.388
Turbidity, NTU	0.821
TDS, mg/L	173.0
Color	9

MICROBIOLOGICAL:

Colilert	Negative
Heterotrophic Plate Count/mL	88 cfu

The Chemical analysis results for Iron are not within regulations of potable water for the parameters analyzed; set by the EPA. However, the Microbiological results are within limits, and a main flush has been requested to clear the discoloration.

If there are any additional questions concerning this report, please feel free to contact Timothy Herndon (Microbiology Supervisor) at (410) 396-6040.

Kind Regards,

[REDACTED]
Office Support Specialist III
Laboratory Operations Division