

Inspections: Damaged Pole Report

Service Request: 26-00027147 Sector: _____ Gateway: _____ Primary: _____

Location on Service Request: 3361 Beech Ave

Grid : 1030130 LLC: 7053

Descriptive Location and Comments:

Street: Beech Ave

Side of Street: N/S _____ E/S ☒ S/S _____ W/S _____

Pole location: 1st ☒ 2nd _____ 3rd _____ 4th _____ 5th _____ 6th _____ Other _____

Direction : N/O _____ E/O _____ S/O ☒ W/O _____

Street or Landmark: W. 34th St

Condition of Pole:

Pole Size :

Type of Pole:

Deteriorated ☒ 11'6" _____

Aluminum ☒

Missing ☒ 12' _____

Steel _____

Damaged _____ 25' ☒

Galvanized Steel _____

Arm/Fixture Missing _____ 30' _____

Fiberglass _____

Other _____ 40' _____

Bolton Hill _____

Other _____

Otterbein _____

Homeland _____

Wooden _____

Other _____

Need new base

Fixture Type:

Lamp Type:

Wattage:

Arm:

Arm Condition:

Cobra Head ☒

HPS Vapor ☒

100 _____

6' ☒

Damaged _____

PMA _____

Mercury Vapor _____

150 _____

10' _____

Missing _____

Otterbein _____

Metal Halide _____

175 _____

15' _____

Homeland _____

LED _____

200 _____

20' _____

Bolton Hill _____

Other _____

250 _____

Other _____

Victorian Acorn _____

400 ☒

Other _____

1000 _____

Pedestal Base:

Base Condition: Good _____ Bad: _____


Base Type:

Yes ☒
No ☒

Bolts ☒
Wires ☒
Conduit ☒

Metal ☒
Concrete _____

Date: 1/12/2026 Inspector's Signature: G. Crowder 8512



✓ 302 to Beech Ave
505 W - 34th St

Mark's father's house

Service Request Summary Report
26-00027147
Printed Date: Jan 14, 2026 - 3:20:13 PM

Type: BGE-StLight Pole Installation
Created By: Keeva Flood
Service Request Owner: BGE
Method Received: Phone
SLA Detail: 45 Business Days

SR #: 26-00027147
Priority: Urgent
Status: Pending
Status Date: Jan 14, 2026 3:16:47 PM
Created Date: Jan 11, 2026 6:44:32 PM
Overdue on: Mar 17, 2026 11:33:11 AM
Closed on:

Location: 3361 BEECH AVE, Baltimore City,
21211

Location Details:
Description:

Service Questions

Questions	Answers
-----------	---------

Contact Information

Name	Address	Email	Phones/Extensions
Elizabeth Keppel	3355 BEECH AVE, Baltimore City, MD, 21211	ebkeppel@gmail.com	+1 (540) 578-6226

Service Activities

Activity Name	Status	Assigned To	Outcome	Outcome Reason	Finish Date
Assign inspector	Complete	Gregory Crowder	Assigned		1/14/2026 3:15 PM

Service Response Not Started

Resolution Questions

Service Activity	Resolution Question	Resolution Answer
Assign inspector	GRID #	1030130
Assign inspector	LLC / POLE #	7053
Assign inspector	BGE AS8 Work Order Number	
Assign inspector	BCRL #	
Assign inspector	BCRL Created date	
Assign inspector	Pole type	25 ft Aluminum Pole
Assign inspector	Type of Fixture	Cobrahead
Assign inspector	Wattage of the Fixture	400 Watts
Assign inspector	Base type	Metal

Comments

Comment	Comment By	Created Date	Visibility
Assign inspector : missing pole report created on 1-12-26	Gregory Crowder	1/14/2026 3:16 PM	Private

Related Child Service Requests