

PERMIT NUMBER

242503

CITY OF BALTIMORE

FIRE DEPARTMENT FIRE PREVENTION BUREAU
410 EAST LEXINGTON STREET, BALTIMORE, MARYLAND 21202

EXPIRATION DATE

00/00/00

FIRE PREVENTION ANNUAL PERMIT

THIS PERMIT MUST BE KEPT ON PERMITTED PREMISES AVAILABLE TO CODE OFFICIAL UPON REQUEST (105.1.1)

MS DIAMOND DAVIS
HAMILL COURT CONDO ASSOC.
P.O. BOX 20921
BALTIMORE, MARYLAND 21209

INDIVIDUAL/BUSINESS

HAMILL COURT CONDOMINIUM

PERMITTED PREMISES LOCATION

1. HAMILL CT

410-433-2081

ISSUE DATE

02/09/26

EXPIRATION DATE

00/00/00

RENEWAL FEE

\$310.00

PAID DATE

04/10/25

APPROVED BY:

MICHAEL W HINELINE, FI, FPB-87

THE ABOVE NAMED INDIVIDUAL/BUSINESS IS HEREBY GRANTED PERMISSION TO CONDUCT THE FOLLOWING BUSINESS AT THE ABOVE PERMITTED PREMISES LOCATION. ON THE ABOVE MENTIONED INSPECTION DATE THE PREMISES WAS COMPLIANT WITH PART VIII OF THE BUILDING, FIRE, AND RELATED CODES OF BALTIMORE CITY. ALL AGENCIES REQUIRED TO INSPECT FOR THIS TYPE OF BUSINESS MUST APPROVE PRIOR TO OPERATIONS. IF CHANGES ARE MADE TO THE BUSINESS OR OPERATION YOU MUST CONTACT THE FIRE PREVENTION BUREAU IMMEDIATELY AT 410-396-5752.

MID RISE APARTMENT BUILDING

CONTACT: DIAMOND DAVIS


SEQ 410005-27

FIRE PERMIT FEE CODES IN ACCORDANCE WITH BUILDING, FIRE AND RELATED CODES OF BALTIMORE CITY PART VIII, CHAPTER 1, SECTION 105

FEE CODES: F105.6.48

Chief of Fire Department

**** AN ANNUAL INSPECTION IS REQUIRED TO OPERATE THIS BUSINESS.****
****THIS PERMIT IS INVALID AFTER THE EXPIRATION DATE ****



IF YOU DO NOT RECEIVE NOTIFICATION TO RENEW 30 DAYS PRIOR TO EXPIRATION DATE CALL (410) 396-5752

NOTICE TO THE PERMIT HOLDER

105.3.9 Violation of permit. Failure to comply with any term or condition of any permit issued under BUILDING, FIRE, AND RELATED CODES OF BALTIMORE CITY constitutes a violation of this Code and subjects the violator to the penalties prescribed in § 109 ("Violations") of the BUILDING, FIRE AND RELATED CODES OF BALTIMORE CITY.

FIRE PREVENTION BUREAU
410 EAST LEXINGTON STREET
BALTIMORE, MARYLAND 21202

For questions concerning this Certificate, please call the Baltimore City Fire Department, Office of the Fire Marshal at 410-396-5752.

PLEASE BE AWARE OF THE FOLLOWING FOR COMPLIANCE:

- FIRE EXTINGUISHERS ARE TO BE SERVICED AS PER NFPA-10, ANNUALLY
- ALARM SYSTEMS ARE TO BE TESTED/INSPECTED AS PER NFPA-72, ANNUALLY
- SPRINKLER SYSTEMS ARE TO BE TESTED/INSPECTED AS PER NFPA-25, ANNUALLY
- COMMERCIAL HOOD SUPPRESSION SYSTEMS ARE TO BE TESTED/INSPECTED AS PER NFPA-17A, SEMIANNUALLY (Every 6 months)
- SPANISH MOSS AND/OR CUT TREES ARE PROHIBITED
- SPRINKLER SYSTEMS ARE TO BE TESTED/INSPECTED AS PER NFPA-25
- EXIT SIGNS MUST BE ILLUMINATED
- ALL EXITS MUST BE CLEAR OF ANY DEBRIS AND UNLOCKED WHEN THE BUILDING IS OCCUPIED
- EMERGENCY LIGHTENING MUST FUNCTION PROPERLY
- FIRE PUMP IS TO BE TESTED/INSPECTED AS PER NFPA-25, ANNUALLY
- NO STORAGE OF ANY KIND AROUND UTILITIES, (ELECTRICAL PANEL, FURNACE, WATER HEATER, ETC.)