

CITY OF BALTIMORE

BRANDON M. SCOTT, Mayor



DEPARTMENT OF PUBLIC WORKS

Matthew W. Garbark, Acting Director
Abel Wolman Municipal Building
200 Holliday Street, 6th Floor
Baltimore, Maryland (MD) 21202

September 24, 2025

Premier Rides Inc
Curtis Lawson
1077 E Pratt Street
Baltimore, Maryland 21202

Dear Consumer:

Drinking water samples were collected from 1077 E Pratt Street on 9/16/25: sample source (bathroom) and analyzed at the Montebello Laboratory.

The results are as follows:

CHEMICAL:

Chlorine, mg/L	0.08
pH, units	8.07
Ammonia, mg/L	0.0145
Iron, mg/L	0.163
Turbidity, NTU	2.67
TDS, mg/L	181.9
Color	7
Odor, TON	Moldy/Musty

MICROBIOLOGICAL:

Colilert	Negative
Heterotrophic Plate Count/mL	4 cfu

The Chemical result (Turbidity) does not meet the regulations of potable water for the parameters analyzed set by the EPA. However, all Microbiological results are within regulation and are negative for E. coli.

If there are any additional questions concerning this report, please feel free to contact Timothy Herndon (Microbiology Supervisor) at (410) 396-6040.

Kind Regards,

LaTonya Hall
Office Support Specialist III
Laboratory Operations Division