



From MCATEE LLC (MD & N VA)
(TM)
P. O. Box 5594
Mooresville, NC 28117
claims@mcateellc.com
+18043620451

Job ID #	114265417	Estimate for	Brendan Crowley
Estimate #	19811		114 UPNOR RD
Issue date	Sep 09, 2026		Baltimore, MD 21212
Job Address	114 UPNOR RD, Baltimore MD, 21212		bcrowley525@gmail.com

Item	Quantity	Price	Total
Proof of Repair	1	\$0.00	\$0.00

Arrived on site customer reported toilet backing up downstairs in the basement. He explained to me that he's had plumbers out here before and they have cleared the line and inspected it with the camera. I let them know. Mcatee plumbing will have to do their own investigation. I pulled the toilet ran my snake all the way out about 75 feet with my K 400 rigid drain cleaning machine felt some resistance at the end of my cable when I pushed all the way out, pulled back some tree roots was able to relieve the line of the clog. I let the customer know this roots will most likely grow back and I believe it is on the cities, sewer line territory and not on the customers property at this point let the customer know if this happens again we can request authorization for a camera if need be and to contact the city to see if they will take accountability for their sewer line issue that is causing problems for this customer... as of right now everything is open and flowing today's job is complete.
Per terms & conditions of warranty company.

By James Rozsa @ 11:17AM, 09/09/2026

Subtotal	\$0.00
Tax	\$0.00
Total	\$0.00