

CITY OF BALTIMORE

BRANDON M. SCOTT, Mayor



DEPARTMENT OF PUBLIC WORKS

Matthew W. Garbark, Director
Abel Wolman Municipal Building
200 Holliday Street, 6th Floor
Baltimore, Maryland (MD) 21202

September 9, 2026

Curtis Lawson
1007 E Pratt Street
Baltimore, MD 21202

Dear Consumer:

Drinking water samples were collected from 1007 E Pratt St on 8/3/26: sample source (Bathroom) and analyzed at the Montebello Laboratory.

The results are as follows:

CHEMICAL:

Chlorine, mg/L	0.02
pH, units	8.75
Ammonia, mg/L	0.0132
Iron, mg/L	0.340
Turbidity, NTU	5.57
TDS, mg/L	171.5
Color	12
Odor/TON	Strong Musty

MICROBIOLOGICAL:

Colilert	Negative
Heterotrophic Plate Count/mL	4 cfu

Due to elevated pH, Iron, Turbidity and Color levels the Chemistry results are not within regulations of potable water for the parameters analyzed; set by the EPA.

However, the Microbiology results are within regulation.

If there are any additional questions concerning this report, please feel free to contact Timothy Herndon (Microbiology Supervisor) at (410) 396-6040.

Kind Regards,

LaTonya Hall
Office Support Specialist III
Laboratory Operations Division