



Lubricant Analysis Report

North America: +1-877-808-3750
Latin America: +1-317-808-3750 / +502-3093-6466 (WhatsApp)
Europe: +1-317-808-3750

0	1	2	3	4
NORMAL		ABNORMAL	CRITICAL	

Overall report severity based on comments.

Account Information		Component Information		Sample Information	
Account Number: 153995-0002-0000 Company Name: BOOM & BUCKET Contact: KRIS HUFF Address: 600 CONGRESS AVE AUSTIN, TX US Phone Number: 1888-313-1597/909-846-6495		Component ID: 2020 SMART GEN E Secondary ID: SGC-100GF Component Type: DIESEL ENGINE Manufacturer: CUMMINS Model: 6BT5.9-G6 Application: UNKNOWN Sump Capacity:		Tracking Number: 22222W10889 Lab Number: S-956427 Lab Location: Salt Lake City Data Analyst: KDN Sampled: 23-Jan-2023 Received: 22-Mar-2023 Completed: 23-Mar-2023	
Filter Information		Miscellaneous Information		Product Information	
Filter Type: Information Requested Micron Rating: 0				Product Manufacturer: Information Requested Product Name: Information Requested Viscosity Grade: Information Requested	
Comments	Flagged data does not indicate an immediate need for maintenance action. Continue to observe the trend and monitor equipment and fluid conditions. Base number is flagged, however without complete lubricant information, the starting point for this lubricant cannot be determined. FUEL DILUTION is at a MINOR LEVEL. FUEL DILUTION possibly caused by excessive idling; Unit and/or lubricant TIME missing. Please provide missing application and sump information.				

	Wear Metals (ppm)										Contaminant Metals (ppm)			Multi-Source Metals (ppm)						Additive Metals (ppm)				
Sample #	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
1	35	1	0	3	9	2	0	0	0	0	6	2	0	0	64	0	1	0	26	802	1409	0	1004	1214

Sample Information								Contaminants			Fluid Properties					
Sample #	Date Sampled	Date Received	Lube Time	Unit Time	Lube Change	Lube Added	Filter Change	Fuel Dilution	Soot	Water	Viscosity 40°C	Viscosity 100 °C	Acid Number	Base No. D4739	Oxidation	Nitration
			h	h	Lube gal			%	%	%	cSt	cSt	mg KOH / g	mg KOH / g	abs / cm	abs / 0.1mm
1	23-Jan-2023	22-Mar-2023	0	0	Unk	0	Unk	3.4 - GC	0.2 - E2412	<.1 - FTIR		13.0		3.84	16	10

Particle Count (particles/mL)										Additional Testing				
Sample #	ISO Code	> 4	> 6	> 10	> 14	> 21	> 38	> 70	> 100	Test Method				
	Based On	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL					
1	4/6/14	/ /												

Comments are advisory only and are based on the assumption that the sample and data submitted are valid. Results relate only to the items tested. Missing fluid or component information limits the evaluation. No warranty is expressed or implied. Measurement uncertainty available upon request.