



Lubricant Analysis Report

North America: +1-877-808-3750
+1-317-808-3750 / +502-3093-
Latin America: 6466 (WhatsApp)
Europe: +1-317-808-3750

0	1	2	3	4
NORMAL	ABNORMAL			Critical

Overall report severity based on comments.

Account Information		Component Information										Sample Information					
Account Number: 153995-0002-0001		Component ID: GTH5514B-237 E Secondary ID:										Tracking Number: 23181X07005 Lab Number: S-043479 Lab Location: Salt Lake City Data Analyst: FLG Sampled: 11-Sep-2023 Received: 13-Sep-2023 Completed: 14-Sep-2023					
Company Name: BOOM & BUCKET Contact: KRIS HUFF Address: 701 BRAZOS ST AUSTIN, TX 78701 US Phone Number: 909-846-6495/888-417-3477		Component Type: UNIDENTIFIED ENGINE Manufacturer: GENIE LIFT Model: Information Requested Application: UNKNOWN Sump Capacity:															
Filter Information		Miscellaneous Information										Product Information					
Filter Type: Information Requested Micron Rating: 0												Product Manufacturer: Information Requested Product Name: Information Requested Viscosity Grade: Information Requested					
Comments	Data indicates no abnormal findings. Resample at normal interval. Please provide COMPONENT MODEL number to compare data to the correct standards for this component. Please provide missing lubricant information. Manufacturer, product name, and viscosity grade are needed to properly evaluate lubricant properties. Unit and/or lubricant TIME missing.																

Sample #	Wear Metals (ppm)								Contaminant Metals (ppm)			Multi-Source Metals (ppm)				Additive Metals (ppm)								
	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
1	4	0	0	2	0	0	0	0	0	0	6	2	0	0	67	40	0	0	1	906	1243	0	1132	1442

Sample #	Sample Information						Contaminants				Fluid Properties					
	Date Sampled	Date Received	Lube Time	Unit Time	Lube Change	Lube Added	Filter Change	Fuel Dilution	Soot	Water	Viscosity 40°C	Viscosity 100 °C	Acid Number	Base No. D4739	Oxidation	Nitration
1	11-Sep-2023	13-Sep-2023	0	0	Unk	0	Unk	<2 - Estimate	<.1	<.1 - FTIR	14.8	cSt	mg KOH / g	mg KOH / g	abs / cm	abs / 0.1mm

Sample #	Particle Count (particles/mL)										Additional Testing					
	ISO Code	> 4	> 6	> 10	> 14	> 21	> 38	> 70	> 100	Test Method						
1	Based On 4/6/14	particles / mL														

Comments are advisory only and are based on the assumption that the sample and data submitted are valid. Results relate only to the items tested. Missing fluid or component information limits the evaluation. No warranty is expressed or implied. Measurement uncertainty available upon request.