



Lubricant Analysis Report

North America: +1-877-808-3750
 Latin America: +1-317-808-3750 / +502-3093-6466 (WhatsApp)
 Europe: +1-317-808-3750

0	1	2	3	4
NORMAL	ABNORMAL		CRITICAL	

Overall report severity based on comments.

Account Information		Component Information		Sample Information	
Account Number: 153995-0003-0000 Company Name: BOOM & BUCKET Contact: STEVEN MESA Address: 701 BRAZOS ST. STE 300 AUSTIN, TX US Phone Number: 888-417-3477		Component ID: 2011JDF135DX E Secondary ID: A6419627 Component Type: UNIDENTIFIED ENGINE Manufacturer: Information Requested Model: Information Requested Application: UNKNOWN Sump Capacity:		Tracking Number: 23209G30305 Lab Number: H-488400 Lab Location: Houston Data Analyst: AC Sampled: 27-Sep-2023 Received: 05-Oct-2023 Completed: 06-Oct-2023	
Filter Information		Miscellaneous Information		Product Information	
Filter Type: Information Requested Micron Rating: 0				Product Manufacturer: Information Requested Product Name: Information Requested Viscosity Grade: Information Requested	
Comments	TITANIUM may be an additive in this lubricant; In order to properly compare data to the correct standards, please provide COMPONENT MANUFACTURER and MODEL, and the FLUID MANUFACTURER, PRODUCT NAME, and VISCOSITY GRADE. Unit and/or lubricant TIME missing.				

Sample #	Wear Metals (ppm)										Contaminant Metals (ppm)			Multi-Source Metals (ppm)					Additive Metals (ppm)					
	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
1	3	0	0	1	1	1	0	0	0	0	6	4	2	87	4	0	0	0	159	430	1732	0	1023	1160

Sample Information									Contaminants			Fluid Properties				
Sample #	Date Sampled	Date Received	Lube Time	Unit Time	Lube Change	Lube Added	Filter Change	Fuel Dilution	Soot	Water	Viscosity 40°C	Viscosity 100 °C	Acid Number	Base No. D4739	Oxidation	Nitration
			h	h		gal		%	%	%	cSt	cSt	mg KOH / g	mg KOH / g	abs / cm	abs / 0.1mm
1	27-Sep-2023	05-Oct-2023	0	0	Unk	0	Unk	<2 - Estimate	<.1	<.1 - FTIR		14.5		7.22	10	6

Particle Count (particles/mL)										Additional Testing		
Sample #	ISO Code	> 4	> 6	> 10	> 14	> 21	> 38	> 70	> 100	Test Method		
	Based On	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL			
1	4/6/14	/ /										

Comments are advisory only and are based on the assumption that the sample and data submitted are valid. Results relate only to the items tested. Missing fluid or component information limits the evaluation. No warranty is expressed or implied. Measurement uncertainty available upon request.