



Lubricant Analysis Report

North America: +1-877-808-3750
 Latin America: +1-317-808-3750 / +502-3093-6466 (WhatsApp)
 Europe: +1-317-808-3750

0	1	2	3	4
NORMAL	ABNORMAL		CRITICAL	

Overall report severity based on comments.

Account Information		Component Information		Sample Information	
Account Number: 153995-0003-0000 Company Name: BOOM & BUCKET Contact: STEVEN MESA Address: 701 BRAZOS ST. STE 300 AUSTIN, TX US Phone Number: 888-417-3477		Component ID: 2013 JOHN DEERE 50D Secondary ID: B&B A3848495 Component Type: DIESEL ENGINE Manufacturer: Information Requested Model: Information Requested Application: UNKNOWN Sump Capacity:		Tracking Number: 23209G30308 Lab Number: H-488823 Lab Location: Houston Data Analyst: FLG Sampled: 28-Sep-2023 Received: 05-Oct-2023 Completed: 06-Oct-2023	
Filter Information		Miscellaneous Information		Product Information	
Filter Type: Information Requested Micron Rating: 0				Product Manufacturer: Information Requested Product Name: Information Requested Viscosity Grade: Information Requested	
Comments	Data indicates no abnormal findings. Resample at normal interval. In order to properly compare data to the correct standards, please provide COMPONENT MANUFACTURER and MODEL, and the FLUID MANUFACTURER, PRODUCT NAME, and VISCOSITY GRADE. Unit and/or lubricant TIME missing.				

Sample #	Wear Metals (ppm)										Contaminant Metals (ppm)			Multi-Source Metals (ppm)					Additive Metals (ppm)					
	Iron	Chromium	Nickel	Aluminum	Copper	Lead	Tin	Cadmium	Silver	Vanadium	Silicon	Sodium	Potassium	Titanium	Molybdenum	Antimony	Manganese	Lithium	Boron	Magnesium	Calcium	Barium	Phosphorus	Zinc
1	5	0	0	2	0	0	0	0	0	0	11	3	0	0	87	0	0	0	61	45	2271	0	1119	1203

Sample #	Sample Information								Contaminants			Fluid Properties					
	Date Sampled	Date Received	Lube Time	Unit Time	Lube Change	Lube Added	Filter Change	Fuel Dilution	Soot	Water	Viscosity 40°C	Viscosity 100 °C	Acid Number	Base No. D4739	Oxidation	Nitration	
			h	h		gal		%	%	%	cSt	cSt	mg KOH / g	mg KOH / g	abs / cm	abs / 0.1mm	
1	28-Sep-2023	05-Oct-2023	0	0	Unk	0	Unk	<2 - Estimate	<.1	<.1 - FTIR		14.2		6.06	11	9	

Sample #	Particle Count (particles/mL)										Test Method	Additional Testing	
	ISO Code	> 4	> 6	> 10	> 14	> 21	> 38	> 70	> 100				
	Based On	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL	particles / mL			
1	4/6/14	/ /											

Comments are advisory only and are based on the assumption that the sample and data submitted are valid. Results relate only to the items tested. Missing fluid or component information limits the evaluation. No warranty is expressed or implied. Measurement uncertainty available upon request.