## Adjustable Swivel Ring Hangers

Designed for the suspension of non-insulated stationary pipe lines. The knurled insert

nut that allows a vertical adjustment after installation, is tapped to NFPA reduced rod size standards. Captured knurled insert nut present on pipe sizes 1/2" (15mm) to

2"(50mm). The capture is permanent in the bottom portion of the band, allowing the

hanger to be opened during installation if desired, but preventing the knurled insert nut from falling completely out. Fig. 141F has a layer of felt which separates the pipe from



Fig. 141 & 141F **NFPA SWIVEL RING HANGER** 


Fig. 141 PRE-GALVANIZED Fig. 141F PRE-GALVANIZED WITH FELT LINING

the hanger to reduce vibration and sound. APPROVALS: Underwriters' Laboratories Listed in the U.S. (UL), Canada (CUL), for use with standard steel pipe sizes 3/4" (20mm) to 8"(200mm) and CPVC pipe sizes 3/4" (20mm) to 4"(100mm). Factory Mutual Approved for sizes 3/4" (20mm) to 8"(200mm). Complies with Federal Specifications A-A-1192A (Type 10), and Manufacturers' Standardization Society ANSI/SP-69 and SP-58 (Type 10).

ORDERING: Specify pipe size and figure number.

**FUNCTION:** 

Rod				Adj.						Max. Rec. Load		Wt. Each		
Pipe Size		Size	В		Ċ		D		E		lbs.	kN	lbs.	kg
<sup>1</sup> / <sub>2</sub>	(15)	<sup>3</sup> / <sub>8</sub>	1 <sup>7</sup> / <sub>8</sub>	(47.63)	1 <sup>7</sup> / <sub>16</sub>	(36.51)	2 <sup>3</sup> / <sub>4</sub>	(69.85)	3 <sup>1</sup> / <sub>16</sub>	(77.79)	300	(1.33)	.10	(.05)
<sup>3</sup> / <sub>4</sub>	(20)	<sup>3</sup> / <sub>8</sub>	1 <sup>11</sup> / <sub>16</sub>	(42.86)	1 <sup>1</sup> / <sub>8</sub>	(28.58)	2 <sup>1</sup> / <sub>2</sub>	(63.50)	3 <sup>1</sup> / <sub>16</sub>	(77.79)	300	(1.33)	.10	(.05)
1	(25)	<sup>3</sup> / <sub>8</sub>	1 <sup>5</sup> /8	(41.28)	1	(25.40)	2 <sup>1</sup> / <sub>2</sub>	(63.50)	3 <sup>3</sup> / <sub>16</sub>	(80.96)	300	(1.33)	.10	(.05)
<b>1</b> <sup>1</sup> / <sub>4</sub>	(32)	<sup>3</sup> / <sub>8</sub>	1 <sup>15</sup> / <sub>16</sub>	(49.21)	<b>1</b> <sup>1</sup> / <sub>16</sub>	(26.99)	2 <sup>13</sup> / <sub>16</sub>	(71.44)	3 <sup>9</sup> / <sub>16</sub>	(90.49)	300	(1.33)	.11	(.05)
1 <sup>1</sup> / <sub>2</sub>	(40)	<sup>3</sup> / <sub>8</sub>	2 <sup>1</sup> / <sub>8</sub>	(53.98)	<b>1</b> <sup>1</sup> / <sub>16</sub>	(26.99)	3 <sup>1</sup> / <sub>8</sub>	(79.38)	3 <sup>7</sup> / <sub>8</sub>	(98.43)	300	(1.33)	.11	(.05)
2	(50)	<sup>3</sup> /8	2 <sup>7</sup> / <sub>16</sub>	(61.91)	1 <sup>1</sup> / <sub>8</sub>	(28.58)	3 <sup>5</sup> / <sub>16</sub>	(84.14)	4 <sup>3</sup> / <sub>8</sub>	(111.13)	300	(1.33)	.14	(.06)
2 <sup>1</sup> / <sub>2</sub>	(65)	<sup>3</sup> / <sub>8</sub>	3 <sup>1</sup> / <sub>16</sub>	(77.79)	1 <sup>5</sup> / <sub>8</sub>	(41.28)	3 <sup>15</sup> / <sub>16</sub>	(100.01)	5 <sup>3</sup> / <sub>8</sub>	(136.53)	525	(2.34)	.19	(.09)
3	(80)	<sup>3</sup> / <sub>8</sub>	3 <sup>11</sup> / <sub>16</sub>	(93.66)	1 <sup>7</sup> / <sub>8</sub>	(47.63)	4 <sup>9</sup> / <sub>16</sub>	(115.89)	6 <sup>5</sup> / <sub>16</sub>	(160.34)	525	(2.34)	.23	(.10)
3 <sup>1</sup> / <sub>2</sub>	(90)	<sup>3</sup> / <sub>8</sub>	3 <sup>3</sup> / <sub>4</sub>	(95.25)	1 <sup>7</sup> / <sub>8</sub>	(47.63)	4 <sup>5</sup> / <sub>8</sub>	(117.48)	6 <sup>5</sup> / <sub>8</sub>	(168.28)	525	(2.34)	.25	(.11)
4	(100)	<sup>3</sup> /8	4 <sup>3</sup> / <sub>16</sub>	(106.36)	1 <sup>7</sup> / <sub>8</sub>	(47.63)	5 <sup>1</sup> / <sub>16</sub>	(128.59)	<b>7</b> <sup>5</sup> / <sub>16</sub>	(185.74)	650	(2.89)	.30	(.14)
5	(125)	<sup>1</sup> / <sub>2</sub>	4 <sup>5</sup> / <sub>8</sub>	(117.48)	1 <sup>5</sup> / <sub>8</sub>	(41.28)	5 <sup>5</sup> /8	(142.88)	8 <sup>3</sup> / <sub>8</sub>	(212.73)	1000	(4.45)	.50	(.23)
6	(150)	<sup>1</sup> / <sub>2</sub>	5 <sup>5</sup> /8	(142.88)	2 <sup>1</sup> / <sub>4</sub>	(57.15)	6 <sup>1</sup> / <sub>2</sub>	(165.10)	9 <sup>13</sup> / <sub>16</sub>	(249.24)	1000	(4.45)	.58	(.26)
8	(200)	<sup>1</sup> / <sub>2</sub>	6 <sup>13</sup> / <sub>16</sub>	(173.04)	2 <sup>7</sup> / <sub>16</sub>	(61.91)	7 <sup>15</sup> / <sub>16</sub>	(201.61)	12 <sup>1</sup> / <sub>4</sub>	(311.15)	1000	(4.45)	.90	(.41)



MATERIAL: Low carbon steel Metric knurl insert nuts available upon request

Note: If ordering Fig. 141F felt lined hangers for pipe sizes of 31/2" (90mm) or under, order the next largest size to allow for the thickness of the felt lining.


	TION:	П	ocianod	for the sus	nonci	on of non	inculat	ad stations	my pip	lines The	knurlo	4			
FUNC	TION:		Designed for the suspension of non-insulated stationary pipe lines. The knurled insert nut, allows for vertical adjustment after installation. Fig. 151F has a layer of felt which separates the pipe from the hanger to reduce vibration and sound. Underwriters' Laboratories Listed in the U.S. (UL) and Factory Mutual Approved												Fig. 151
															SWI
		vi													INC II
PPR	OVAL	5: U													ING H
		fo	for all sizes. Complies with Federal Specification A-A-1192A (Type 10), and												
		Μ	Manufacturers' Standardization Society ANSI/SP-69 and SP-58 (Type 10). Specify pipe size and figure number. MATERIAL: Low carbon steel									Fig	5. 151	PRE-GA	
RDE	ERING:	s Sp										Fig	g. 151F	PRE-GAI	
											Max. Rec.				WITH FI
		Rod		_	Adj.				_		Load		Wt. Each		
	Size	Size		В		С		D		E	lbs.	kN	lbs.	kg	
2 <sup>1</sup> / <sub>2</sub>	(65)	<sup>1</sup> / <sub>2</sub>	2 <sup>3</sup> / <sub>4</sub>	(69.85)	1 <sup>1</sup> / <sub>4</sub>	(31.75)	3 <sup>11</sup> / <sub>16</sub>	(93.66)	5 <sup>1</sup> / <sub>8</sub>	(130.18)	600	(2.67)	.33	(.15)	
3	(80)	<sup>1</sup> / <sub>2</sub>	3 <sup>1</sup> / <sub>8</sub>	(79.38)	1 <sup>1</sup> / <sub>8</sub>	(28.58)	4	(101.60)	5 <sup>7</sup> / <sub>8</sub>	(149.23)	600	(2.67)	.35	(.16)	
3 <sup>1</sup> / <sub>2</sub>	(90)	<sup>1</sup> / <sub>2</sub>	3 <sup>5</sup> /8	(92.08)	1 <sup>1</sup> / <sub>2</sub>	(38.10)	4 <sup>5</sup> / <sub>16</sub>	(109.54)	6 <sup>5</sup> / <sub>8</sub>	(168.28)	600	(2.67)	.37	(.17)	
4	(100)	<sup>5</sup> / <sub>8</sub>	3 <sup>7</sup> / <sub>8</sub>	(98.43)	1 <sup>1</sup> / <sub>4</sub>	(31.75)	4 <sup>15</sup> / <sub>16</sub>	(125.41)	7 <sup>1</sup> / <sub>8</sub>	(180.98)	1000	(4.45)	.48	(.22)	1
5	(125)	<sup>5</sup> /8	3 <sup>3</sup> / <sub>8</sub>	(85.73)	1 <sup>3</sup> /8	(34.93)	5 <sup>5</sup> /8	(142.88)	8 <sup>1</sup> / <sub>2</sub>	(215.90)	1000	(4.45)	.57	(.26)	
6	(150)	<sup>3</sup> / <sub>4</sub>	5 <sup>5</sup> / <sub>16</sub>	(134.94)	2	(50.80)	6 <sup>11</sup> / <sub>16</sub>	(169.86)	10 <sup>1</sup> / <sub>8</sub>	(257.18)	1250	(5.56)	1.06	(.48)	Ē
8	(200)	<sup>3</sup> / <sub>4</sub>	6 <sup>15</sup> / <sub>16</sub>	(176.21)	2 <sup>5</sup> / <sub>8</sub>	(66.68)	8 <sup>5</sup> / <sub>16</sub>	(211.14)	12 <sup>7</sup> / <sub>8</sub>	(327.03)	1250	(5.56)	1.32	(.60)	

**Note:** If ordering Fig. 151F felt lined hangers for pipe sizes of  $3^{1/2}$ " (90mm) or under, order the next largest size to allow for the thickness of the felt lining.

## & 151F VEL ANGER

VANIZED VANIZED





Unless otherwise specified, all dimensions on drawings and in charts are in inches and dimensions shown in parentheses are in millimeters.

## PHD Manufacturing, Inc.