uponor

Engineered Plastic (EP) Heating Manifold Single Section with Balancing Valve and Flow Meter

Submittal Information Revision A: Oct. 15, 2008

Project Information

Job Name:

Location:	Part No. Ordered:
Engineer:	Date Submitted:
Contractor:	Submitted By:
Manufacturer's Representative:	Approved By:

Technical Data

Manifold: Valve Insert, Handwheels: Metal Inserts: Axel: Spring: O-ring:	PA66-GF30 POM Brass C38500 Stainless Steel Stainless Steel EPDM
v Meter (A2670003) adds additio	Manifold Single Section with Balancing Valve and nal loops to an EP Heating Manifold assembly for
, 3	cooling systems. Use only propylene glycol in nifolds; never use ethylene glycol.

\checkmark	Description	Part Number	Height	Width	Weight
	EP Heating Manifold Single Section with Balancing Valve and Flow Meter	A2670003	7.5"	2.0"	0.36 lbs.
	EP Heating Manifold Flow Meter Valve Body, replacement part	A2670005			
	EP Heating Manifold Valve Replacement Tool	A2670007			
	EP Heating Manifold Replacement O-ring	A2670008			

Installation

Select the proper bracket spacing for the manifold and mount the bracket to the wall. Snap the manifold to the bracket. See the installation manual for complete instructions. **Note**: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.

Standards	
N/A	
Codes	
N/A	
Listings	
N/A	

Related Applications

Radiant Heating and Cooling Systems Snow and Ice Melting Systems Permafrost Protection Systems Turf Conditioning Systems

Contact Information

Uponor, Inc. 5925 148th Street West Apple Valley, MN 55124 USA Phone: (800) 321-4739 Fax: (952) 891-2008 www.uponor-usa.com Uponor Ltd. 2000 Argentia Road, Plaza 1, Suite 200 Mississauga, ON L5N 1W1 CANADA Phone: (888) 994-7726 Fax: (800) 638-9517 www.uponor.ca