

Hydrant Flow Test Report

Test Date 4/21/2017

Test Time 10:00am

Location

133 WEST UNION STREET
ASHLAND, MA

Tested by

KEVIN LAROSE
SPRINK DESIGN INC.

Notes

STATIC HYDRANT IS ACROSS THE STREET
SOUTHEAST FROM RESIDENCE. FLOW HYDRANT
IS NEAREST HYDRANT NORTHEAST.

Read Hydrant

76 psi **static pressure**
68 psi **residual pressure**
hydrant elevation

Flow Hydrant(s)

Outlet	Elev	Size	C	Pitot Pressure	Flow
#1				62.5	1325 gpm

Flow Graph



