



Certificate number: 2310830 (1)

Issued 19/12/2023

Expires 19/11/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Watts Industries UK.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Watts Industries UK
Colmworth Business Park
St Neots
PE19 8YX
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2310830

The following products belong to this certificate

PRODUCT DESCRIPTION Y333 range of Y-strainers with blue epoxy coated cast iron bodies and stainless-steel strainer. ATS3 – Without Production Surveillance.
MODEL(S) Ref 3260 Ref 3261 Ref 3262 Ref 3263 Ref 3264 Ref 3265 Ref 3266 Ref 3267 Ref 3268 Ref 3269
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature 100°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
MARKING Socla on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes