



MUUNTOTAULUKKO IMI STAD* → DANFOSS MSV-BD

		ESISÄÄTÖARVO																																			
STAD*	DN10		1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0				
MSV-BD	DN15LF		0.2			0.3	0.4	0.5	0.6	0.8	1.0	1.2	1.4	1.5	1.6	1.8	1.9	2.1	2.3	2.5	2.7	2.9	3.1	3.3	3.6	3.8	4.0	4.2	4.3		4.4	4.5	4.6				
STAD*	DN15	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0
MSV-BD	DN15	0.4	0.5	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.7	1.8	2.0	2.1	2.3	2.5	2.6	2.8	3.0	3.3	3.5	3.8	4.0	4.2	4.4	4.5	4.6	4.7	4.9	5.1	5.2	5.4	5.7
	DN15LF	0.5	0.7	0.8	0.9	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.9	2.0	2.2	2.4	2.6	2.7	2.9	3.1	3.2	3.4	3.7	3.9	4.2	4.5	4.8	5.1	5.3	5.4	5.6	5.9	6.1	6.3			
STAD*	DN20	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0
MSV-BD	DN20	0.7	0.8		0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.7	1.9	2.0	2.2	2.4	2.6	2.7	2.9	3.0	3.1	3.2	3.4	3.5	3.7	3.8	4.0	4.1	4.2	4.3	4.5	4.6	4.8	4.9	5.1		
STAD*	DN25	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0
MSV-BD	DN25	0.3	0.4	0.5	0.7	0.8	1.0	1.3	1.5	1.8	2.0	2.3	2.5	2.7	3.0	3.3	3.5	3.8	4.0	4.3	4.5	4.7	4.9	5.0	5.2	5.3	5.5	5.6	5.7	5.8	5.9	6.1	6.2				
STAD*	DN32	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0
MSV-BD	DN32	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.8	1.9	2.1	2.2	2.4	2.5	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4		3.5	3.6	3.7	3.8		3.9	4.0	4.1
STAD*	DN40	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0
MSV-BD	DN40	0.5	0.6	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.2	2.3	2.5	2.7	2.8	3.0	3.2	3.4	3.5	3.7	3.8	3.9	4.1	4.2	4.3	4.4	4.5	4.6	4.8	4.9	5.0
STAD*	DN50	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.1	3.2	3.3	3.4	3.5	3.6	3.7	3.8	3.9	4.0
MSV-BD	DN50	0.4	0.5	0.6	0.8	0.9	1.0	1.2	1.3	1.5	1.7	1.9	2.1	2.4	2.6	2.9	3.2	3.4	3.6	3.8	4.0	4.2	4.4	4.6	4.8	4.9	5.1	5.2	5.3	5.5	5.6	5.7	5.9	6.0	6.2	6.4	

ARVOT PERUSTUVAT VALMISTAJIEN TEKNISIIN ESITTEISIIN (2024)