

(h) Any waters or wastes having a pH in excess of 9.5.

(i) Materials which exert or cause:

- (1) Unusual concentrations of inert suspended solids (such as, but not limited to, Fullers earth, lime slurries, and lime residues) or of dissolved solids (such as, but not limited to, sodium chloride or sodium sulfate).
- (2) Excessive discoloration (such as, but not limited to, dye wastes and vegetable tanning solutions).
- (3) Unusual BOD, chemical oxygen demand, or chlorine requirements in such quantities as to constitute a significant load on the sewage treatment works.
- (4) Unusual volume of flow or concentration of wastes constituting "slugs" as defined herein.

(j) Waters or wastes containing substances which are not amenable to treatment or reduction by the sewage treatment processes employed or are amenable to treatment only to such degree that the sewage treatment plant effluent cannot meet the requirements of other agencies having jurisdiction over discharge to the receiving waters.

(k) Any waters or wastes having (1) a 5-day BOD greater than 300 parts per million by weight, or (2) containing more than 350 parts per million by weight of suspended solids, or (3) having an average daily flow greater than 2 percent of the average sewage flow of the City, shall be subject to the review of the Maintenance Supervisor. Where necessary in the opinion of the Maintenance Supervisor, the owner shall provide, at his expense, such preliminary treatment as may be necessary to (1) reduce the biochemical oxygen demand to 300 parts per million by weight, or (2) reduce the suspended solids to 350 parts per million by weight or (3) control the quantities and rates of discharge of such waters or wastes. Plans, specifications, and any other pertinent information relating to proposed preliminary treatment facilities shall be submitted for the approval of the Maintenance Supervisor and no construction of such facilities shall be commenced until said approvals are obtained in writing.

Sec. 5. If any waters or wastes are discharged, or are proposed to be discharged to the public sewers, which waters contain the substances or possess the characteristics enumerated in Section 4 of this Article, and which in the judgement of the Maintenance Supervisor, may have a deleterious effect upon the sewage works, processes, equipment, or receiving waters, or which otherwise create a hazard to life to constitute a public nuisance, the Maintenance Supervisor may:

- (a) Reject the wastes,
- (b) Require pretreatment to an acceptable condition for discharge to the public sewers,
- (c) Require control over the quantities and rates of discharge, and/or
- (d) Require payment to cover the added cost of handling and treating the wastes not covered by existing taxes or sewer charges under the provisions of Section 10 of the Article.

If the Maintenance Supervisor permits the pretreatment or equalization of waste flows, the design and installation of the plants and equipment shall be subject to the review and approval of the Maintenance Supervisor, and subject to the requirements of all applicable codes, ordinances and laws.

Sec. 6. Grease, oil, and sand interceptors shall be provided when, in the opinion of the Maintenance Supervisor, they are necessary for the proper handling of liquid wastes containing grease in excessive amounts, or any flammable wastes, sand, or other harmful ingredients; except that such interceptors shall not be required for private living quarters or dwelling units. All interceptors shall be of a type and capacity approved by the Maintenance Supervisor and shall be located as to be readily and easily accessible for cleaning and inspection.

Sec. 7. Where preliminary treatment or flow-equalizing facilities are provided for any waters or wastes, they shall be maintained continuously in satisfactory and effective operation by the owner at his expense.

Sec. 8. When required by the Maintenance Supervisor, the owner of any property serviced by a building sewer carrying industrial wastes shall install a suitable control manhole together with such necessary meters and other appurtenances in the building sewer to facilitate observation, sampling, and measurement of the wastes. Such

manhole, when required, shall be accessibly and safely located, and shall be constructed in accordance with plans approved by the Maintenance Supervisor. The manhole shall be installed by the owner at his expense and shall be maintained by him so as to be safe and accessible at all times.

Sec. 9. All measurements, tests, and analyses of the characteristics of waters and wastes to which reference is made in this ordinance shall be determined in accordance with the latest edition of "Standard Methods for the Examination of Water and Wastewater", published by the American Public Health Association, and shall be determined at the control manhole provided, or upon suitable samples taken at said control manhole. In the event that no special manhole has been required, the control manhole shall be considered to be the nearest downstream manhole in the public sewer to the point at which the building sewer is connected. Sampling shall be carried out by customarily accepted methods to reflect the effect of constituents upon the sewage works and to determine the existence of hazards to life, limb, and property. (The particular analyses involved will determine whether a twenty-four (24) hours composite of all outfalls of a premise is appropriate or whether a grab sample or samples should be taken. Normally, but not always, BOD and suspended solids analyses are obtained from 24-hour composites of all outfalls whereas pH's are determined from periodic grab samples.)

Sec. 10. No statement contained in this article shall be construed as preventing any special agreement or arrangement between the City and any industrial concern whereby an industrial waste of unusual strength or character may be accepted by the City for treatment, subject to payment therefore, by the industrial concern.

ARTICLE VI

Sec. 1. No unauthorized person shall maliciously, willfully, or negligently break, damage, destroy, uncover, deface, or tamper with any structure, appurtenance, or equipment which is part of the sewage works. Any person violating this provision shall be subject to immediate warrant under charge of disorderly conduct.

ARTICLE VII

Sec. 1. The Maintenance Supervisor and other duly authorized employees of the City bearing proper credentials and identification shall be permitted to enter all properties for the purpose of inspection, observation, measurement, sampling, and testing in accordance with the provisions of this ordinance. The Maintenance Supervisor or his representatives shall have no authority to inquire into any processes including metallurgical, chemical, oil, refining, ceramic, paper, or other industries beyond that point having a direct bearing on the kind and source of discharge to the sewers or waterways or facilities for waste treatment.

Sec. 2. While performing the necessary work on private properties referred to in Article VII, Section 1 above, the Maintenance Supervisor or duly authorized employees of the City shall observe all safety rules applicable to the premises established by the company and the company shall be held harmless for injury or death to the City employees and the City shall indemnify the company against loss or damage to its property by City employees and against liability claims and demands for personal injury or property damage asserted against the company and growing out of the gauging and sampling operation, except as such may be caused by negligence or failure of the company to maintain safe conditions as required in Article V, Section 8.

Sec. 3. The Maintenance Supervisor and other duly authorized employees of the City bearing proper credentials and identification shall be permitted to enter all private properties through which the City holds a duly negotiated easement for the purposes of, but not limited to, inspection, observation, measurement, sampling, repair, and maintenance of any portion of the sewage works lying within said easement. All entry and subsequent work, if any, on said easement, shall be done in full accordance with the terms of the duly negotiated easement pertaining to the private property involved.

ARTICLE VIII

Sec. 1. Any person found to be violating any provision of this ordinance except Article VI shall be served by the City with written notice stating the nature of the violation and providing a reasonable time limit for the satisfactory correction thereof. The offender shall, within the period of time stated in such notice, permanently cease all violations.