











Building Energy Performance		Scotland
Energy Performance Certificate	Calculated asset rating using Lifespan SBEM v4.1.c [SBEM]	Building type Storage or Distribution
	Current rating	
	Excellent	
		Carbon Neutral
		A (0 to 15)
		B (16 to 30)
		C (31 to 45)
		D (46 to 60)
	E (61 to 80)	
	F (81 to 100)	
	G (100+)	
Very Poor		
Carbon Dioxide Emissions		
The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year		75
Approximate current energy use per m ² of floor area:		278 kWh/m²
Main heating fuel: Natural Gas		Building Services: Heating with Nat. Vent.
Renewable energy source: None		Electricity: Grid supplied
Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.		
Benchmarks		
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		26  B
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		69  E+
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance		
<p>1. Consider replacing T8 lamps with retrofit T5 conversion kit.</p> <p>2. Some windows have high U-values - consider installing secondary glazing.</p> <p>3. Some glazing is poorly insulated. Replace/improve glazing and/or frames.</p>		

Address: Unit 3, Block 10, Burns Way, Clydebank Business Park , Clydebank, G81 254
Conditioned area (m²):
Name of protocol organisation: Royal Institution of Chartered Surveyors, [RICS850263]
Date of issue of certificate: 30 Nov 2011 (Valid for a period not exceeding 10 years)
 This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.
NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE