











Building Energy Performance		Scotland						
Energy Performance Certificate	Calculated asset rating using iSBEM v3.2.b [SBEM]	Building type Warehouse and storage						
	Current rating							
	Excellent							
		Carbon Neutral						
		A (0 to 15)						
		B (16 to 30)						
		C (31 to 45)						
		D (46 to 60)						
	E (61 to 80)							
	F (81 to 100)							
	G (100+)							
Very Poor								
Carbon Dioxide Emissions								
The number refers to the calculated carbon dioxide emissions in terms of kg per m ² of floor area per year		68						
Approximate current energy use per m ² of floor area:		263 kWh/m²						
Main heating fuel: Natural Gas		Building Services: Heating with Nat. Vent.						
Renewable energy source:		Electricity: Grid supplied						
Carbon Dioxide is a greenhouse gas which contributes to climate change. Less Carbon Dioxide emissions from buildings helps the environment.								
Benchmarks								
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		21  B+						
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		62  E+						
Recommendations for the cost-effective improvement (lower cost measures) of the energy performance								
<table border="0" style="width: 100%;"> <tr> <td style="width: 50%;">1. Consider replacing T8 lamps with retrofit T5 conversion kit.</td> <td style="width: 50%;">4. Consider installing building mounted wind turbine(s).</td> </tr> <tr> <td>2. Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.</td> <td>5. Consider installing solar water heating.</td> </tr> <tr> <td>3. Some windows have high U-values - consider installing secondary glazing.</td> <td>6. Some glazing is poorly insulated. Replace/improve glazing and/or frames.</td> </tr> </table>			1. Consider replacing T8 lamps with retrofit T5 conversion kit.	4. Consider installing building mounted wind turbine(s).	2. Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	5. Consider installing solar water heating.	3. Some windows have high U-values - consider installing secondary glazing.	6. Some glazing is poorly insulated. Replace/improve glazing and/or frames.
1. Consider replacing T8 lamps with retrofit T5 conversion kit.	4. Consider installing building mounted wind turbine(s).							
2. Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	5. Consider installing solar water heating.							
3. Some windows have high U-values - consider installing secondary glazing.	6. Some glazing is poorly insulated. Replace/improve glazing and/or frames.							

Address: Units 16, 17 and 18 Belleknowes Industrial Estate, Fife, INVERKEITHING
Conditioned area (m²): 1661
Name of protocol organisation: BRE Global, [123456]
Date of issue of certificate: 29 Jan 2009 (Valid for a period not exceeding 10 years)
 This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.
NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE