

UL Type Examination Certificate

Certificate
UL TEC-05632

Issue date
2026-05-25

The UL Type Examination
Certification Scheme is ISO/IEC
17065 accredited by
International Accreditation
Service (IAS)
[IAS Accreditation \(PCA-164\)](#)

This is to acknowledge that

Meamar Gulf Industrial Co.

Istanbul Street, Meshal Industrial Area, 14327
Riyadh, Kingdom of Saudi Arabia (KSA)

has had

Empty Enclosure, floor mounted Extendable type

EX Series, floor mounted extendable type

evaluated and meets the requirements of the standard

IEC 62208:2023

Test Report No. 4792235298.1.1 issued on 2026-05-20

Certification Manager
Thomas Wilson

**UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark,
Tel. +45 44 85 65 65, www.ul.com**

This is to certify that the sample(s) of the Product described herein has been investigated and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL Solutions did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL Solutions has not established Follow-Up Service or other surveillance of the product. The Applicant/ Manufacturer are solely and fully responsible for any declaration of ongoing conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL Solutions' prior written approval.

UL TYPE EXAMINATION CERTIFICATE

TECHNICAL DETAILS

Manufacturing site/location Meamar Gulf Industrial Co.
Istanbul Street, Meshal Industrial Area, 14327
Riyadh, Kingdom of Saudi Arabia (KSA)

Trademark 

Ratings IP rating: IP55
Mechanical impact: IK10
Ambient Temperature: 50°C,
Refer Type Examination summary for other details
(4792235298.1.1-S)

Additional Information Product Sample Description:
Empty enclosure for low-voltage switchgear and controlgear
assemblies, floor mounted, extendable type metallic enclosure