



INSTALLATION, OPERATION & MAINTENANCE INSTRUCTIONS

1455 Kleppe Lane ♦ Sparks, NV 89431-6467 ♦ (775) 359-4712 ♦ Fax (775) 359-7424
E-mail: haws@hawsco.com ♦ website: www.hawsco.com

No. 0002077791 (24)

Model 6518.2FR

NOTE TO INSTALLER: Please leave this information with the Maintenance Department.

LIMITED WARRANTY

HAWS warrants that all of its products are guaranteed against defective material or poor workmanship for a period of **one year from the date of shipment**. The foregoing notwithstanding, *HAWS* warrants certain specific products or components thereof for an adjusted period. A list of these excepted products and components and a description of their respective warranty terms may be found here: www.hawsco.com/warranty. *HAWS'* liability under this warranty shall be discharged by furnishing without charge F.O.B. *HAWS* factory any goods, or part thereof, which shall appear to the Company upon inspection to be of defective material or not of first-class workmanship, provided that a claim is made in writing to Company within a reasonable period after receipt of the product. Where claims for defects are made, the defective part or parts shall be delivered to the Company, prepaid, for inspection. *HAWS* shall not be liable for the cost of repairs, alterations or replacements, or the labor required to implement them, or for any expense connected therewith made by the owner or owner's agents, except upon written authority from *HAWS*. *HAWS* shall not be liable for any damages caused by defective materials or poor workmanship, except for replacements, as provided above. Buyer agrees that *HAWS* has made no other warranties either express or implied in addition to those above stated, except that of title with respect to any of the products or equipment sold hereunder and that *HAWS* shall not be liable for general, special, incidental, or consequential damages claimed to arise under the contract of sale.

Equipment manufactured by *HAWS* is warranted to function if installation and maintenance instructions provided are adhered to. The units also must be used for the purpose for which they were intended. Any *HAWS* emergency equipment is intended to supplement first-aid treatment. Due to widely varying conditions, *HAWS* cannot guarantee that the use of this emergency equipment will prevent serious injury or the aggravation of existing or prior injuries.

EXCEPT AS EXPRESSLY STATED HEREIN, HAWS HEREBY DISCLAIMS ALL WARRANTIES, WHETHER EXPRESS OR IMPLIED, ARISING BY LAW OR OTHERWISE, INCLUDING WITHOUT LIMITATION, ANY IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. THIS WARRANTY MAY NOT BE MODIFIED OR EXTENDED WITHOUT THE WRITTEN CONSENT OF HAWS. REMEDIES AND REPLACEMENTS STATED HEREIN ARE EXCLUSIVE. IN NO EVENT SHALL HAWS BE LIABLE FOR ANY SPECIAL, PUNITIVE, CONSEQUENTIAL OR INCIDENTAL DAMAGES TO ANY PERSON INCLUDING BUT NOT LIMITED TO DAMAGES FOR LOSS OF USE OR PROFITS, SUBSTITUTE PRODUCTS OR COSTS, PROPERTY DAMAGE, OR OTHER MONETARY LOSS.

SHOULD YOU EXPERIENCE DIFFICULTY WITH THE INSTALLATION OF THIS MODEL PLEASE CALL:

TECHNICAL SUPPORT: 1-800-766-5612
FOR CUSTOMER SERVICE: 1-888-640-4297

RECOMMENDED TOOLS: Pipe joint sealant, screwdriver, level, 5/64" hex key wrench, 12" adjustable wrench, 10" pipe wrench, 5/16", 3/4", 9/16", 1/2" and 7/16" open end wrenches.

LOCATION OF UNIT: The Model 6518.2FR is suitable for all season outdoor use where temperatures may drop well below freezing. This model is used with HAWS outdoor drinking fountains and jug fillers. When installing this unit, local state or federal codes should be adhered to.

SUPPLY LINE: The minimum recommended line size is 1/2" IPS with 30-90 psi (2-6 ATM) flowing pressure. Where sediment or mineral content in water is a problem, an inlet filter is recommended.

PLUMBING CONNECTIONS: Inlet valve is 1/2" IPS male, which must be buried below the frost line. Waste outlet is female 1-1/4" outside diameter tailpiece.

INSTALLATION PROCEDURE

GENERAL NOTES:

1. For all plastic push-in type fitting connections, only connect NSF-61 copper or plastic tubing. Stainless steel or glass tubing is not recommended. The following assembly instructions must be followed to ensure a watertight connection:
 - a. Cut tubing square and clean.
 - b. Mark from end of tube the length of insertion (See table below).
 - c. Push tube into the fitting until it bottoms out.
 - d. To remove, depress collet and pull tubing out.

Tube Sizes	O.D. Tolerance	Insertion Depth
1/4"	±.005"	11/16"
3/8"	±.005"	3/4"
1/2"	±.005"	7/8"

Refer to installation drawing for details. Use pipe joint sealant on all water connections.

STEP 1: Trench for water supply and waste drain lines. The hole should be deep enough to accommodate the PVC casing and a minimum of 10 cubic feet of porous fill (gravel). Additional porous fill and drainpipe may be required due to local ground conditions. Provide a shut-off valve for maintenance. Install the 1/2" supply line and 1-1/4" sanitary drain, (see Installation Drawing sheet 2 of 3), excavation detailed drawing. Cut the PVC pipe to fit desired bury depth, but no less than 40" long.

STEP 2: Attach the supply hose assembly to the inlet elbow below the frost line (see Installation Drawing sheet 3 of 3). Lower the PVC pipe into place. Then with PVC primer and glue attach the "Y" fitting to the pipe. Pull the supply assembly up through the casing using the attached metal rod. Flush the line before attaching the valve.

INSTALLATION PROCEDURE

- STEP 3:** Attach the valve assembly to the hose assembly outside of the casing. **Pressure test for leaks:** Using the metal rod as a handle, lower the complete valve assembly into casing. Make sure that the supply hose coils into the bottom of the casing without any kinks. Keep the hose coiled underneath the valve (see Installation Drawing sheet 1 of 3). Cap the casing and back-fill the trench. Keep the valve casing vertical at all times.
- STEP 4:** Locate the fountain anchor bolts in the proper position. Care must be taken to insure clearance within the pedestal for the valve casing branch arm waste drain line. Pour concrete into forms and finish. Let concrete set for at least 24 hours.
- STEP 5:** Place the fountain onto the mounting pad and secure in place. Pull the valve assembly out of the valve casing. Feed the supply tubing from the fountain down into the valve casing branch arm. Reach into the top of the casing and pull the tubing out. Tubing should now run from pedestal operator down through valve casing arm, then up valve casing to ground level. Measure and cut the tubing to length, allowing enough tubing, to reach the bottom of valve casing. Connect tubing from fountain to the push-in type fitting outlet of the valve. Connect the waste line to the fountain.
- STEP 6:** Feed the two 5/32" O.D. tubing from the valve up to the fountain through the valve casing branch arm. Connect the tubing with label to the push button. Secure with the compression nut (hand tight only). Leave the end of the attached breather tube open to the air.
- STEP 7:** Turn on the supply line shutoff valve. Test the 6518.2FR valve using the fountain push button. Check for leaks. Refer to trouble shooting section for any malfunction.
- STEP 8:** Lower the complete valve assembly back into the casing as in Step 3. Test the flow once again and make sure that the line water between valve and fountain drains back to porous fill. Make sure the tubing has no low spots, which might collect water causing ice plugs in freezing weather.
- STEP 9:** When the fountain operates satisfactorily, install the access plates. Place a piece of insulation foam (provided) inside the casing as shown on installation drawing. To complete installation, cap valve casing and replace valve box cover.


TROUBLESHOOTING

PROBLEM	REPAIR CHECKLIST
1. Bubbler Flow Control.	1. Adjust pressure regulator: <ol style="list-style-type: none"> a. Pull knob out. b. Rotate the knob clockwise to increase flow or counterclockwise to reduce flow. c. Push knob in to lock adjustment. d. Lower the valve assembly back into the casing. e. Repeat the above steps until the bubbler flow is correct. f. Replace pressure regulator if necessary.
2. Insufficient bubbler flow.	2. <ol style="list-style-type: none"> a. Check that the main shut-off valve is wide open. b. Verify minimum 30 psi supply pressure. c. Clean inlet strainer screen located in the valve body. d. Adjust Pressure Regulator (Refer to Step 1).
3. No flow.	3. <ol style="list-style-type: none"> a. Check for leaks in the air tubing going from the push button to the valve. b. Make sure the air tubing compression nuts are hand tight. c. Disconnect air tube from push button assembly. Blow into tube to verify valve function. Replace valve if necessary. d. Disconnect air tube from push button. Place finger over air outlet. Push button to test diaphragm. Tighten diaphragm cap screws. Replace diaphragm if necessary.
4. Continued insufficient or varied height of bubbler flow.	4. <ol style="list-style-type: none"> a. Check for kinks in the tubing. b. Adjust Pressure Regulator (Refer to Step 1).

TROUBLESHOOTING	
PROBLEM	REPAIR CHECKLIST
5. Continuous bubbler flow.	5. a. Ensure that push button is not obstructed and springs back to normal position. b. Remove four screws, which secure plastic diaphragm block to brass valve body. Pull plastic and rubber diaphragm assembly out of valve body. Locate tiny hole in rubber diaphragm just under lip of plastic part. Clean debris from this hole. Inspect valve seat for grooves. If seat is worn, replace with stainless steel seat (newer models) or replace valve (older models, integral brass seat). c. If valve seat was OK and diaphragm holes were free from debris, inspect rubber button located at center of floating steel disc in valve diaphragm block assembly. If button is worn, turn disc over or replace disc. d. If diaphragm and seats are in good condition, stretch spring slightly. Spring is located behind floating stainless-steel plate. e. Ensure that air bleed port on valve plastic block assembly is not plugged.



For more information about Haws products, see our website: www.hawesco.com

PARTS BREAKDOWN




NOTES:

- 1 THIS BLACK COVER IS NOT INTERCHANGEABLE WITH GRAY COVERS USED ON OLDER 5881 VALVES. (SCREWS & WASHERS NOT SUPPLIED WITH COVERS).
- 2 0006040013 TUBING (NOT SUPPLIED IN ANY VALVE REPAIR KITS OR REPLACEMENTS; MUST BE ORDERED SEPARATELY).



WHEN ORDERING PARTS PLEASE SPECIFY MODEL NUMBER.

		Haws Since 1906		1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM	
				ECN NO. 6011 REVISOR FV DATE 08/26/04 CHKD JC	MODEL(S) 6518.2FR
APPROVED FV DATE 07/30/24	SCALE: 1:1	DRAWING TYPE: PARTS BREAKDOWN	SIZE: A	SHEET 1 OF 1	






Haws
Since 1906

1455 KLEPPE LANE
SPARKS, NEVADA 89431
(775) 359-4712 FAX (775) 359-7424
E-MAIL: HAWS@HAWS.CO.COM
WEBSITE: WWW.HAWS.CO.COM

ECN NO.	REVISED PER	BY:	MODEL(S)	PART NUMBER
	ECN: 6011	FV		0002077791.D
DRAWN:	DATE:	CHKD.:	6518.2FR	REVISION
CJL	09/22/92	JC		24
APPROVED:	DATE:	SCALE:	DRAWING TYPE:	SHEET 1 OF 3
FV	07/30/24	1:13	INSTALLATION	






Haws
Since 1906

1455 KLEPPE LANE
SPARKS, NEVADA 89431
(775) 359-4712 FAX (775) 359-7424
E-MAIL: HAWS@HAWS.CO.COM
WEBSITE: WWW.HAWS.CO.COM

ECN NO.	REVISOR	BY:	MODEL(S)	PART NUMBER
6011	FV	FV	6518.2FR	000207791.D
DRAWN:	DATE:	CHKD.:		REVISION
CJL	09/22/92	JC		24
APPROVED:	DATE:	SCALE:	DRAWING TYPE:	SHEET
FV	07/30/24	1:24	INSTALLATION	2 OF 3





Haws
Since 1906

1455 KLEPPE LANE
SPARKS, NEVADA 89431
(775) 359-4712 FAX (775) 359-7424
E-MAIL: HAWS@HAWS.CO.COM
WEBSITE: WWW.HAWS.CO.COM

ECN NO.	REVISER	BY:	MODEL(S)	PART NUMBER
ECN: 6011	FV	FV	6518.2FR	0002077791.D
DRAWN:	DATE:	CHKD.:		REVISION
CJL	09/22/92	JC		24
APPROVED:	DATE:	SCALE:	DRAWING TYPE:	INSTALLATION
FV	07/30/24	1:24	INSTALLATION	SIZE: A SHEET 3 OF 3