

### **SUBMITTAL SHEET**

JOB NAME		ITEM TAG	
JOB LOCATION		PART NUMBER	
CONTRACTOR	DATE		
ENGINEER APPROVAL	DATE		

## NO LEAD QUARTER-TURN ANTI-SIPHON FREEZE-RESISTANT SILLCOCK

# TM-550NL, TM-550PNL, TMP-550NL and TM-550NLP1960

Easy to grip Softouch™ TPR coated metal handle.

Oversized, 5° angled mounting flange for ease of installation. Includes EPDM rubber gasket.

Integrated anti-siphon vacuum breaker with chrome-plated brass cap.

ASSE 1019-Type A Device.1

	PART	MATERIAL	SPECIFICATION
1	Exterior body	Lead-free brass, chrome plated	UNS Alloy C6802
2	Outer Tube	Lead-free brass, chrome plated	UNS Alloy C27000
3	End Adapter	Lead-free forged brass, chrome plated	UNS Alloy C46400
4	Bonnet nut assembly	Forged brass, chrome plated	UNS Alloy C36000 / Othe
5	Handwheel	Aluminum & TPR rubber	
6	Vacuum breaker assembly	Forged brass / POM	
7	Stem assembly	Lead-free brass / Other	UNS Alloy C27000 / Othe
	<u> </u>		

DIMENSIONS - Inch					
Size	Α	В			
4"	4	3.4			
6"	6	3.4			
8"	8	3.4			
10"	10	3.4			
12"	12	3.4			
14"	14	3.4			

<b>C</b>
1.00
1.06
1.12
1.25
1.81
1.12









LegendPress®

MNPT/FNPT

MNPT/Sweat

TM-550NL


Cut-away





PEX (F1807)

PEX (F1960)



#### **Certifications/Listings:**

Third-party certified

NSF/ANSI 61: Drinking water system components - Health effects.

ASSE 1019-A: Performance requirements for wall hydrant with backflow protection and freeze resistance

#### Standards:

ANSI/ASME B1.20.1: Pipe threads, general purpose, Inch

ANSI/ASME B16.18: Cast pressure alloy solder-joint pressure fitting

ASTM F1807: Metal insert fittings utilizing a copper crimp ring or stainless steel clamps.

ASTM F1960: Cold expansion fittings with PEX reinforcing rings.

ANSI/ASME B16.51: Copper and copper alloy press-connect pressure fittings

<sup>1</sup>This device must not be subjected to more than 12 hours of continuous water pressure. The hose must be removed in order to prevent damage from freezing.