F-2974M26 14"-24"

Iron Check Valve 100 SWP - 150 WOG † Horizontal Swing • Flanged Ends Bolted Cover Conforms to: MSS SP-71

SPECIFICATION

ASTM A126, Class B

ASTM A536

ASTM A126, Class B

ASTM A126, Class B

ASTM A307

ASTM A126, Class B

MATERIAL LIST

Steel

Aluminum

Cast Iron

Graphite

Steel

Steel

Graphite

SS 304

Ductile Iron

Cast Iron

Steel

Zinc Plated Steel

Cast Iron

Steel

Cast Iron

Steel

No.

1 Bolt

2

3

4

5 Nut

6

7

8

9

10 Disc

11

12

13

14

15

16

PART

Name Plate

Cover Gasket

Side Plug

Hanger Pin

Gasket

Hanger

Washer

Cotter Pin

Seat Ring

Disc Nut

Stud Bolt

Body

Cover

Flange shape and drilling to specification ASME B 16.1 (125 lb).



Note 1: On pump discharge, the preferred check va is either an in-line spring loaded valve or a swing design with lever and weight. Install t valves as far as possible from the pump an elbows with a minimum distance of 5 times pipe diameter.	hese d

- Note 2: These iron body check valves may be installed in horizontal and vertical lines with upward flow or in intermediate position.
- Note 3: The wetted surface of this product contacted by consumable water contains less than one quarter of one percent (.25%) of lead by weight. Meets the requirements of Senate law S.3874.

DIMENSIONS - INCHES/MILLIMETERS						
Units	Size	Α	В	С	D	Cv
Inches mm	14	31.00 787	15.75 400	21.00 533	1.38 35	7006
Inches mm	16	36.00 914	17.25 438	23.50 597	1.44 37	9151
Inches mm	18	36.00 914	19.00 483	25.00 635	1.56 40	11581
Inches mm	20	40.00 1016	21.88 556	27.50 699	1.69 43	14298
Inches mm	24	48.00 1219	24.44 621	32.00 813	1.88 48	20588

Suffix M – Signifies "MILVACO" Series International Valves. † Non-Shock





The information presented on this sheet is correct at time of publication. Milwaukee Valve reserves the right to change design and/or materials without notice. For our Installation, Operation and Maintenance Manual and the most current product information go to www.milwaukeevalve.com. A State of California Prop 65 **WARNING:** Cancer and Reproductive Harm. For more information visit www.p65warnings.ca.gov.

BI-79