


Job Record

Zone Valve Control 306V



Zoning

306V_J

10/16

Replaces: New

Job site Location _____

Control Location _____

Thermostat Locations

Thermostat	Location
1	
2	
3	
4	
5	
6	

DIP Switch Settings

Switch	Circle Setting Position	
MASTER / MEMBER	MASTER	MEMBER
T-STAT 1 PRIORITY	ON	OFF
EXERCISING	ON	OFF
POST PURGE	ON	OFF
MOD BOILER	0-10 V	4-20 mA
SYSTEM PUMP DURING PRIORITY	ON	OFF
SYSTEM PUMP WITH MEMBER CALL	ON	OFF
ZONE VALVE END SWITCHES	ON	OFF

Mod Max % Dial

Dial Position

--

tekmar[®]

A **WATTS** Brand

All specifications are subject to change without notice.

Tel: (250) 545-7749 • Fax: (250) 984-0815
tekmarControls.com