



Medical and Lavatory Faucets

B-2866-05FC-CR

EasyInstall


Concealed Widespread Lavatory Faucet

TAG:

Architect/Engineering Specifications:

8" deck mount lavatory mixing faucet with forged brass body, 5 11/16" swivel/rigid gooseneck with plain end outlet, 1.5 GPM flow control device, ceramic cartridges with check valves, 4" wrist action handles, chrome plated escutcheons and 1/2" NPT male inlets with coupling nuts. Certified to ASME A112.18.1/CSA B125.1, NSF 61-Section 9 and NSF 372. Meets ADA ANSI/ICC A117.1 requirements.

Job Name _____
 Model Specified _____ Quantity _____
 Variations Specified _____
 Date _____



Features & Benefits:

- 8" EasyInstall concealed deck mount faucet w/ forged brass body
- 5 11/16" swivel/rigid gooseneck
- Lock washer provided for rigid application
- 1.5 GPM flow control device (pre-installed in gooseneck swivel)
- Quarter-Turn Cerama cartridges w/ check valves to prevent cross flow of water
- 4" wrist action handles w/ color coded indexes
- 1/2" NPT male inlets w/ coupling nuts
- Material: Forged brass body, chrome plated metal handles & escutcheons and polished chrome plated brass tubular spout

Product Compliance:

- ASME A112.18.1 / CSA B125.1
- NSF 61 - Section 9
- NSF 372 (Low Lead Content)
- ANSI A117.1 (ADA)

Warranty: One Year (Limited)

- Cerama Cartridge: Lifetime (Limited)

Performance Data:

- Pressure: 20 - 125 psi [1.38 - 8.62 bar]
- Temperature: 40 °F - 140 °F [4.44 °C - 60 °C]
- Flow Rate: 1.5 GPM [5.68 L/min] @ 60 psi [4.14 bar]



ADA Compliant

Optional Flow Disc

GPM	Model No	Optional Cartridges	Optional Handles
0.5	☐ FD05	☐ Quarter-Turn Cerama w/ Check Valve (Standard)	☐ 4" Wrist Action (Standard)
1.0	☐ FD10	☐ Quarter-Turn Eterna w/ Spring Check	☐ Lever
1.2	☐ FD12	☐ Push Button Metering	☐ 4-Arm
1.5	Standard	☐ Pivot Action Metering	
2.2	☐ FD22	☐ Wrist Action Metering	



T&S BRASS AND BRONZE WORKS, INC.



• 2 Saddleback Cove • Travelers Rest, SC 29690
 Ph 800-476-4103 • Fax 864-834-3518
 • Simi Valley, CA • Ph 800-423-0150 • www.tsbrass.com

Date: 09/27/22