

AIR CONDITIONER

Wall mounted type

DESIGN & TECHNICAL MANUAL

For Extra Cold Climate Area

INDOOR



ASUG09LZAS
ASUG12LZAS
ASUG15LZAS

OUTDOOR



AOUG09LZAH1
AOUG12LZAH1
AOUG15LZAH1

FUJITSU GENERAL LIMITED

DR_AS117EF_03
2022.10.12

Notices:

- Product specifications and design are subject to change without notice for future improvement.
- For further details, please check with our authorized dealer.

Trademarks

FGLair™ is trademark of Fujitsu General Limited in the United States, other countries or both.

Google Play™ is trademark of Google LLC.

App Store® is a service mark of Apple Inc., registered in the U.S. and other countries.

CONTENTS

Part 1. INDOOR UNIT	1
1. Specifications	2
2. Wireless LAN control	4
2-1. System requirement	4
2-2. Wireless LAN function list	5
3. Dimensions	6
3-1. Models: ASUG09LZAS, ASUG12LZAS, and ASUG15LZAS	6
4. Wiring diagrams	8
4-1. Models: ASUG09LZAS, ASUG12LZAS, and ASUG15LZAS	8
5. Capacity table	9
5-1. Cooling capacity	9
5-2. Heating capacity	11
6. Fan performance	13
6-1. Air velocity distributions	13
6-2. Airflow	15
7. Operation noise (sound pressure)	18
7-1. Noise level curve	18
7-2. Sound level check point	19
8. Safety devices	20
9. External input and output	21
9-1. External input	22
9-2. External output	23
9-3. Combination of external input and output	24
9-4. Details of function	25
10. Remote controller	38
10-1. Wireless remote controller	38
11. Function settings	40
11-1. Function settings by using remote controller	40
11-2. Custom code setting for wireless remote controller	48
11-3. Switching the temperature unit of remote controller	49
12. Accessories	50
13. Optional parts	51
13-1. Controllers	51
13-2. Others	52

CONTENTS (continued)

Part 2. OUTDOOR UNIT.....	53
1. Specifications.....	54
2. Dimensions.....	55
2-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1	55
3. Installation space	56
3-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1	56
4. Refrigerant circuit	59
4-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1	59
5. Wiring diagrams	60
5-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1	60
6. Capacity compensation rate for pipe length and height difference.....	61
6-1. Models: AOUG09LZAH1 and AOUG12LZAH1	61
6-2. Model: AOUG15LZAH1	62
7. Additional charge calculation	63
7-1. Models: AOUG09LZAH1 and AOUG12LZAH1	63
7-2. Model: AOUG15LZAH1	63
8. Airflow	64
8-1. Model: AOUG09LZAH1	64
8-2. Model: AOUG12LZAH1	64
8-3. Model: AOUG15LZAH1	65
9. Operation noise (sound pressure).....	66
9-1. Noise level curve.....	66
9-2. Sound level check point	67
10. Electrical characteristics	68
11. Safety devices	69
12. Accessories	70

Part 1. INDOOR UNIT

WALL MOUNTED TYPE:

ASUG09LZAS

ASUG12LZAS

ASUG15LZAS

1. Specifications

Type	Wall mounted					
Model name	Inverter heat pump					
Power supply		ASUG09LZAS	ASUG12LZAS	ASUG15LZAS		
Power supply intake		208/230 V ~60 Hz				
Available voltage range		Outdoor unit				
Capacity	Cooling	Rated	kW	2.64	3.52	4.25
			Btu/h	9,000	12,000	14,500
		Min.—Max.	kW	0.91—3.52	0.91—3.99	0.91—5.39
			Btu/h	3,100—12,000	3,100—13,600	3,100—18,400
	Heating	Rated	kW	3.52	4.69	5.28
			Btu/h	12,000	16,000	18,000
		Min.—Max.	kW	0.91—6.45	0.91—6.48	0.91—7.00
			Btu/h	3,100—22,000	3,100—22,100	3,100—23,900
	Heating (17°F)*1	Rated	kW	2.17	2.93	3.28
			Btu/h	7,400	10,000	11,200
		Max.	kW	4.69	5.13	6.30
			Btu/h	16,000	17,500	21,500
Input power	Heating (5°F)*2	Rated	kW	4.51	4.87	5.13
			Btu/h	15,400	16,600	17,500
		Max.	kW	4.51	4.87	6.15
			Btu/h	15,400	16,600	21,000
	Cooling	Rated	kW	0.50	0.79	1.04
		Min.—Max.		0.11—0.85	0.11—0.99	0.15—1.56
		Heating	Rated	0.66	1.01	1.15
		Min.—Max.		0.17—1.93	0.17—1.94	0.15—2.19
	Heating (17°F)*1	Rated		0.62	0.91	1.04
	Max.				2.21	2.74
	Heating (5°F)*2	Rated			2.25	2.19
	Max.				2.25	2.90
	Current	Cooling	A	2.5	3.8	4.8
		Heating		3.3	4.7	5.2
EER2	Cooling		kW/kW	5.28	4.46	4.09
			Btu/hW	18.0	15.2	13.9
COP2	Heating		kW/kW	5.34	4.64	4.60
			Btu/hW	18.2	15.8	15.7
SEER2	Cooling		Btu/hW	33.1	29.4	25.3
HSPF2	Heating		Btu/hW	13.3		12.7
Power factor	Cooling		%	87	90	94
	Heating			87	93	96
Moisture removal		pints/h (L/h)		2.5 (1.2)	2.7 (1.3)	4.0 (1.9)
Maximum operating current*3	Cooling		A		9.4	9.9
	Heating				11.9	14.4
Fan	Airflow rate	Cooling	HIGH		542 (920)	583 (990)
			MED		406 (690)	459 (780)
			LOW		312 (530)	312 (530)
			QUIET		206 (350)	241 (410)
		Heating	HIGH		542 (920)	600 (1,020)
			MED		406 (690)	459 (780)
			LOW		312 (530)	
			QUIET		206 (350)	241 (410)
	Type × Qty				Crossflow fan × 1	
	Motor output		W		59	
Sound pressure level*4	Sound pressure level*4	Cooling	HIGH		43	45
			MED		37	40
			LOW		31	32
			QUIET		23	26
		Heating	HIGH		43	45
			MED		36	39
			LOW		31	32
			QUIET		23	26
	Dimensions (H × W × D)		in (mm)		Main 1: 8-1/4 × 31-7/16 × 1-1/16 (210 × 798 × 26.6) Main 2: 5-5/16 × 31-7/16 × 13/16 (135 × 798 × 20.0) Sub 1: 3-5/16 × 31-7/16 × 1/2 (84 × 798 × 13.3) Sub 2: 3-5/16 × 31-7/16 × 1/2 (84 × 798 × 13.3)	
	Fin pitch		FPI		Man 1: 21 Main 2: 23 Sub 1: 18 Sub 2: 18	
	Rows × Stages				Main 1: 2 × 10 Main 2: 2 × 8 Sub 1: 1 × 4 Sub 2: 1 × 4	
	Pipe type				Copper	
	Fin type				Aluminum	
Enclosure	Material				Polystyrene	
	Color				White	
Dimensions (H × W × D)	Net				Approximate color of Munsell N 9.25/	
	Gross		in (mm)		Main 1: 38.9/16 × 9.7/16 (280 × 980 × 240) Main 2: 12-11/16 × 42-7/16 × 13-5/8 (322 × 1,078 × 346)	
Weight	Net		lb (kg)		29 (13)	
	Gross				37 (17)	
Connection pipe	Size	Liquid	in (mm)		Ø1/4 (Ø6.35)	
		Gas			Ø3/8 (Ø9.52)	Ø1/2 (Ø12.70)
	Method				Flare	
Drain hose	Material				PP+LLDPE	
	Tip diameter		in (mm)		Ø17/32 (Ø13.8) (I.D.), Ø5/8 to 21/32 (Ø15.8 to 16.7) (O.D.)	

Type	Wall mounted			
	Inverter heat pump			
Model name		ASUG09LZAS	ASUG12LZAS	ASUG15LZAS
Operation range	Cooling	°F (°C)	64 to 90 (18 to 32)	
		%RH	80 or less	
	Heating	°F (°C)	60 to 86 (16 to 30)	
Remote controller type	Wireless (Wired, Mobile app ⁵ [FG Lair™] [option])			

NOTES:

- Specifications are based on the following conditions:
 - Cooling: Indoor temperature of 80°FDB (26.67°CDB)/67°FWB (19.44°CWB), and outdoor temperature of 95°FDB (35°CDB)/75°FWB (23.9°CWB).
 - Heating: Indoor temperature of 70°FDB (21.11°CDB)/59°FWB (15.56°CWB), and outdoor temperature of 47°FDB (8.33°CDB)/43°FWB (6.11°CWB).
 - *1: Heating (17°F): Indoor temperature of 70°FDB (21.11°CDB)/60°FWB (15.56°CWB), and outdoor temperature of 17°FDB (-8.33°CDB)/15°FWB (-9.44°CWB).
 - *2: Heating (5°F): Indoor temperature of 70°FDB (21.11°CDB)/60°FWB (15.56°CWB), and outdoor temperature of 5°FDB (-15.0°CDB)/4°FWB (-15.56°CWB).
 - Test conditions are based on AHRI 210/240 2023.
 - Pipe length: 25 ft (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)
 - Protective function might work when using it outside the operation range.
 - *3: Maximum current is maximum value when operated within the operation range.
 - *4: Sound pressure level:
 - Measured values in manufacturer's anechoic chamber.
 - Because of the surrounding sound environment, the sound levels measured in actual installation conditions might be higher than the specified values here.
 - *5: Available on Google Play™ store or on App Store®. Optional WLAN Adapter is also required. For details, refer to the setting manual.

M condition						
Model name			ASUG09LZAS	ASUG12LZAS	ASUG15LZAS	
Capacity	Cooling	Rated	kW	2.64	3.52	
		Btu/h	9,000	12,000	14,500	
		Min.—Max.	kW	0.91—3.52	0.91—3.99	
		Btu/h	3,100—12,000	3,100—13,600	3,100—18,400	
	Heating	Rated	kW	3.52	4.69	
		Btu/h	12,000	16,000	18,000	
		Min.—Max.	kW	0.91—6.45	0.91—6.48	
		Btu/h	3,100—22,000	3,100—22,100	3,100—23,900	
	Heating (17°F)*	Rated	kW	2.17	2.93	
		Btu/h	7,400	10,000	11,200	
		Max.	kW	4.69	5.13	
		Btu/h	16,000	17,500	21,500	
Input power	Cooling	Rated		0.50	0.79	
		Min.—Max.		0.11—0.85	0.11—0.99	
			kW	0.66	1.01	
	Heating	Rated		0.17—1.93	0.17—1.94	
		Min.—Max.		0.62	0.91	
	Heating (17°F)*	Rated			2.21	
Current	Cooling	Rated	A	2.5	3.8	
	Heating			3.3	4.7	
EER	Cooling		kW/kW	5.28	4.46	
			Btu/hW	18.0	15.2	
COP	Heating		kW/kW	5.34	4.64	
			Btu/hW	18.2	15.8	
SEER	Cooling		Btu/hW	33.1	29.4	
HSPF	Heating		Btu/hW	14.0	13.8	
Power factor	Cooling	%		87	90	
	Heating			87	93	

NOTES:
 Specifications are based on the following conditions:

- Cooling: Indoor temperature of 80°FDB (26.67°CDB)/67°FWB (19.44°CWB), and outdoor temperature of 95°FDB (35°CDB)/75°FWB (23.9°CWB).
- Heating: Indoor temperature of 70°FDB (21.11°CDB)/59°FWB (15.56°CWB), and outdoor temperature of 47°FDB (8.33°CDB)/43°FWB (6.11°CWB).
- *: Heating (17°F): Indoor temperature of 70°FDB (21.11°CDB)/60°FWB (15.56°CWB), and outdoor temperature of 17°FDB (-8.33°CDB)/15°FWB (-9.44°CWB).
- Test conditions are based on AHRI 210/240 2017.
- Pipe length: 25 ft (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)

2. Wireless LAN control

By installing Mobile App on a smart device, several functions can be controlled from outside the house.

2-1. System requirement

Before using this function, prepare the following items:

- **Wireless router:**

Wireless LAN standard	IEEE802.11b/g/n
Frequency bands*	<ul style="list-style-type: none"> • U.S.A., Canada: 2.4 GHz (1ch—11ch) • Other countries: 2.4 GHz (1ch—13ch)
Network security standard	<ul style="list-style-type: none"> • Open • WEP • WPA (PSK) • WPA2 Personal (PSK) • WPS for same-LAN registration

*: Usable only in the country or region where you purchased the product.

To check whether your wireless router complies with the network security standards listed above, refer to the operation manual.

- **Smartphone or Tablet PC:**

App-compliant operating system	iOS Android	Check the latest version of supported OS at Google Play store or App Store.
--------------------------------	----------------	---

- **FGLair™ (mobile application):**

Mobile App is available on Google Play store or on App Store.

After installation of Mobile App, user registration is required. For user registration and setup information, refer to Setting Manual attached with the product.

For the latest version of the Wireless LAN (WLAN) control manuals, refer to the following web site.
<https://www.fujitsu-general.com/global/support/>

2-2. Wireless LAN function list

NOTE: To use Wireless LAN control, user registration in advance and access to the wireless home network are required.

	Item	Mobile App	Attached wireless remote controller
Air conditioning control function	Operation on/off	○	○
	Operation mode setting	○	○
	Set temperature setting	○	○
	Fan speed setting	○	○
	Airflow direction setting	Louver position adjustment (vertical)	○
		Swing (vertical)	○
	Timer operation	Off timer	— ○*1
		On timer	— ○*1
		Sleep timer	— ○*1
		On/off program timer	— ○*1
		Weekly timer*2	○ ○*1
Additional function	POWERFUL operation setting	○*1	○*1
	ECONOMY operation setting	○	○
	MIN. HEAT operation setting	○*1	○*1
	Room temperature indication	○	—
	Human sensor for energy saving setting	○*1	○*1
	Outdoor unit low noise operation setting	○*1	○*1
App function	Air conditioner error e-mail notification	○	—


*1: Not operable when wired remote controller is connected.

*2: Configurable functions of the weekly timer differs on wireless remote controller and on mobile application. If timer settings are done from mobile application and from wireless remote controller, both timer settings will be active.

3. Dimensions

3-1. Models: ASUG09LZAS, ASUG12LZAS, and ASUG15LZAS



Unit: in (mm)



■ Installation space requirement


Provide sufficient installation space for product safety.

Unit: in (mm)



4. Wiring diagrams

4-1. Models: ASUG09LZAS, ASUG12LZAS, and ASUG15LZAS



5. Capacity table

Capacity tables show each of following values calculated based on the outdoor temperature and the indoor temperature, under given Airflow Rate (AFR):

For cooling capacity: Total Capacity (TC), Sensible Heat Capacity (SHC), and Input Power (IP)

For heating capacity: Total Capacity (TC) and Input Power (IP)

5-1. Cooling capacity

■ Model: ASUG09LZAS

AFR	CFM	542
-----	-----	-----

		Indoor temperature																	
		64			70			75			80			85			90		
Outdoor temperature	°FDB	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP
	°FWB	kBtu	kW	kBtu	kW	kBtu	kW	kBtu	kW	kBtu	kW	kBtu	kW	kBtu	kW	kBtu	kW	kBtu	kW
14	8.33	8.06	0.19	9.29	8.11	0.19	10.25	8.87	0.20	10.57	9.53	0.20	11.17	9.50	0.20	11.81	10.07	0.21	
23	8.16	7.88	0.22	9.09	7.91	0.22	10.03	8.65	0.23	10.35	9.31	0.22	10.94	9.28	0.22	11.56	9.91	0.23	
32	7.99	7.69	0.22	8.90	7.75	0.23	9.81	8.45	0.24	10.13	9.16	0.23	10.70	9.09	0.23	11.32	9.68	0.24	
41	7.81	7.58	0.24	8.71	7.61	0.24	9.60	8.28	0.25	9.90	8.97	0.24	10.47	8.90	0.24	11.07	9.50	0.25	
50	7.64	7.36	0.22	8.51	7.41	0.22	9.38	8.07	0.24	9.68	8.76	0.23	10.24	8.70	0.23	10.83	9.26	0.24	
59	7.47	7.24	0.27	8.32	7.27	0.27	9.16	7.91	0.28	9.46	8.57	0.28	10.01	8.51	0.28	10.58	9.08	0.28	
67	8.42	8.15	0.34	9.38	8.18	0.35	10.33	8.94	0.36	10.67	9.63	0.36	11.28	9.59	0.36	11.93	10.18	0.37	
77	8.01	7.74	0.39	8.93	7.77	0.39	9.85	8.49	0.40	10.16	9.15	0.40	10.74	9.11	0.41	11.35	9.73	0.41	
87	7.57	7.29	0.44	8.45	7.36	0.44	9.31	8.01	0.45	9.58	8.67	0.45	10.16	8.63	0.46	10.74	9.18	0.46	
95	7.09	6.88	0.48	7.91	6.91	0.49	8.73	7.53	0.50	9.00	8.15	0.50	9.55	8.12	0.51	10.06	8.63	0.51	
104	6.00	5.67	0.45	6.68	6.16	0.46	7.36	6.71	0.46	7.60	7.26	0.46	8.05	7.22	0.47	8.52	7.70	0.47	
115	5.52	5.33	0.45	6.17	5.71	0.46	6.78	6.22	0.46	6.99	6.74	0.46	7.43	6.71	0.47	7.84	7.15	0.47	

AFR	m ³ /h	920
-----	-------------------	-----

		Indoor temperature																	
		17.8			21.1			23.9			26.7			29.4			32.2		
Outdoor temperature	°CDB	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP	TC	SHC	IP
	°CWB	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW	kW
-10.0	2.44	2.36	0.19	2.72	2.38	0.19	3.00	2.60	0.20	3.10	2.79	0.20	3.27	2.78	0.20	3.46	2.95	0.21	
-5.0	2.39	2.31	0.22	2.67	2.32	0.22	2.94	2.53	0.23	3.03	2.73	0.22	3.21	2.72	0.22	3.39	2.90	0.23	
0.0	2.34	2.25	0.22	2.61	2.27	0.23	2.88	2.48	0.24	2.97	2.68	0.23	3.14	2.67	0.23	3.32	2.84	0.24	
5.0	2.29	2.22	0.24	2.55	2.23	0.24	2.81	2.43	0.25	2.90	2.63	0.24	3.07	2.61	0.24	3.25	2.79	0.25	
10.0	2.24	2.16	0.22	2.49	2.17	0.22	2.75	2.37	0.24	2.84	2.57	0.23	3.00	2.55	0.23	3.17	2.71	0.24	
15.0	2.19	2.12	0.27	2.44	2.13	0.27	2.69	2.32	0.28	2.77	2.51	0.28	2.93	2.49	0.28	3.10	2.66	0.28	
19.4	2.47	2.39	0.34	2.75	2.40	0.35	3.03	2.62	0.36	3.13	2.82	0.36	3.31	2.81	0.36	3.50	2.98	0.37	
25.0	2.35	2.27	0.39	2.62	2.28	0.39	2.89	2.49	0.40	2.98	2.68	0.40	3.15	2.67	0.41	3.33	2.85	0.41	
30.6	2.22	2.14	0.44	2.48	2.16	0.44	2.73	2.35	0.45	2.81	2.54	0.45	2.98	2.53	0.46	3.15	2.69	0.46	
35.0	2.08	2.02	0.48	2.32	2.03	0.49	2.56	2.21	0.50	2.64	2.39	0.50	2.8	2.38	0.51	2.95	2.53	0.51	
40.0	1.76	1.66	0.45	1.96	1.80	0.46	2.16	1.97	0.46	2.23	2.13	0.46	2.36	2.12	0.47	2.50	2.26	0.47	
46.1	1.62	1.56	0.45	1.81	1.67	0.46	1.99	1.82	0.46	2.05	1.98	0.46	2.18	1.97	0.47	2.30	2.10	0.47	

5-2. Heating capacity

NOTE: Values mentioned in the table are calculated based on the maximum capacity.

■ Model: ASUG09LZAS

AFR	CFM	Indoor temperature								
Outdoor temperature	°FDB	°FDB	60		65		70		75	
		°FWB	TC kBtu	IP kW	TC kBtu	IP kW	TC kBtu	IP kW	TC kBtu	IP kW
-15	-17	11.6	2.15		11.4	2.19	11.1	2.23	10.5	2.31
-5	-7	14.7	2.16		14.3	2.20	14.0	2.24	13.3	2.32
5	3	16.1	2.17		15.7	2.21	15.4	2.25	14.6	2.34
14	12	16.8	2.13		16.4	2.17	16.0	2.22	15.2	2.30
23	19	18.3	2.10		17.9	2.14	17.5	2.18	16.6	2.26
32	28	18.8	2.06		18.4	2.10	17.9	2.14	17.0	2.22
41	37	21.3	1.88		20.8	1.92	20.3	1.95	19.3	2.03
47	43	23.1	1.85		22.6	1.89	22.0	1.93	20.9	2.01
50	47	25.5	1.84		24.9	1.88	24.3	1.91	23.1	1.99
59	50	26.5	1.63		25.8	1.67	25.2	1.70	23.9	1.77

AFR	CFM	Indoor temperature								
Outdoor temperature	°CDB	°CDB	15.6		18.3		21.1		23.9	
		°CWB	TC kW	IP kW	TC kW	IP kW	TC kW	IP kW	TC kW	IP kW
-26.1	-27.0	3.41	2.15		3.33	2.19	3.25	2.23	3.09	2.31
-20.6	-21.7	4.31	2.16		4.20	2.20	4.10	2.24	3.90	2.32
-15.0	-16.1	4.73	2.17		4.61	2.21	4.50	2.25	4.28	2.34
-10.0	-11.1	4.91	2.13		4.80	2.17	4.68	2.22	4.45	2.30
-5.0	-7.2	5.38	2.10		5.25	2.14	5.12	2.18	4.86	2.26
0.0	-2.2	5.52	2.06		5.39	2.10	5.26	2.14	5.00	2.22
5.0	2.8	6.25	1.88		6.10	1.92	5.95	1.95	5.65	2.03
8.3	6.1	6.77	1.85		6.61	1.89	6.45	1.93	6.13	2.01
10.0	8.3	7.48	1.84		7.30	1.88	7.13	1.91	6.77	1.99
15.0	10.0	7.75	1.63		7.57	1.67	7.38	1.70	7.02	1.77

■ Model: ASUG12LZAS

AFR	CFM	Indoor temperature								
Outdoor temperature	°FDB	°FDB	60		65		70		75	
		°FWB	TC kBtu/h	IP kW	TC kBtu/h	IP kW	TC kBtu/h	IP kW	TC kBtu/h	IP kW
-15	-17	12.4	2.15		12.1	2.19	11.8	2.23	11.2	2.31
-5	-7	15.8	2.16		15.4	2.20	15.0	2.24	14.3	2.32
5	3	17.4	2.17		17.0	2.21	16.6	2.25	15.8	2.34
14	12	18.3	2.13		17.8	2.18	17.4	2.22	16.5	2.30
23	19	20.0	2.10		19.5	2.14	19.0	2.18	18.1	2.26
32	28	20.6	2.07		20.1	2.11	19.6	2.15	18.6	2.23
41	37	22.5	1.88		21.9	1.92	21.4	1.96	20.3	2.04
47	43	23.2	1.86		22.7	1.90	22.1	1.94	21.0	2.02
50	47	25.6	1.85		25.0	1.89	24.4	1.93	23.2	2.00
59	50	26.6	1.64		25.9	1.68	25.3	1.71	24.0	1.78

AFR	CFM	Indoor temperature								
Outdoor temperature	°CDB	°CDB	15.6		18.3		21.1		23.9	
		°CWB	TC kW	IP kW	TC kW	IP kW	TC kW	IP kW	TC kW	IP kW
-26.1	-27.0	3.62	2.15		3.54	2.19	3.45	2.23	3.28	2.31
-20.6	-21.7	4.63	2.16		4.52	2.20	4.41	2.24	4.19	2.32
-15.0	-16.1	5.11	2.17		4.99	2.21	4.86	2.25	4.62	2.34
-10.0	-11.1	5.36	2.13		5.23	2.18	5.10	2.22	4.85	2.30
-5.0	-7.2	5.86	2.10		5.72	2.14	5.58	2.18	5.30	2.26
0.0	-2.2	6.03	2.07		5.88	2.11	5.74	2.15	5.45	2.23
5.0	2.8	6.58	1.88		6.43	1.92	6.27	1.96	5.96	2.04
8.3	6.1	6.80	1.86		6.64	1.90	6.48	1.94	6.15	2.02
10.0	8.3	7.52	1.85		7.34	1.89	7.16	1.93	6.80	2.00
15.0	10.0	7.79	1.64		7.60	1.68	7.42	1.71	7.05	1.78

■ Model: ASUG15LZAS

AFR	CFM	600
-----	-----	-----

Indoor temperature										
Outdoor temperature	°FDB		60		65		70		75	
	°FDB	°FWB	TC	IP	TC	IP	TC	IP	TC	IP
			kBtu/h	kW	kBtu/h	kW	kBtu/h	kW	kBtu/h	kW
-15	-17	17.1	2.77	16.7	2.82	16.3	2.88	15.5	2.98	
-5	-7	19.6	2.78	19.1	2.84	18.6	2.89	17.7	3.00	
5	3	22.0	2.79	21.5	2.85	21.0	2.90	19.9	3.01	
14	12	22.7	2.68	22.2	2.73	21.6	2.78	20.5	2.89	
23	19	23.3	2.56	22.8	2.61	22.2	2.66	21.1	2.76	
32	28	24.0	2.45	23.4	2.49	22.9	2.54	21.7	2.64	
41	37	24.7	2.18	24.1	2.22	23.5	2.27	22.3	2.36	
47	43	25.1	2.10	24.5	2.15	23.9	2.19	22.7	2.28	
50	47	26.1	1.97	25.5	2.01	24.9	2.05	23.6	2.13	
59	50	27.2	1.75	26.5	1.79	25.9	1.82	24.6	1.89	

AFR	m ³ /h	1,020
-----	-------------------	-------

Indoor temperature										
Outdoor temperature	°CDB		15.6		18.3		21.1		23.9	
	°CDB	°CWB	TC	IP	TC	IP	TC	IP	TC	IP
			kW		kW		kW		kW	
-26.1	-27.0	5.01	2.77	4.89	2.82	4.77	2.88	4.53	2.98	
-20.6	-21.7	5.73	2.78	5.60	2.84	5.46	2.89	5.19	3.00	
-15.0	-16.1	6.46	2.79	6.31	2.85	6.15	2.90	5.84	3.01	
-10.0	-11.1	6.65	2.68	6.49	2.73	6.33	2.78	6.02	2.89	
-5.0	-7.2	6.84	2.56	6.68	2.61	6.52	2.66	6.19	2.76	
0.0	-2.2	7.04	2.45	6.87	2.49	6.70	2.54	6.37	2.64	
5.0	2.8	7.23	2.18	7.06	2.22	6.88	2.27	6.54	2.36	
8.3	6.1	7.35	2.10	7.18	2.15	7.00	2.19	6.65	2.28	
10.0	8.3	7.66	1.97	7.47	2.01	7.29	2.05	6.93	2.13	
15.0	10.0	7.97	1.75	7.78	1.79	7.59	1.82	7.21	1.89	


6. Fan performance

6-1. Air velocity distributions


■ Models: ASUG09LZAS and ASUG12LZAS

Measuring conditions	Fan speed HIGH	Operation mode FAN
----------------------	-------------------	-----------------------


Top view
Horizontal louver: Up
Vertical louver: Center




Top view
Horizontal louver: Up
Vertical louver: Left & Right




Side view
Horizontal louver: Up
Vertical louver: Center



Side view
Horizontal louver: Down
Vertical louver: Center



■ Model: ASUG15LZAS



6-2. Airflow

■ Model: ASUG09LZAS

● Cooling

Fan speed	Airflow	
HIGH	m^3/h	920
	l/s	256
	CFM	542
MED	m^3/h	690
	l/s	192
	CFM	406
LOW	m^3/h	530
	l/s	147
	CFM	312
QUIET	m^3/h	350
	l/s	97
	CFM	206

● Heating

Fan speed	Airflow	
HIGH	m^3/h	920
	l/s	256
	CFM	542
MED	m^3/h	690
	l/s	192
	CFM	406
LOW	m^3/h	530
	l/s	147
	CFM	312
QUIET	m^3/h	350
	l/s	97
	CFM	206

■ Model: ASUG12LZAS

● Cooling

Fan speed	Airflow	
HIGH	m ³ /h	920
	l/s	256
	CFM	542
MED	m ³ /h	690
	l/s	192
	CFM	406
LOW	m ³ /h	530
	l/s	147
	CFM	312
QUIET	m ³ /h	350
	l/s	97
	CFM	206

● Heating

Fan speed	Airflow	
HIGH	m ³ /h	920
	l/s	256
	CFM	542
MED	m ³ /h	690
	l/s	192
	CFM	406
LOW	m ³ /h	530
	l/s	147
	CFM	312
QUIET	m ³ /h	350
	l/s	97
	CFM	206

■ Model: ASUG15LZAS

● Cooling

Fan speed	Airflow	
HIGH	m ³ /h	990
	l/s	275
	CFM	583
MED	m ³ /h	780
	l/s	217
	CFM	459
LOW	m ³ /h	530
	l/s	147
	CFM	312
QUIET	m ³ /h	410
	l/s	114
	CFM	241

● Heating


Fan speed	Airflow	
HIGH	m ³ /h	1,020
	l/s	283
	CFM	600
MED	m ³ /h	780
	l/s	217
	CFM	459
LOW	m ³ /h	530
	l/s	147
	CFM	312
QUIET	m ³ /h	410
	l/s	114
	CFM	241

7. Operation noise (sound pressure)


7-1. Noise level curve

■ Models: ASUG09LZAS and ASUG12LZAS

● Cooling




● Heating




■ Model: ASUG15LZAS


● Cooling



● Heating



7-2. Sound level check point



NOTE: Detailed shape of the actual indoor unit might be slightly different from the one illustrated above.


8. Safety devices

Type of protection	Protection form	Model		
		ASUG09LZAS	ASUG12LZAS	ASUG15LZAS
Circuit protection	Current fuse (PCB*)	250 V, 3.15 A		
Fan motor protection	Thermal protector program	Activate	257±18 °F (125±10 °C) Fan motor stop	
		Reset	212±18 °F (100±10 °C) Fan motor restart	

*PCB: Printed Circuit Board

9. External input and output

External input and output PCB



PCB	External input	External output	Connector	Input select	Input signal
External input and output (UTY-XCSXZ2)	Operation/Stop	—	CN313/ CN314	Dry contact/ Apply voltage	Edge/Pulse
	Forced stop				
	Forced thermostat off		CN313	—	Edge
	—	Operation status	CN310		—
		Error status	CN311		
		Indoor unit fan operation status	CN312		
		External heater output	—		

9-1. External input

With using external input function, some functions on this product can be controlled from an external device.

- "Operation/Stop" mode or "Forced stop" mode can be selected with function setting of indoor unit.
- A twisted pair cable (22AWG) should be used. Maximum length of cable is 492 ft (150 m).
- The wire connection should be separate from the power cable line.

External Input and Output PCB


The indoor unit Operation/Stop can be set by using the input connector on the PCB.

Input select:

Use either one of these types of connectors according to the application. (Both types of connectors cannot be used simultaneously.)

Dry contact


In case of internal power supply, set the slide switch of SW301 to "NON VOL" side.



*1: The switches can be used on the following condition: DC 12 V to 24 V, 1 mA to 15 mA.

Apply voltage

In case of external power supply, set the slide switch of SW301 to "VOL" side.



*1: The switches can be used on the following condition: DC 12 V to 24 V, 1 mA to 15 mA.

*2: Make the power supply DC 12 to 24 V, 10 mA or more.


9-2. External output

Use an external output cable with appropriate external dimension, depending on the number of cables to be installed.

External Input and Output PCB


- A twisted pair cable (22AWG) should be used. Maximum length of cable is 82 ft (25 m).
- Output voltage: High DC 12 V±2 V, Low 0 V.
- Permissible current: 50 mA
- For details, refer to "[Combination of external input and output](#)" on page 24.
- When indicator or other components are connected directly:**

Example: Rotary SW on External Input and Output PCB is set to "1".



- When connecting with a device equipped with a power supply:**

Example: Rotary SW on External Input and Output PCB is set to "1".



9-3. Combination of external input and output

By combining the function setting of the rotary switch setting of the External Input and Output PCB, you can select various combinations of functions.

Combination examples of external input and output are as follows:

External Input and Output PCB (Rotary SW)	External input		
	External Input and Output PCB		
	CN313	CN314	Signal type
1	Operation/Stop	Not available	Edge
	Operation	Stop	Pulse
2	Forced Thermostat OFF	Not available	Edge
3 - 9, A	(Setting prohibited)		
B	Forced Thermostat OFF	Not available	Edge
C	Forced Thermostat OFF	Not available	Edge
D	Forced Thermostat OFF	Not available	Edge

External Input and Output PCB (Rotary SW)	External output		
	External Input and Output PCB		
	CN310	CN311	CN312
1	Operation/Stop	Error status	Indoor unit fan operation status
2	Error status	Indoor unit fan operation status	External heater output
3 - 9, A	(Setting prohibited)		
B	Operation/Stop	Indoor unit fan operation status	External heater output
C	Operation/Stop	Error status	External heater output
D	Operation/Stop	Indoor unit fan operation status	Error status

NOTE: Input of Operation/Stop depends on the setting of function setting 46.

00: Operation/Stop mode 1 (R.C. enabled)

01: (Setting prohibited)

02: Forced stop


03: Operation/Stop mode 2 (R.C. disabled)

■ Input signal type

External Input and Output PCB:

The input signal type can be selected.

Signal type (edge or pulse) can be switched by the DIP switch SW302 on the External Input and Output PCB.




9-4. Details of function

■ Control input function


- When function setting is “Operation/Stop” mode 1
 - In the case of “Edge” input:

Function setting	Rotary SW on External Input and Output PCB	External input		Input signal	Command
46-00	1	External Input and Output PCB	CN313	Off → On	Operation
				On → Off	Stop



- In the case of “Pulse” input:

Function setting	Rotary SW on External Input and Output PCB	External input		Input signal	Command
46-00	1	External Input and Output PCB	CN313	Pulse	Operation
			CN314	Pulse	Stop




NOTES:

- The last command has priority.
- The indoor units within the same remote controller group operates in the same mode.

- When function setting is “Forced stop” mode


- In the case of “Edge” input:

Function setting	Rotary SW on External Input and Output PCB	External input		Input signal	Command
46-02	1	External Input and Output PCB	CN313	Off → On	Forced stop
				On → Off	Normal



- In the case of “Pulse” input:

Function setting	Rotary SW on External Input and Output PCB	External input		Input signal	Command
46-02	1	External Input and Output PCB	CN313	Pulse	Forced stop
			CN314	Pulse	Normal



NOTES:

- When the forced stop is triggered, indoor unit stops and Operation/Stop operation by the remote controller is restricted.
- When forced stop function is used with forming a remote controller group, connect the same equipment to each indoor unit within the group.

- When function setting is “Operation/Stop” mode 2


- In the case of “Edge” input:

Function setting	Rotary SW on External Input and Output PCB	External input		Input signal	Command
46-03	1	External Input and Output PCB	CN313	Off → On	Operation
				On → Off	Stop (Remote controller disabled)



- In the case of “Pulse” input:


Function setting	Rotary SW on External Input and Output PCB	External input		Input signal	Command
46-03	1	External Input and Output PCB	CN313	Pulse	Operation
			CN314	Pulse	Stop (Remote controller disabled)



NOTE: When “Operation/Stop” mode 2 function is used with forming a remote controller group, connect the same equipment to each indoor unit within the group.

- Forced thermostat off function

Rotary SW on External Input and Output PCB	External input		Input signal	Command
2 B C	External Input and Output PCB	CN313	Off → On	Thermostat off
			On → Off	Normal operation




■ Control output function

- Operation/Stop status

Rotary SW on External Input and Output PCB	External output		Output signal	Command
1 B C D	External Input and Output PCB	CN310	Off → On	Operation
			On → Off	Stop


The output is low when the unit is stopped.



- Error status

Rotary SW on External Input and Output PCB	External output		Output signal	Command
1 C	External Input and Output PCB	CN311	Off → On	Error
			On → Off	Normal
D	External Input and Output PCB	CN312	Off → On	Error
			On → Off	Normal


The output is ON when an error is generated for the indoor unit.



- Indoor unit fan operation status

Rotary SW on External Input and Output PCB	External output		Output signal	Command
1	External Input and Output PCB	CN312	Off → On	Fan run
			On → Off	Fan stop
2 B D	External Input and Output PCB	CN311	Off → On	Fan run
			On → Off	Fan stop

Output signal	Condition
On Low → High	The indoor unit fan is operating.
Off High → Low	The fan is stopped or during cold air prevention. During thermostat off when in dry mode operation.



- External heater output

Rotary SW on External Input and Output PCB	External output		Output signal	Command
2 B C	External Input and Output PCB	CN312	Off → On	Heater on
			On → Off	Heater off

■ External heater output


Control	Primary heater	Auxiliary heater	Function setting	
			Indoor unit	Wired R. C.
			Control switching external heaters No. 61	Sensor activation*2
Auxiliary heater control 1	Heat pump	External device*1	61-00	—
Auxiliary heater control 2	Heat pump	External device	61-01	—
Heat pump prohibition control	External device	None	61-02	On (Enabled)
Auxiliary heater control by outdoor temperature 1	Heat pump	External device	61-03	On (Enabled)
Auxiliary heater control by outdoor temperature 2	Heat Pump	External device	61-04	On (Enabled)

NOTES:

- After turning off the heater, 3 minutes of standby time is required by next power-on of the heater.
- For items marked “—” in the table, any of validate or invalidate of the setting are acceptable.
- *1: External device means Hot water, Electrical heater, etc.
- *2: Sensor activation:
 - Setting change from the factory setting is required.
 - Indoor unit fan setting will be on for safety reason without sensor activation of wired remote controller.

● Installation configuration of individual connection

External heating device is installed individually. (No use of indoor unit fan)




⚠ WARNING

- Design and install external heater appropriately with considering its protection.
- Inappropriate designing and installation of external heater may cause a fire by emitted heat from the external heater.
- Fujitsu General Ltd. is not responsible for inappropriate designing or installation of external heating device.

● Auxiliary heater control 1

Operation	Condition
Heater on	Heater is on as shown in following diagram of heating temperature.
Heater off	<ul style="list-style-type: none"> Heater is off as shown in following diagram of heating temperature. Other than heating mode Error occurred Forced thermostat off Fan stop protection

- Temperature of heater on (Thon): Adjustable by function number 62 (Operating temperature switching of external heaters).
- All control temperatures will shift by adjusting “Thon”.



Tr: Room temperature
 Ts: Set temperature
 Thon: Heater on temperature


Example: When set temperature (Ts) is 72°F (22°C) (Factory setting),

- and room temperature (Tr) increases above 53.6°F (12°C), signal output is on.
- and room temperature (Tr) increases above 69.8°F (21°C), signal output is off.
- and room temperature (Tr) decreases below 66.2°F (19°C), signal output is on.
- and room temperature (Tr) decreases below 50°F (10°C), signal output is off.

● Auxiliary heater control 2

Operation	Condition
Heater on	Heater is on as shown in following diagram of heating temperature.
Heater off	<ul style="list-style-type: none"> Heater is off as shown in following diagram of heating temperature. Other than heating mode Error occurred Forced thermostat off Fan stop protection

- Temperature of heater on (Thon): Adjustable by function number 62 (Operating temperature switching of external heaters).
- All control temperatures will shift by adjusting “Thon”.




Tr: Room temperature
 Ts: Set temperature
 Thon: Heater on temperature

● Heat pump prohibition control


Perform heating by external heater only. Indoor unit is continuous thermostat off.

Operation	Condition
Heater on	Heater is on as shown in following diagram of heating temperature.
Heater off	<ul style="list-style-type: none"> • Heater is off as shown in following diagram of heating temperature. • Other than heating mode • Error occurred • Forced thermostat off

- Temperature of heater on (Thon): Adjustable by function number 62 (Operating temperature switching of external heaters).
- All control temperatures will shift by adjusting “Thon”.



- Operation status



NOTE: In following operations, compressor will be on.

- Other than heating
- Test run


● Auxiliary heater control by outdoor temperature 1

This control selects heat pump or external heater according to the outdoor temperature. When outdoor temperature is high, the heating is performed by using heat pump only.


Operation	Condition
Heater on	Heater is on as shown in following diagram of heating temperature.
Heater off	<ul style="list-style-type: none"> • Heater is off as shown in following diagram of heating temperature. • Other than heating mode • Error occurred • Forced thermostat off • Heat pump only zone

- Temperature of heater on (Thon): Adjustable by function number 62 (Operating temperature switching of external heaters).
- All control temperatures will shift by adjusting “Thon”.
- Outdoor temperature zone boundary A and B: Adjustable individually by function setting number 66 and 67.

• External heater output




• Outdoor temperature zone



*: Adjustable by function setting 66 and 67

- Operation status



* The outdoor temperature zone transition from one to another will stay in that zone for minimum of 30 min.

NOTE: In following operations, compressor will be on in heat pump prohibition zone.


- Other than heating
- Test run

● Auxiliary heater control by outdoor temperature 2


This control selects heat pump or external heater according to the outdoor temperature. Even when outdoor temperature is high, the heating is performed by using both of heat pump and external heater.

Operation	Condition
Heater on	Heater is on as shown in following diagram of heating temperature.
Heater off	<ul style="list-style-type: none"> • Heater is off as shown in following diagram of heating temperature. • Other than heating mode • Error occurred • Forced thermostat off

- Temperature of heater on (Thon): Adjustable by function number 62 (Operating temperature switching of external heaters).
- All control temperatures will shift by adjusting “Thon”.
- Outdoor temperature zone boundary A: Adjustable by function setting number 66.
- **External heater output**




- **Outdoor temperature zone**



*: Adjustable by function setting 66

- Operation status



* The outdoor temperature zone transition from one to another will stay in that zone for minimum of 30 min.


NOTE: In following operations, compressor will be on in heat pump prohibition zone.

- Other than heating
- Test run

10. Remote controller


10-1. Wireless remote controller

■ Overview



NOTE: Functions may differ by type of the indoor unit. For details, refer to the operation manual.

Display panel




To facilitate explanation, the accompanying illustration has been drawn to show all possible indicators; in actual operation, however, the display will only show those indicators appropriate to the current operation.

■ Specifications

● Controller


Unit: in (mm)



Size (H × W × D)	in (mm)	8-1/16 × 2-3/8 × 11/16 (205 × 61 × 17)
Weight	oz (g)	4.4 (124) (without batteries)

● Holder

Unit: in (mm)



Size (H × W × D)	in (mm)	5-7/8 × 2-3/4 × 1-1/16 (150 × 69.3 × 26.2)
Weight	oz (g)	1 (27)

11. Function settings

To adjust the functions of this product according to the installation environment, various types of function settings are available.

NOTE: Incorrect settings can cause a product malfunction.

11-1. Function settings by using remote controller

Some function settings can be changed on the remote controller. After confirming the setting procedure and the content of each function setting, select appropriate functions for your installation environment.

■ Setting procedure by using wireless remote controller

The function number and the associated setting value are displayed on the LCD of the remote controller. Follow the instructions written in the local setup procedure supplied with the remote controller, and select appropriate setting according to the installation environment.

Before connecting the power supply of the indoor unit, reconfirm following items:

- Cover for the electrical enclosure on the outdoor unit is in place.
- There is no wiring mistake.
- Piping air tight test and vacuuming have been performed firmly.
- All the necessary wiring work for outdoor unit has been finished.

After reconfirming the items listed above, connect the power supply of the indoor unit.

NOTES:

- Settings will not be changed if invalid numbers or setting values are selected.
- When optional wired remote controller is used, refer to the installation manual enclosed with the remote controller.

Entering function setting mode:

While pressing the POWERFUL button and TEMP. (\wedge) (\vee) button simultaneously, press the RESET button to enter the function setting mode.

Selecting the function number and setting value:

1. Press the MIN. HEAT button. TEMP. (\wedge) (\vee) buttons to select the function number. Press the MIN. HEAT button to switch between the left and right digits.
2. Press the POWERFUL button to proceed to value setting. To return the function number selection, press the POWERFUL button again.
3. Press the TEMP. (\wedge) (\vee) buttons to select the setting value. To switch between the left and right digits, press the MIN. HEAT button.
4. Press the MODE button once. Confirm that you hear the beep sound.
5. Press the START/STOP button to fix the function setting. Confirm that you hear the beep sound.
6. Press the RESET button to end the function setting mode.
7. After completing the function setting, be sure to disconnect the power supply and then reconnect it.



⚠ CAUTION

After disconnecting the power supply, wait 30 seconds or more before reconnecting it. The function setting will not become active unless the power supply is disconnected and then reconnected.

NOTES:

- The air conditioner custom code is set to prior to shipment.
- If you do not know the air conditioner custom code setting, try each of the custom codes (→ → →) until you find the code that operates the air conditioner.

■ Contents of function setting

Each function setting listed in this section is adjustable in accordance with the installation environment.

NOTE: Setting will not be changed if invalid numbers or setting values are selected.

● Function setting list

	Function no.	Functions
1)	00	Remote controller address setting
2)	11	Filter sign
3)	30/31	Room temperature control for indoor unit sensor
4)	35/36	Room temperature control for wired remote controller sensor
5)	40	Auto restart
6)	42	Room temperature sensor switching
7)	44	Remote controller custom code
8)	46	External input control
9)	48	Room temperature sensor switching (Aux.)
10)	49	Indoor unit fan control for energy saving for cooling
11)	61	Control switching of external heaters
12)	62	Operating temperature switching of external heaters
13)	66	Outdoor temperature zone boundary temperature A
14)	67	Outdoor temperature zone boundary temperature B
15)	95	Heat insulation condition (building insulation)

1) Remote controller address setting

NOTE: Because this setting is normally done automatically when 2-wire-type wired remote controller is installed, setting is unnecessary.

Multiple indoor units can be operated by using one wired remote controller.

Set the unit number of each indoor unit.

Function number	Setting value	Setting description	Factory setting
00	00	Unit no. 0	◆
	01	Unit no. 1	
	02	Unit no. 2	
	03	Unit no. 3	
	04	Unit no. 4	
	05	Unit no. 5	
	06	Unit no. 6	
	07	Unit no. 7	
	08	Unit no. 8	
	09	Unit no. 9	
	10	Unit no. 10	
	11	Unit no. 11	
	12	Unit no. 12	
	13	Unit no. 13	
	14	Unit no. 14	
	15	Unit no. 15	

NOTE: When different type of indoor units (such as wall mounted type and cassette type, cassette type and duct type, or other combinations) are connected using group control system, some functions may no longer be available.

2) Filter sign

Select appropriate intervals for displaying the filter sign on the indoor unit according to the estimated amount of dust in the air of the room.

If the indication is not required, select "No indication" (03).

Function number	Setting value	Setting description	Factory setting
11	00	Standard (400 hours)	
	01	Long interval (1,000 hours)	
	02	Short interval (200 hours)	
	03	No indication	◆

3) Room temperature control for indoor unit sensor

NOTE: Before performing this setting, refer to Function 95.

Depending on the installed environment, correction of the room temperature sensor may be required. Select the appropriate control setting according to the installed environment.

The temperature of the room temperature sensor is corrected as follows:

$$\text{Corrected temp.} = \text{Temp. of the room temp. sensor} - \text{Correction temp. value}$$

Example of correction:

When the temperature of the room temp. sensor is 78°F and the setting value is "03" (-2°F), the corrected temp. will be 80°F (78°F - [-2°F]).

The temperature correction values show the difference from the Standard setting "00" (manufacturer's recommended value).

*When Function 95-01 (High insulation) is set, the Standard setting "00" will be the same as "No correction 0.0 °F (0.0 °C)" (01).

Function number	Setting value	Setting description	Factory setting
30 (For cooling)	00	Standard setting*	◆
	01	No correction 0.0 °F (0.0 °C)	
	02	-1 °F (-0.5 °C)	More cooling Less heating
	03	-2 °F (-1.0 °C)	
	04	-3 °F (-1.5 °C)	
	05	-4 °F (-2.0 °C)	
	06	-5 °F (-2.5 °C)	
	07	-6 °F (-3.0 °C)	
	08	-7 °F (-3.5 °C)	
	09	-8 °F (-4.0 °C)	
	10	+1 °F (+0.5 °C)	Less cooling More heating
	11	+2 °F (+1.0 °C)	
	12	+3 °F (+1.5 °C)	
	13	+4 °F (+2.0 °C)	
	14	+5 °F (+2.5 °C)	
	15	+6 °F (+3.0 °C)	
	16	+7 °F (+3.5 °C)	
	17	+8 °F (+4.0 °C)	

4) Room temperature control for wired remote controller sensor

NOTE: Before performing this setting, refer to Function 95.

Depending on the installed environment, correction of the wire remote temperature sensor may be required. Select the appropriate control setting according to the installed environment.

To change this setting, set Function 42 to Both "01".

Ensure that the Thermo Sensor icon is displayed on the remote controller screen.

*When Function 95-01 (High insulation) is set, the Standard setting "00" will be the same as "No correction 0.0 °C" (01).

Function number	Setting value	Setting description	Factory setting
35 (For cooling)	36 (For heating)	00	Standard setting*
		01	No correction 0.0 °F (0.0 °C)
		02	-1 °F (-0.5 °C)
		03	-2 °F (-1.0 °C)
		04	-3 °F (-1.5 °C)
		05	-4 °F (-2.0 °C)
		06	-5 °F (-2.5 °C)
		07	-6 °F (-3.0 °C)
		08	-7 °F (-3.5 °C)
		09	-8 °F (-4.0 °C)
		10	+1 °F (+0.5 °C)
		11	+2 °F (+1.0 °C)
		12	+3 °F (+1.5 °C)
		13	+4 °F (+2.0 °C)
		14	+5 °F (+2.5 °C)
		15	+6 °F (+3.0 °C)
		16	+7 °F (+3.5 °C)
		17	+8 °F (+4.0 °C)

More cooling
Less heating

Less cooling
More heating

5) Auto restart

Enables or disables automatic restart after a power interruption.

Function number	Setting value	Setting description	Factory setting
40	00	Enable	♦
	01	Disable	

NOTE: Auto restart is an emergency function such as for power outage etc. Do not attempt to use this function in normal operation. Be sure to operate the unit by remote controller or external device.

6) Room temperature sensor switching

(Only for wired remote controller)

When using the wired remote controller temperature sensor, change the setting to "Both" (01).

Function number	Setting value	Setting description	Factory setting
42	00	Indoor unit	♦
	01	Both	

00: Sensor on the indoor unit is active.

01: Sensors on both indoor unit and wired remote controller are active.

NOTE: Remote controller sensor must be turned on by using the remote controller.

7) Remote controller custom code

(Only for wireless remote controller)

The indoor unit custom code can be changed. Select the appropriate custom code.

Function number	Setting value	Setting description	Factory setting
44	00	A	◆
	01	B	
	02	C	
	03	D	

8) External input control

"Operation/Stop" mode or "Forced stop" mode can be selected.

Function number	Setting value	Setting description	Factory setting
46	00	Operation/Stop mode 1 (R.C. enabled)	◆
	01	(Setting prohibited)	
	02	Forced stop mode	
	03	Operation/Stop mode 2 (R.C. disabled)	

9) Room temperature sensor switching (Aux.)

To use the temperature sensor on the wired remote controller only, change the setting to "Wired remote controller" (01).

This function will only work if the function setting 42 is set at "Both" (01).

When the setting value is set to "Both" (00), more suitable control of the room temperature is possible by setting function setting 30 and 31 too.

Function number	Setting value	Setting description	Factory setting
48	00	Both	◆
	01	Wired remote controller	

10) Indoor unit fan control for energy saving for cooling

Enables or disables the power-saving function by controlling the indoor unit fan rotation when the outdoor unit is stopped during cooling operation.

Function number	Setting value	Setting description	Factory setting
49	00	Disable	
	01	Enable	
	02	Remote controller	◆

00: When the outdoor unit is stopped, the indoor unit fan operates continuously following the setting on the remote controller.

01: When the outdoor unit is stopped, the indoor unit fan operates intermittently at a very low speed.

02: Enable or disable this function by remote controller setting.

NOTES:

- As the factory setting, this setting is initially invalidated.
- Set to "00" or "01" when connecting a remote controller that cannot set the Fan control for energy saving function or connecting a network converter.
To confirm if the remote controller has this setting, refer to the operating manual of each remote controller.

11) Control switching of external heaters

Sets the control method for external heater to be used.

For details, refer to "External heater output" in Chapter 9-4. "[Details of function](#)" on page 25.

Function number	Setting value	Setting description	Factory setting
61	00	Auxiliary heater control 1	◆
	01	Auxiliary heater control 2	
	02	Heat pump prohibition control	
	03	Auxiliary heater control by outdoor temperature 1	
	04	Auxiliary heater control by outdoor temperature 2	

12) Operating temperature switching of external heaters

Sets the temperature conditions when the external heater is ON.

For details, refer to "External heater output" in Chapter 9-4. "[Details of function](#)" on page 25.

Function number	Setting value	Setting description		Factory setting
		Heater: On	Heater: Off	
62	00	-5.4 °F (-3 °C)	-1.8 °F (-1 °C)	◆
	01	-3.6 °F (-2 °C)	-1.8 °F (-1 °C)	
	02	-3.6 °F (-2 °C)	-1.8 °F (-1 °C)	
	03	-5.4 °F (-3 °C)	-1.8 °F (-1 °C)	
	04	-7.2 °F (-4 °C)	-1.8 °F (-1 °C)	
	05	-9.0 °F (-5 °C)	-1.8 °F (-1 °C)	

13) Outdoor temperature zone boundary temperature A

Setting required if changing of the outdoor temperature setting for heat pump prohibition zone is required when auxiliary heater control by outdoor temperature 1 and 2 are performed on the indoor unit. For details, refer to "External heater output" in Chapter 9-4. "[Details of function](#)" on page 25.

Function number	Setting value	Setting description	Factory setting
66	00	-4.0 °F (-20 °C)	◆
	01	-0.4 °F (-18 °C)	
	02	3.2 °F (-16 °C)	
	03	6.8 °F (-14 °C)	
	04	10.4 °F (-12 °C)	
	05	14.0 °F (-10 °C)	
	06	17.6 °F (-8 °C)	
	07	21.2 °F (-6 °C)	
	08	24.8 °F (-4 °C)	

14) Outdoor temperature zone boundary temperature B

Setting required if changing of the outdoor temperature setting for heat pump only zone is required when auxiliary heater control by outdoor temperature 1 is performed on the indoor unit. For details, refer to "External heater output" in Chapter 9-4. "[Details of function](#)" on page 25.

Function number	Setting value	Setting description	Factory setting
67	00	42.8 °F (6 °C)	◆
	01	14.0 °F (-10 °C)	
	02	17.6 °F (-8 °C)	
	03	21.2 °F (-6 °C)	
	04	24.8 °F (-4 °C)	
	05	28.4°F (-2 °C)	
	06	32.0 °F (0 °C)	
	07	35.6 °F (2 °C)	
	08	39.2 °F (4 °C)	
	09	42.8 °F (6 °C)	
	10	46.4 °F (8 °C)	
	11	50.0 °F (10 °C)	
	12	53.6 °F (12 °C)	
	13	57.2 °F (14 °C)	
	14	60.8 °F (16 °C)	
	15	64.4 °F (18 °C)	

15) Heat insulation condition (building insulation)

Heat insulation conditions differ according to the installed environment.

"Standard insulation" (00) allows system to rapidly respond to the cooling or heating load changes.

"High insulation" (01) is when the heat insulation structure of the building is high and does not require system to rapidly respond to cooling or heating load changes.

When "High insulation" (01) is selected:

- Overheating (overcooling) is prevented at the start-up.
- All room-temperature control settings (Function 30, 31, 35, and 36) will reset to "No correction 0.0 °F (0.0 °C)".

Function number	Setting value	Setting description	Factory setting
95	00	Standard insulation	◆
	01	High insulation	

NOTE: When changing Function 95, perform this setting before other room-temperature control settings (Function 30, 31, 35, and 36). If Function 95 is not set first, room-temperature control settings (Function 30, 31, 35, and 36) will be reset and you must re-do them again.

11-2. Custom code setting for wireless remote controller

To interconnect the air conditioner and the wireless remote controller, assignment of the custom code for the wireless remote controller is required.

NOTE: Air conditioner cannot receive a signal if the air conditioner has not been set for the custom code.

When 2 or more air conditioners are installed in a room, and the remote controller is operating an air conditioner other than the one you wish to set, change the custom code of the remote controller to operate only the air conditioner you wish to set. (4 selections possible.)

Confirm the setting of the remote controller custom code and the function setting. If these do not match, the remote controller cannot be used to operate for the air conditioner.

1. Press the START/STOP button until only the clock is displayed on the remote controller display.
2. Press the MODE button for at least 5 seconds to display the current custom code. (Initially set to **A**.)
3. Press the TEMP. (\wedge) (\vee) buttons to change the custom code between **A** \rightarrow **B** \rightarrow **C** \rightarrow **D**. Match the code on the display to the air conditioner custom code. (Initially set to **A**.)
4. Press the MODE button again to return to the clock display. The custom code will be changed.



NOTES:


- If no button is pressed within 30 seconds after the custom code is displayed, the system returns to the original clock indicator. In this case, start again from step 1.
- The air conditioner custom code is set to **A** prior to shipment. To change the custom code, contact your retailer.
- If you do not know the assigned code for the air conditioner, try each of the custom code (**A** \rightarrow **B** \rightarrow **C** \rightarrow **D**) until you find the code which operates the air conditioner.

11-3. Switching the temperature unit of remote controller

Displayed temperature unit on the remote controller LCD can be switched between °F (Fahrenheit) and °C (Celsius).

To change temperature unit, do as follows:

1. Press the TEMP. (Up) button (\wedge) for at least 5 seconds to display the current temperature unit. (Factory setting: °F)
2. Press the TEMP. (\wedge) (\vee) buttons to switch the temperature unit between °F and °C.
3. With either of pressing the START/STOP button or no additional button operation for 30 seconds in step 2., the temperature unit currently selected will be set.




12. Accessories

Part name	Exterior	Q'ty	Part name	Exterior	Q'ty
Operating manual		1	Tapping screw (large)		5
Installation manual		1	Tapping screw (small)		2
Remote controller		1	Battery		2
Remote controller holder		1	Filter holder		2
Cloth tape		1	Air cleaning filters		1
Wall hook bracket		1			

13. Optional parts

13-1. Controllers

Exterior	Part name	Model name	Summary
	Wired remote controller	UTY-RNRUZ*	<p>Easy finger touch operation with LCD panel. Backlit LCD enables easy operation in a dark room. Wire type: Non-polar 2-wire Optional communication kit is necessary for installation.</p> <p>NOTE: When this remote controller is connected, wireless remote controller cannot be used.</p> 
	Simple remote controller	UTY-RSRY	<p>Compact remote controller concentrates on the basic functions such as Start/Stop, fan control, temperature setting, and operation mode. Wire type: Non-polar 2-wire Optional communication kit is necessary for installation.</p>
	Simple remote controller	UTY-RHRY	<p>Compact remote controller concentrates on the basic functions such as Start/Stop, fan control, and temperature setting. Wire type: Non-polar 2-wire Optional communication kit is necessary for installation.</p>

NOTES:

- Available functions may differ by the remote controller. For details, refer to the operation manual.
- When using the group controlling system of the wired remote controller, using Wireless LAN adapter is prohibited.

13-2. Others

Exterior	Part name	Model name	Summary
	External Connect Kit	UTY-XWZXZ5	Required when external device is connected.
	External Input and Output PCB	UTY-XCSXZ2	Use to connect with external devices and air conditioner PCB. Optional External Connect Kit is necessary for installation.
	Communication Kit	UTY-TWRXZ2	Use to connect Non-polar 2-core wired remote controller.

Part 2. OUTDOOR UNIT

SINGLE TYPE:

AOUG09LZAH1

AOUG12LZAH1

AOUG15LZAH1

1. Specifications


Type			Inverter heat pump				
Model name			AOUG09LZAH1	AOUG12LZAH1	AOUG15LZAH1		
Power supply			208/230 V ~ 60 Hz				
Available voltage range			187—253 V				
Starting current	A		3.3	4.7	5.2		
Fan	Airflow rate	Cooling	1,089 (1,850)	1,171 (1,990)	1,218 (2,070)		
		Heating	1,089 (1,850)	1,089 (1,850)	1,348 (2,290)		
Type × Q'ty	Propeller fan × 1						
Motor output	W		49				
Sound pressure level *1	Cooling	dB (A)	46	47	49		
			47	47	50		
Heat exchanger type	Dimensions (H × W × D)		Main1: 23-1/8 × 34-11/16 × 11/16 (588 × 881 × 18.19) Main2: 23-1/8 × 33-1/2 × 11/16 (588 × 851 × 18.19)				
	Fin pitch	FPI	20				
	Rows × Stages		Main1: 1 × 28 Main2: 1 × 28				
	Pipe type		Copper				
	Fin type	Type (Material)	Aluminum				
		Surface treatment	PC fin				
Compressor	Type		DC rotary				
	Motor output	W	900	1,030			
Refrigerant	Type		R410A				
	Charge	lb oz	2 lb 14 oz	2 lb 16 oz			
		g	1,300	1,350			
Refrigerant oil	Type		RB68				
	Amount	in³ (cm³)	24.4 (400)				
Enclosure	Material		Steel sheet				
	Color		Beige Approximate color of Munsell 10YR 7.5/1.0				
(H × W × D)	Net	in (mm)	24-7/8 × 31-7/16 × 11-7/16 (632 × 799 × 290)				
	Gross		27-1/4 × 37 × 14-3/4 (692 × 940 × 375)				
Weight	Net	lb (kg)	86 (39)	88 (40)			
	Gross		95 (43)				
Connection pipe	Size	Liquid	in (mm)	Ø 1/4 (Ø 6.35)			
		Gas		Ø 3/8 (Ø 9.52)			
	Method			Flare			
	Pre-charge length		ft (m)	49 (15)			
	Max. length			66 (20)			
Max. height difference				49 (15)			
Operation range		°F (°C)	14 to 115 (-10 to 46)				
			-15 to 75 (-26 to 24)				

NOTES:

- Specifications are based on the following conditions:
 - Cooling: Indoor temperature of 80 °FDB (26.67 °CDB) / 67 °FWB (19.44 °CWB), and outdoor temperature of 95 °FDB (35 °CDB) / 75 °FWB (23.9 °CWB).
 - Heating: Indoor temperature of 70 °FDB (21.11 °CDB) / 59 °FWB (15 °CWB), and outdoor temperature of 47 °FDB (8.33 °CDB) / 43 °FWB (6.11 °CWB).
 - Pipe length: 24 ft 6 in (7.5 m), Height difference: 0 ft (0 m). (Between outdoor unit and indoor unit.)
 - Protective function might work when using it outside the operation range.
 - *1: Sound pressure level
 - Measured values in manufacturer's anechoic chamber.
 - Because of the surrounding sound environment, the sound levels measured in actual installation conditions might be higher than the specified values here.

2. Dimensions

2-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1



3. Installation space

3-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1

■ Space requirement

Provide sufficient installation space for product safety.

⚠ CAUTION


Keep the space shown in the installation examples.

If the installation is not performed accordingly, it could cause a short circuit and result in a lack of operating performance.


● Single outdoor unit installation

- When the upper space is open:


Obstacles at rear only




Obstacles at front



Obstacles at rear and sides




Obstacles at front and rear




- When an obstruction in the upper space:

Obstacles at rear and above



Obstacles at rear, sides, and above




● Multiple outdoor unit installation

- Provide at least 250 mm of space between the outdoor units if multiple units are installed.
 - When routing the piping from the side of an outdoor unit, provide space for piping.
 - No more than 3 units must be installed side by side.
- When 4 units or more are arranged in a line, provide the space as shown in the following example "**When an obstruction in the upper space:**".


- When the upper space is open:**

Unit: in (mm)


Obstacles at rear only



Obstacles at front only




Obstacles at front and rear



- When an obstruction in the upper space:**

Unit: in (mm)


Obstacles at rear and above.





● Outdoor units installation in multi-row

Unit: in (mm)

Single parallel unit arrangement




Multiple parallel unit arrangement

**NOTES:**

- If the space is larger than stated above, the condition will be the same as when there is no obstacle.
- When installing the outdoor unit, be sure to open the front and left side to obtain better operation efficiency.


⚠ CAUTION

- Do not install the outdoor unit in two-stage where the drain water could freeze. Otherwise the drainage from the upper unit may form ice and cause a malfunction of the lower unit.
- When the outdoor temperature is 32 °F (0 °C) or less, do not use the accessory drain pipe and drain cap. If the drain pipe and drain cap are used, the drain water in the pipe may freeze in extremely cold climate. (For reverse cycle model only.)
- In area with heavy snowfall, if the inlet and outlet of the outdoor unit is blocked with snow, it might become difficult to get warm, and it is likely to cause product malfunction. Construct a canopy and a pedestal, or place the unit on a high stand that is locally installed.



4. Refrigerant circuit

4-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1

OUTDOOR UNIT
AOUG09-15LZAH1OUTDOOR UNIT
AOUG09-15LZAH1

Thc : Thermistor (Compressor temperature)

ThD : Thermistor (Discharge temperature)

Tho : Thermistor (Outdoor temperature)


ThHo : Thermistor (Heat exchanger out temperature)

ThPI : Thermistor (Pipe temperature)


ThR : Thermistor (Room temperature)

5. Wiring diagrams

5-1. Models: AOUG09LZAH1, AOUG12LZAH1, and AOUG15LZAH1

OUTDOOR UNIT
AOUG09-15LZAH1OUTDOOR UNIT
AOUG09-15LZAH1

6. Capacity compensation rate for pipe length and height difference

OUTDOOR UNIT
AOUG09-15LZAH1OUTDOOR UNIT
AOUG09-15LZAH1

6-1. Models: AOUG09LZAH1 and AOUG12LZAH1

NOTE: Values mentioned in the table are calculated based on the maximum capacity.

COOLING		Pipe length						
		m	5	7.5	10	15	20	
Height difference H	Indoor unit is higher than outdoor unit *1	15	49	-	-	-	0.877	0.874
		10	33	-	-	0.956	0.891	0.888
		7.5	25	-	0.988	0.960	0.895	0.892
		5	16	1.017	0.992	0.964	0.899	0.895
	Indoor unit is lower than outdoor unit *2	0	0	1.025	1.000	0.971	0.906	0.902
		-5	-16	1.025	1.000	0.971	0.906	0.902
		-7.5	-25	-	1.000	0.971	0.906	0.902
		-10	-33	-	-	0.971	0.906	0.902
		-15	-49	-	-	-	0.906	0.902

HEATING		Pipe length						
		m	5	7.5	10	15	20	
Height difference H	Indoor unit is higher than outdoor unit *1	15	49	-	-	-	0.933	0.925
		10	33	-	-	0.981	0.933	0.925
		7.5	25	-	1.000	0.981	0.933	0.925
		5	16	1.017	1.000	0.981	0.933	0.925
	Indoor unit is lower than outdoor unit *2	0	0	1.017	1.000	0.981	0.933	0.925
		-5	-16	1.012	0.995	0.976	0.928	0.920
		-7.5	-25	-	0.993	0.974	0.926	0.918
		-10	-33	-	-	0.971	0.923	0.916
		-15	-49	-	-	-	0.914	0.906

6-2. Model: AOUG15LZAH1

NOTE: Values mentioned in the table are calculated based on the maximum capacity.

COOLING		Pipe length					
		m	5	7.5	10	15	20
Height difference H	Indoor unit is higher than outdoor unit *1	ft	16	25	33	49	66
		15	49	-	-	-	0.951
		10	33	-	-	0.979	0.967
		7.5	25	-	0.988	0.983	0.971
	Indoor unit is lower than outdoor unit *2	5	16	0.994	0.992	0.987	0.975
		0	0	1.002	1.000	0.995	0.983
		-5	-16	1.002	1.000	0.995	0.983
		-7.5	-25	-	1.000	0.995	0.983
		-10	-33	-	-	0.995	0.983
	-15	-49	-	-	-	0.983	0.982

HEATING		Pipe length					
		m	5	7.5	10	15	20
Height difference H	Indoor unit is higher than outdoor unit *1	ft	16	25	33	49	66
		15	49	-	-	-	0.994
		10	33	-	-	1.012	0.994
		7.5	25	-	1.000	1.012	0.994
	Indoor unit is lower than outdoor unit *2	5	16	0.969	1.000	1.012	0.994
		0	0	0.969	1.000	1.012	0.994
		-5	-16	0.964	0.995	1.007	0.989
		-7.5	-25	-	0.993	1.004	0.986
		-10	-33	-	-	1.002	0.984
	-15	-49	-	-	-	-	0.974
							0.959

7. Additional charge calculation

7-1. Models: AOUG09LZAH1 and AOUG12LZAH1

Refrigerant type	R410A		
Refrigerant amount	lb oz	2 lb 14 oz	
	g	1,300	

■ Refrigerant charge

Total pipe length	ft	49 or less	66 (Max.)	0.22 oz/ft (20 g/m)
	m	15 or less	20 (Max.)	
Additional charge	oz	0	3.5	
	g	0	100	

7-2. Model: AOUG15LZAH1

Refrigerant type	R410A		
Refrigerant amount	lb oz	2 lb 16 oz	1,350

■ Refrigerant charge

Total pipe length	ft	49 or less	66 (Max.)	0.22 oz/ft (20 g/m)
	m	15 or less	20 (Max.)	
Additional charge	oz	0	3.5	
	g	0	100	

8. Airflow

8-1. Model: AOUG09LZAH1

● Cooling

Airflow	
m ³ /h	1,850
l/s	514
CFM	1,089

● Heating

Airflow	
m ³ /h	1,850
l/s	514
CFM	1,089

8-2. Model: AOUG12LZAH1

● Cooling

Airflow	
m ³ /h	1,990
l/s	553
CFM	1,171

● Heating

Airflow	
m ³ /h	1,850
l/s	514
CFM	1,089

8-3. Model: AOUG15LZAH1

● Cooling

Airflow	
m ³ /h	2,070
l/s	575
CFM	1,218

● Heating


Airflow	
m ³ /h	2,290
l/s	636
CFM	1,348

9. Operation noise (sound pressure)


9-1. Noise level curve

■ Model: AOUG09LZAH1

● Cooling




● Heating




■ Model: AOUG12LZAH1

● Cooling




● Heating




■ Model: AOUG15LZAH1


● Cooling



● Heating



9-2. Sound level check point



NOTE: Detailed shape of the actual outdoor unit might be slightly different from the one illustrated above.

10. Electrical characteristics

Model name			AOUG09LZAH1	AOUG12LZAH1	AOUG15LZAH1
Power supply	Voltage Frequency	V Hz	208/230~ 60		
MCA *1		A	14.4		17.5
Starting current		A	3.3	4.7	5.2
Wiring spec. *2	MAX. CKT. BKR *3	A	15	14	14
	Power cable	AWG			
	Connection cable *4	Size Limited wiring length	AWG ft (m)	69 (21)	

*1: Minimum Circuit Ampacity (Calculation based on UL60335-2-40)

*2: Selected sample based on Japan Electrotechnical Standards and Codes Committee E0005. As the regulations of wire size and circuit breaker differ in each country or region, select appropriate devices complied to the regional standard.

*3: Maximum Circuit Breaker

*4: Limit voltage drop to less than 2%. If voltage drop is 2% or more, increase cable conductor size.

11. Safety devices

Type of protection	Protection form	Model		
		AOUG09LZAH1	AOUG12LZAH1	AOUG15LZAH1
Circuit protection	Current fuse (Main PCB)	250 V, 15 A		250 V, 20 A
		250 V, 5 A		
		250 V, 3.15 A		
Fan motor protection	Thermal protection program	Activate	257±18 °F (125±10 °C) Fan motor stop	
		Reset	248±18 °F (120±10 °C) Fan motor restart	
Compressor protection	Thermal protection program (Compressor temp.)	Activate	226 °F (108 °C) Compressor stop	
		Reset	After 3 minutes, and 176 °F (80 °C) or less Compressor restart	
	Thermal protection program (Discharge temp.)	Activate	230 °F (110 °C) Compressor stop	
		Reset	After 7 minutes Compressor restart	
	Thermal protection program (Outdoor temp.) (Only in COOL and DRY mode)	Activate	5 °F (-15 °C) Compressor stop	
		Reset	14 °F (-10 °C) Compressor restart	

12. Accessories

Part name	Exterior	Qty	Part name	Exterior	Qty
Installation manual		1	Cable tie		2