



Job Name _____

Address _____

Designer/Engineer _____

Wholesaler _____

Mechanical Contractor _____

Model / Quantity ☐ DTI 30 _____ ☐ DTI 40 _____
 ☐ DTI 55 _____ ☐ DTI 65 _____
 ☐ DTI 80 _____ ☐ DTI 119 _____
 ☐ DTI 80-Max _____ ☐ DTI 119-Max _____

Date _____

Features

- Stainless Steel construction, pickled & passivated
- High-capacity smooth wall Stainless Steel coil
- 2" of polystyrene foam insulation
- Top domestic water connections on DTI 40, DTI 55, DTI 65
- Side domestic water connections on DTI 30, DTI 80, DTI 119, DTI 80-Max, DTI 119-Max
- Side boiler connections on all models
- Removable inspection port for easy access to coil and tank
- Thermal well for aquastat or temperature sensor
- Standard Aquastat (USA only) & 10kΩ temperature sensor
- Lightweight for easy installation
- Maintenance free design

Certifications

- Compliant with CSA/ANSI Z21.10.3 • CSA 4.3
- Compliant with NSF/ANSI 372

Warranties

- 1 year limited parts warranty
- Lifetime limited tank and heating coil warranty for residential use
- 7 years limited tank and heating coil warranty for commercial use

Specifications

Specification	DTI 30	DTI 40	DTI 55	DTI 65
Diameter	20.1	21.8	21.8	23.8
Inches (cm)	(51.1)	(55.5)	(55.5)	(60.4)
Height	39.6	46.9	62.8	59.5
Inches (cm)	(100.6)	(119.2)	(159.4)	(151.0)
Gross DHW Volume USG	26.8	40.1	56.8	66.6
Net DHW Volume USG	25.7	38.9	55.1	64.9
Max. Operating Pressure PSI	150	150	150	150
Max. DHW Temperature °F (°C)	180 (82)	180 (82)	180 (82)	180 (82)
Weight	44	58	83	96
Pounds (kg)	(20)	(27)	(38)	(44)
Shipping Weight	51	66	92	105
Pounds (kg)	(23)	(30)	(42)	(48)
Domestic Connection Size Inches	¾	¾	¾	¾
Boiler Connection Size Inches	1	1	1	1
First Hour Delivery* Gallons / Hour	159	185	240	285
Continuous Draw* Gallons / Hour	137	154	193	230
Boiler Output Required* BTU / Hour	88,000	98,000	123,000	146,500
Heating Coil Flow Rate* GPM	8	8	8	13
Heating Coil Pressure Drop* Feet of Head	3.0	2.5	3.3	8.2
Heating Coil Surface Area Ft² (m²)	6.9 (0.64)	8 (0.74)	10.7 (0.99)	11.1 (1.03)
Certified – Water Heater	✓	✓	✓	✓
Certified – Low Lead	✓	✓	✓	✓


* Based on 180°F boiler supply, 135° DHW and 58°F entering cold water

Specification	DTI 80	DTI 119	DTI 80-Max	DTI 119-Max
Diameter	23.8	28.9	23.8	28.9
Inches (cm)	(60.4)	(73.4)	(60.4)	(73.4)
Height	69.9	65.8	69.9	65.8
Inches (cm)	(177.6)	(167.2)	(177.6)	(167.2)
Gross DHW Volume Gallons	80.2	115	80.2	115
Net DHW Volume USG	78.0	111.8	75.3	110
Max. Operating Pressure USG	150	150	150	150
Max. DHW Temperature °F (°C)	180 (82)	180 (82)	180 (82)	180 (82)
Weight	107	143	130	166
Pounds (kg)	(48)	(65)	(59)	(76)
Shipping Weight	118	155	141	178
Pounds (kg)	(53)	(71)	(64)	(81)
Domestic Connection Size Inches	1	1 ½	1 ½	1 ½
Boiler Connection Size Inches	1	1 ½	1 ½	1 ½
First Hour Delivery* Gallons / Hour	345	445	484	625
Continuous Draw* Gallons / Hour	279	350	428	537
Boiler Output Required* BTU / Hour	178,000	224,000	273,000	343,000
Heating Coil Flow Rate* GPM	13	15	13	25
Heating Coil Pressure Drop* Feet of Head	10.5	8.8	7.2	28.0
Heating Coil Surface Area Ft² (m²)	14.2 (1.32)	18.5 (1.72)	26.4 (2.45)	27.6 (2.56)
Certified – Water Heater	✓	✓	✓	✓
Certified – Low Lead	✓	✓	✓	✓

* Based on 180°F boiler supply, 135° DHW and 58°F entering cold water



Surface	Minimum Distance from Combustibles	Recommended Distance for Service
Front	1	24
Inches (cm)	(2.5)	(61)
Right, Left, and Rear	1	1
Inches (cm)	(2.5)	(2.5)
Top	1	1
Inches (cm)	(2.5)	(2.5)
Bottom	0	0
Inches (cm)	(0)	(0)

Dimensions




Dimension	DTI 30
A = Diameter	20.1
Inches (cm)	(51.1)
B = Height	39.6
Inches (cm)	(100.6)
C = DHW Outlet & Relief Valve	30.9
Inches (cm)	(78.5)
D = Sensor / Aquastat Well	22.4
Inches (cm)	(57.0)
E = Boiler Supply	22
Inches (cm)	(56.0)
F = Boiler Return	9.5
Inches (cm)	(24.0)
G = DHW Inlet	2.2
Inches (cm)	(5.5)

Legend	DTI 30
1	DHW Outlet (¾" M)
2	T & P Relief Valve (¾" F)
3	Sensor / Aquastat Well
4	Boiler Supply (1" M)
5	Boiler Return (1" M)
6	DHW Inlet (¾" M)



Dimension	DTI 40	DTI 55	DTI 65
A = Diameter Inches (cm)	21.8 (55.5)	21.8 (55.5)	23.8 (60.4)
B = DHW Inlet & Outlet Center to Center Inches (cm)	10.1 (25.6)	10.1 (25.6)	10.1 (25.6)
C = Height Inches (cm)	46.9 (119.2)	62.8 (159.4)	59.5 (151.0)
D = Relief Valve Inches (cm)	37 (93.9)	52.8 (134.1)	50.1 (127.2)
E = Boiler Supply & Sensor / Aquastat Well Inches (cm)	23.6 (59.9)	27.7 (70.4)	26.1 (66.2)
F = Boiler Return & Drain Inches (cm)	10.2 (25.9)	10.2 (25.9)	9.9 (25.2)

Legend	DTI 40, DTI 55, DTI 65
1	DHW Outlet (¾" M)
2	DHW Inlet (¾" M)
3	T & P Relief Valve (¾" F)
4	Boiler Supply (1" M)
5	Sensor / Aquastat Well
6	Boiler Return (1" M)
7	DHW Drain (½" F)



Dimension	DTI 80	DTI 119	DTI 80-Max	DTI 119-Max
A = Diameter	23.8	28.9	23.8	28.9
Inches (cm)	(60.4)	(73.4)	(60.4)	(73.4)
B = Height	69.9	65.8	69.9	65.8
Inches (cm)	(177.6)	(167.2)	(177.6)	(167.2)
C = DHW Outlet & Relief Valve	60.5	52.8	60.1	52.8
Inches (cm)	(153.7)	(134.2)	(152.7)	(134.2)
D = Boiler Supply	30.0	31.7	52.8	42.5
Inches (cm)	(76.2)	(80.5)	(134.2)	(107.9)
E = Sensor / Aquastat Well	30.0	31.7	26.3	34.0
Inches (cm)	(76.2)	(80.5)	(66.7)	(86.2)
F = DHW Inlet	12.1	13.3	12.3	13.9
Inches (cm)	(30.7)	(33.7)	(31.2)	(35.2)
G = Boiler Return & Drain	9.9	11.5	9.9	11.5
Inches (cm)	(25.2)	(29.2)	(25.2)	(29.2)

Legend	DTI 80	DTI 119, DTI 80-Max, DTI 119-Max
1	T & P Relief Valve (¾" F)	T & P Relief Valve (1" F)
2	DHW Outlet (1" M)	DHW Outlet (1½" M)
3	Boiler Supply (1" M)	Boiler Supply (1½" M)
4	Sensor / Aquastat Well	Sensor / Aquastat Well
5	Boiler Return (1" M)	Boiler Return (1½" M)
6	DHW Drain (½" F)	DHW Drain (½" F)
7	DHW Inlet (1" M)	DHW Inlet (1½" M)