


CON  
PF



## OPEN CIRCUIT COOLING TOWER DETAIL

SCALE: NONE

### NOTES:

1. PROVIDE HEAT TRACE & INSULATION PIPING AS INDICATED.
2. STRUCTURAL SUPPORT FURNISHED AND INSTALLED BY MECHANICAL CONTRACTOR.
3. PROVIDE ELECTRIC MAKE-UP VALVE COMPLETE WITH LEVEL PROBE.
4. REFER TO FLOOR PLANS FOR ROUTING OF PIPING TO MECH RM.