NorthWoods Software



Program Name: Prop-W_BUu

Project Number: -

Project Description: -

Project Designer: Dik

Last Revised (yy-mm-dd): 21.11.26

Reference: NBCC, CSA S16

Disclaimer:
Created using SMath Studio, a MathCAD workalike from https://en.smath.info/view/SMathStudio. The User is responsible to verify data and calculations using an alternative method

Menu:

..... Input Data	..... Important Output	..... Logical Constructs	Blue Units
..... Sum / For	Red Important Note	Gray Temporary Variables	

Input Data

$desI_W := "Custom"$	$desI_W = "Custom"$		Designation Imperial
$desM_W := "Custom"$	$desM_W = "Custom"$		Designation Metric
$d_W := 15.1\ in$	$d_W = 15.10\ in$	$d_W = 383.5\ mm$	W Depth
$w_W := 1.25\ in$	$w_W = 1.25\ in$	$w_W = 31.8\ mm$	W Web Thickness
$b_{1W} := 12.9\ in$	$b_{1W} = 12.9\ in$	$b_{1W} = 327.7\ mm$	W Bottom Flange Width
$t_{1W} := 2.07\ in$	$t_{1W} = 2.07\ in$	$t_{1W} = 52.6\ mm$	W Bottom Flange Thickness
$b_{2W} := 12.9\ in$	$b_{2W} = 12.9\ in$	$b_{2W} = 327.7\ mm$	W Top Flange Width
$t_{2W} := 2.07\ in$	$t_{2W} = 2.07\ in$	$t_{2W} = 52.6\ mm$	W Top Flange Thickness



c b a

Section Properties:

$A_W := b_{1W} \cdot t_{1W} + b_{2W} \cdot t_{2W} + \left(d_W - t_{1W} - t_{2W}\right) \cdot w_W$

$A_W = 67.11\ \text{in}^2$ $A_W = 43294\ \text{mm}^2$ Area

$wt_W := A_W \cdot \gamma_s$ $wt_W = 227.88\ \text{plf}$ $wt_W = 3.33\ \text{kNpm}$ Weight per Unit Length

$$y_{Wb} := \frac{t_{1W} \cdot b_{1W} \cdot \frac{t_{1W}}{2} + t_{2W} \cdot b_{2W} \cdot \left(d_W - \frac{t_{2W}}{2}\right) + + w_W \cdot \left(d_W - t_{1W} - t_{2W}\right) \cdot \left(\frac{\left(d_W - t_{1W} - t_{2W}\right)}{2} + t_{1W}\right)}{A_W}$$

$y_{Wb} = 7.55\ \text{in}$ $y_{Wb} = 191.8\ \text{mm}$ Depth to Bottom Fibre (X-Axis)

$y_{Wt} := d_W - y_{Wb}$ $y_{Wt} = 7.55\ \text{in}$ $y_{Wt} = 191.8\ \text{mm}$ Depth to Top Fibre (X-Axis)

$x_W := 0.5 \cdot \max\left(\left[\begin{array}{ccc} b_{1W} & b_{2W} & w_W \end{array}\right]\right)$ $x_W = 6.45\ \text{in}$ $x_W = 163.8\ \text{mm}$ Depth to Outer Fibre (Y-Axis)

$$Ix_{W1} := \frac{1}{12} \cdot \left(b_{1W} \cdot t_{1W}^{\ 3} + b_{2W} \cdot t_{2W}^{\ 3} + w_W \cdot \left(d_W - t_{2W} - t_{1W}\right)^3\right)$$

$$Ix_{W2} := Ix_{W1} + b_{1W} \cdot t_{1W} \cdot \left(y_{Wb} - \frac{t_{1W}}{2}\right)^2 + b_{2W} \cdot t_{2W} \cdot \left(y_{Wt} - \frac{t_{2W}}{2}\right)^2$$

$$Ix_W := Ix_{W2} + w_W \cdot \left(d_W - t_{1W} - t_{2W}\right) \cdot \left(y_{Wb} - \left(\frac{d_W - t_{1W} - t_{2W}}{2} + t_{1W}\right)\right)^2$$

$Ix_W = 2423.04\ \text{in}^4$ $Ix_W = 1.01 \cdot 10^9\ \text{mm}^4$ Moment of Inertia (X-Axis)

$$Iy_W := \frac{1}{12} \cdot \left(t_{1W} \cdot b_{1W}^{\ 3} + t_{2W} \cdot b_{2W}^{\ 3} + \left(d_W - t_{1W} - t_{2W}\right) \cdot w_W^{\ 3}\right)$$

$Iy_W = 742.39\ \text{in}^4$ $Iy_W = 3.09 \cdot 10^8\ \text{mm}^4$ Moment of Inertia (Y-Axis)

$Ip_W := Ix_W + Iy_W$ $Ip_W = 3165.43\ \text{in}^4$ $Ip_W = 1.32 \cdot 10^9\ \text{mm}^4$ Moment of Inertia (Polar)

$Sx_t := \frac{Ix_W}{y_{Wt}}$ $Sx_t = 320.93\ \text{in}^3$ $Sx_t = 5.26 \cdot 10^6\ \text{mm}^3$ Section Modulus (Top, X-Axis)

$Sx_b := \frac{Ix_W}{y_{Wb}}$ $Sx_b = 320.93\ \text{in}^3$ $Sx_b = 5.26 \cdot 10^6\ \text{mm}^3$ Section Modulus (Bottom, X-Axis)

$rx_W := \sqrt{\frac{Ix_W}{A_W}}$ $rx_W = 6.01\ \text{in}$ $rx_W = 152.6\ \text{mm}$ Radius of Gyration (X-Axis)

$ry_W := \sqrt{\frac{Iy_W}{A_W}}$ $ry_W = 3.33\ \text{in}$ $ry_W = 84.5\ \text{mm}$ Radius of Gyration (Y-Axis)

$Sy_W := \frac{Iy_W}{x_W}$ $Sy_W = 115.10\ \text{in}^3$ $Sy_W = 1.89 \cdot 10^6\ \text{mm}^3$ Section Modulus (X-Axis)

$$Zx_{W1} := b_{2W} \cdot t_{2W} \cdot \left(y_{Wt} - \frac{t_{2W}}{2}\right) + b_{1W} \cdot t_{1W} \cdot \left(y_{Wb} - \frac{t_{1W}}{2}\right)$$

$Zx_{W1} = 347.94\ \text{in}^3$ $Zx_{W1} = 5.70 \cdot 10^6\ \text{mm}^3$

$$Zx_W := Zx_{W1} + w_W \cdot \frac{\left(y_{Wt} - t_{2W}\right)^2}{4} + w_W \cdot \frac{\left(y_{Wb} - t_{1W}\right)^2}{4}$$

$Zx_W = 366.71\ \text{in}^3$ $Zx_W = 6.01 \cdot 10^6\ \text{mm}^3$ Plastic Section (X-Axis)

$$Zy_W := t_{1W} \cdot \frac{b_{1W}^2}{4} + t_{2W} \cdot \frac{b_{2W}^2}{4} + \left(d_W - t_{1W} - t_{2W}\right) \cdot \frac{w_W^2}{4}$$

$Zy_W = 176.52\ \text{in}^3$ $Zy_W = 2.89 \cdot 10^6\ \text{mm}^3$ Plastic Section (X-Axis)

$$Cw_W := \frac{\left(d_W - \left(\frac{t_{1W} + t_{2W}}{2}\right)\right)^2 \cdot \left(\frac{b_{1W} + + b_{2W}}{2}\right)^3 \cdot \left(\frac{t_{1W} + t_{2W}}{2}\right)}{24}$$

Approx (Average Properties)

$Cw_W = 31435.26\ \text{in}^6$ $Cw_W = 8.44 \cdot 10^{12}\ \text{mm}^6$ Warping Constant

$$J_W := \frac{b_{1W} \cdot t_{1W}^3}{3} + \frac{b_{2W} \cdot t_{2W}^3}{3} + \frac{\left(d_W - t_{1W} - t_{2W}\right) \cdot w_W^3}{3}$$

$J_W = 83.42\ \text{in}^4$ $J_W = 3 \cdot 10^7\ \text{mm}^4$ Torsional Constant

Class of Section

$$bt_1 := \frac{145}{\sqrt{\frac{f_{y1}}{\text{MPa}}}}$$ $bt_1 = 8.325$ b/t Ratio Class 1

$$bt_2 := \frac{170}{\sqrt{\frac{f_{y1}}{\text{MPa}}}}$$ $bt_2 = 9.7603$ b/t Ratio Class 2

$$bt_3 := \frac{200}{\sqrt{\frac{f_{y1}}{\text{MPa}}}}$$ $bt_3 = 11.4827$ b/t Ratio Class 3

$$dw_1 := \frac{1600}{\sqrt{\frac{f_{y1}}{\text{MPa}}}}$$ $dw_1 = 91.8616$ d/w Ratio Class 1

$$dw_2 := \frac{1700}{\sqrt{\frac{f_{y1}}{\text{MPa}}}}$$ $dw_2 = 97.603$ d/w Ratio Class 2

$$dw_3 := \frac{1900}{\sqrt{\frac{f_{y1}}{\text{MPa}}}}$$ $dw_3 = 109.0857$ d/w Ratio Class 3

```
if (max([b_1W/(2·t_1W)  b_2W/(2·t_2W)]) ≤ bt_1) ∧ (d_W/w_W ≤ dw_1)
  Class := 1
else
  if (max([b_1W/(2·t_1W)  b_2W/(2·t_2W)]) ∧ (d_W/w_W ≤ dw_2))
    Class := 2
  else
    if max([b_1W/(2·t_1W)  b_2W/(2·t_2W)]) ∧ (d_W/w_W ≤ dw_3)
      Class := 3
    else
      Class := 4
```

$Class = 1$

```
if (Class = 1) ∨ (Class = 2)
  M_r := φ_s · Zx_W · f_y1
else
  M_r := φ_s · Sx_W · f_y1
```

$M_r = 1210.14\ \text{K\_ft}$ $M_r = 1640.73\ \text{kN\_m}$ Moment Resistance



Summary:

$\varphi_s = 0.90$

$f_{y1} = 44.00$ Ksi

Section Properties

Designation	$desI_W =$ "Custom"	$desM_W =$ "Custom"
W Depth	$d_W = 15.10$ in	$d_W = 383.5$ mm
W Web Thickness	$w_W = 1.25$ in	$w_W = 31.8$ mm
W Bottom Flange Width	$b_{1W} = 12.9$ in	$b_{1W} = 327.7$ mm
W Bottom Flange Thickness	$t_{1W} = 2.07$ in	$t_{1W} = 52.6$ mm
W Top Flange Width	$b_{2W} = 12.9$ in	$b_{2W} = 327.7$ mm
W Top Flange Thickness	$t_{2W} = 2.07$ in	$t_{2W} = 52.6$ mm
Area	$A_W = 67.11$ in^2	$A_W = 43294$ mm^2
Weight per Unit Length	$wt_W = 227.88$ plf	$wt_W = 3.33$ kNpm
Moment of Inertia (X-Axis)	$Ix_W = 2423.04$ in^4	$Ix_W = 1.01 \cdot 10^9$ mm^4
Section Modulus (X-Axis)	$Sx_t = 320.93$ in^3	$Sx_t = 5.26 \cdot 10^6$ mm^3
Radius of Gyration (X-Axis)	$rx_W = 6.01$ in	$rx_W = 152.6$ mm
Plastic Section (X-Axis)	$Zx_W = 366.71$ in^3	$Zx_W = 6.01 \cdot 10^6$ mm^3
Moment of Inertia (Y-Axis)	$Iy_W = 742.39$ in^4	$Iy_W = 3.09 \cdot 10^8$ mm^4
Section Modulus (Y-Axis)	$Sy_W = 115.10$ in^3	$Sy_W = 1.89 \cdot 10^6$ mm^3
Radius of Gyration (Y-Axis)	$ry_W = 3.33$ in	$ry_W = 84.5$ mm
Plastic Section (Y-Axis)	$Zy_W = 176.52$ in^3	$Zy_W = 2.89 \cdot 10^6$ mm^3
Moment of Inertia (Polar)	$Ip_W = 3165.43$ in^4	$Ip_W = 1.32 \cdot 10^9$ mm^4
Warping Constant	$Cw_W = 31435.26$ in^6	$Cw_W = 8.44 \cdot 10^{12}$ mm^6
Torsional Constant	$J_W = 83.42$ in^4	$J_W = 3 \cdot 10^7$ mm^4
Class of Section	$Class = 1$	
Moment Resistance	$M_r = 1210.14$ K_ft	$M_r = 1640.73$ kN_m