



DG TYPE EXAMINATION CERTIFICATE

No.
DG-1936

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the schedule attached hereto.

Applicant	Neoperl Nordic A/S
Address	Erhvervsparken 1, Bjerregrav, DK-8900 Randers
Manufacturer	Witzenmann GmbH
Address	Östliche Karl-Friedrich Strasse 134, D-75175 Pforzheim, Germany
Type of Appliance	Flexible Metal Hose
Trade Mark	Hydra
Type/Model	GA921, GA621, GA421
Specified Standards	DIN 3382, part 2, DIN 3383, part 1

The attached (*schedule of approval*) forms part of this certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.

Date of issue 2008-01-08 Issued by Danish Institute of Fire and Security Technology
Notified Body No. 0845

Signed

Name

Ken Olesen

Note:

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.



-XXXX

Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

This certificate is issued under the authority of the Danish Safety Technology Authority.



(Annex)

Description of Type Approval

Product Description

Trade Marks Hydra
Type/Model GA921, GA621, GA421

Technical Data

Category: III
Maximum operation pressure: 100 mbar
Diameter: ½"
Length: 300 mm, 400 mm
Materials: Rubber, steel and PVC cover
Connections: According to the requirements in Gasreglementet, part A

Comments

Type Approval Documentation

Test report : -
Drawings: No. 1092870, dated 2000.02.07
No. 1092869, dated 2000.02.07
No. 1272163, dated 2006.06.23
Approval certificate No. : 87.01e156, dated 1992.10.28 from DVGW
NG-4605AU0478, dated 1999.12.21 from DVGW
Others: -

End of Certificate