



DG TYPE EXAMINATION CERTIFICATE

No.
DG-2099

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the schedule attached hereto.

| | |
|---------------------|---|
| Applicant | Neoperl Nordic A/S |
| Address | Erhvervsparken 1, Bjerregrav, DK-8900 Randers |
| Manufacturer | Witzenmann GmbH |
| Address | Östliche Karl-Friedrich Strasse 134, D-75175 Pforzheim, Germany |
| Type of Appliance | Flexible Metal Hose |
| Trade Mark | Hydra |
| Type/Model | GA911, GA641, GA451 |
| Specified Standards | DIN 3381, part 2, DIN 3383, part 1+2 |

The attached (*schedule of approval*) forms part of this certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.

Date of issue 2006-06-07 Issued by Danish Institute of Fire and Security Technology
Notified Body No. 0845

Signed

Name

Ken Olesen

Note:

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.



Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

This certificate is issued under the authority of the Danish Safety Technology Authority.



(Annex)

Description of Type Approval

Product Description

Trade Marks Hydra
Type/Model GA911, GA641, GA451

Technical Data

Category: III
Maximum operation pressure: 100 mbar
Diameter: ½"
Length: Max. 1250 mm
Materials: Steel and PVC cover
Connections: According to the requirements in Gasreglementet, part A

Comments

Type Approval Documentation

Test report : -

Drawings: No. 1092873, dated 2000.02.07
No. 1092872, dated 2000.02.01
No. 1270727, dated 2006.05.02

Approval certificate No. : 87.02e156, dated 1992.10.28 from DVGW
95-110-6, dated 1997.02.14 from SVGW

Others: -

End of Certificate