

Testing tools COMBI CHECK

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com



The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LED-Display
- acc. to VDE standard
- high peak voltage strength
- the right tester for every application

General ordering data

Type	COMBI CHECK
Order No.	9918860000
Version	2-pole voltage tester type 1156, Yes - visual + acoustic
GTIN (EAN)	4032248405749
Qty.	1 pc(s).

Testing tools COMBI CHECK

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com

Technical data

Dimensions and weights

Width	264 mm	Width (inches)	10.394 inch
Height	33 mm	Height (inches)	1.299 inch
Depth	67 mm	Depth (inches)	2.638 inch
Weight	290 g	Net weight	356 g

Measuring and testing devices

AC voltage display	6, 12, 24, 50, 120, 230, 400, 690 V	AC voltage measuring range	6-690 V
Accessories description	Screw-on, thicker test probes	Battery type	1.5 V type AAA battery
Continuity test	Yes - visual + acoustic	DC voltage display	6, 12, 24, 50, 120, 230, 400, 690 V
Display	LED	Frequency range, max.	400 Hz
Frequency range, min.	16 Hz	Insulation test	8 kV
Measuring range category	CAT IV – 600V/ CAT III – 690V	Operating temperature, max.	55 °C
Operating temperature, min.	-15 °C	Peak voltage resistance	8 kV
Protection degree	IP65	RCD circuit breaker	The selectable load enables conscious triggering of a 30 mA RCD circuit breaker
Rated voltage, max.	690 V AC/DC	Rated voltage, min.	6 V
Tested and approved according to	IEC 61243-3:2014 (DIN EN 61243-3:2015-08)		

Classifications

ETIM 3.0	EC000494	ETIM 4.0	EC000494
ETIM 5.0	EC000494	ETIM 6.0	EC000494
UNSPSC	41-11-36-37	eClass 5.1	27-20-03-08
eClass 6.2	27-20-03-08	eClass 7.1	27-20-03-08
eClass 8.1	27-20-03-08	eClass 9.0	27-20-03-08
eClass 9.1	27-20-03-08		

Product information

Descriptive text technical data	Buzzer included
---------------------------------	-----------------

Approvals

Approvals



ROHS	Conform
------	---------

Downloads

Approval/Certificate/Document of Conformity	9918860000_DECLARATION_OF_CONFORMITY.pdf
Brochure/Catalogue	CAT 6 TOOLS 15/16 EN
Product Change Notification	PCN-PW641110-20180410-00-A EN PCN-PW641110-20180410-00-A DE
User Documentation	BANL_manual 2pol Tester

Creation date May 23, 2018 1:04:55 PM CEST