



## Product certificate K109854/03

Issued 2022-12-15

Replaces K109854/02

Page 1 of 2

### Water softening by ion exchange

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

### Harvey Water Softeners Ltd.

As specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with

Kiwa evaluation guideline

**BRL-K14022** "Equipment for conditioning drinking water and/or hot tap water" dated 2018-01-12.

which embodies

**EN 14743 + A1:** "Water conditioning equipment inside buildings – Softeners – Requirements for performance, safety and testing"

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

# CERTIFICATE

286180711

#### Kiwa Nederland B.V.

Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
[NL.Kiwa.info@Kiwa.com](mailto:NL.Kiwa.info@Kiwa.com)  
[www.kiwa.nl](http://www.kiwa.nl)

#### Company

Harvey Water Softeners Ltd.  
Hiple Street – Old Woking  
9U22 9LQ Woking  
United Kingdom  
Tel. 44 1483753400  
[www.harveywatersofteners.co.uk](http://www.harveywatersofteners.co.uk)  
[info.harveywatersofteners.co.uk](mailto:info.harveywatersofteners.co.uk)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Water Softening by ion exchange

---

### PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

#### H20B

- Minimax
- Dualflo
- Aquacell

#### H20C

- Minimax
- Arc
- Aquacell

### Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette)

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down for confidentiality reasons in the undisclosed 'appendix hygienic aspects' to this certificate.

### MARKING

The Kiwa®-mark products are marked with the word mark "KIWA" 

Place of the mark: On the water softener bulkhead

Compulsory specifications:

- Name of the manufacturer or supplier or Trademark
- Type description;
- Serial number or manufacturing date;
- Class of pressure (PN);
- Working temperature range;
- Initiation and operation for full regeneration in the event the softener was out of service over a period longer than 96 hours

Method of marking:

- Non-erasable;
- visible after assembly.

### APPLICATION AND USE

The products are intended to be used in drinking water and hot tap water installations with a maximum working pressure of 1 MPa (10 Bar)

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Harvey Water Softeners Ltd.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.