



5675Z Oras Clinica Safety Bruserarmatur, 6 V, Bluetooth




EAN: 6414150098666

VVS: 704287004

static.oras.com/5675Z



- Health & Care
- Berøringsfri, Termostatisk, Batteridrevet, Bluetooth®
- Vægmonteret
- Forkromet
- Armaturhuset leder minimal varme
- Termostatisk temperaturregulering, Kontraventil(er), Smudsfilter
- Autofocus infrarød sensor, Impulsstyret magnetventil, Indikator for lavt batteriniveau
- Direkte tilslutning
- DZR messing, Vandveje uden nikkel, Termisk desinfektion, Justerbare software indstillinger (med bluetooth)





Tekniske data

Flow attributter

Vandmængde ved 300 kPa0.2 l/s

Tekniske egenskaber

Varmtvandsforsyningmax. +70°C
Arbejdstryk100 - 1000 kPa
TilslutningsstørrelseG3/4
Installationsbredde150 ± 3 mm
Forebyggelse af tilbageløb (EN1717)EB
Materialebrass

Software indstillinger

Efterløbetid5 s (1-20 s)
Automatisk skylningoff (off/1-120 h)
Automatisk skylleperiode30 s (1-1800 s)
Max. løbetid5 min (1 - 1800 s)

Elektroniske attributter


BatteriLithium 2CR5 6 V
Bluetooth version4.x (D034445)

Bestemmelser


EU DirektivC € Radio Equipment Directive 2014/53/EU , Low Voltage Directive 2014/35/EU , EMC Directive 2014/30/EU , RoHS Directive 2011/65/EU
EN standardEN 1111 , EN 15091, ETSI EN 301 489-1 V1.9.2 , ETSI EN 300 328 v2.2.2 , EN 61000-6-1:2007 , EN 61000-6-3:2007+A1:2011+AC:2012 , EN 60335-1:2012+A11+A13+A14+A15:2021, Part 19.11.4
StøjklasseI (ISO 3822)
Støjklasse 0.2 l/sI (ISO 3822)
BeskyttelsesklasseIP 55

Godkendelser og Erklæringer

UN38.3UN38-3 Maxell 2CR5
Declaration of conformityRED
EPDS-P-06397



Reservedele



SP5670U

	Navn	Kode	WS
01	Batteriboks	199438V	704283503
02	Sensor holder Forkromet	1006102V	704287991
03	Opdaterings kit	1017251V	
04	Membran til magnetventil	1006500V	704283670
05	Kombinere	602438/2	745131488
06	Filter pakning, G3/4, DN20	178375V	704283759
07	Dækkappe Forkromet	1006473V	745142464
08	Termostatdel	178780V	745131812
09	Temperaturreguleringsgreb Forkromet	1006058V	745142364