



NATIONAL TYPE EVALUATION PROGRAM

*Certificate of Conformance*  
*for Weighing and Measuring Devices*

**For:**

Load Cell  
Beam, Single Point Load Cell  
Model: PC5H  
 $n_{max}$ : 3000, Class III, Single Cell  
Capacity: 2000 kg  
Accuracy Class: III

**Submitted By:**

Flintec UK Ltd.  
W4/5 Capital Point, Capital Business Park, Wentloog Avenue  
Cardiff, South Wales CF3 2PW  
The United Kingdom  
Tel: +44 (0)2920 797959  
Fax: +44 (0)2920 797939  
Contact: John Haberfield  
Email: [john.h@flintec.com](mailto:john.h@flintec.com)  
Web site: [www.flintec.com](http://www.flintec.com)

**Standard Features and Options**

- Model PC5H, specific load cell capacities and  $v_{min}$  values covered by this Certificate are listed in the table below.
- Nominal output: 2.0 mV/V
- Stainless Steel material
- 6 wire design
- Minimum Dead Load: 0 kg

Models	Capacity	$V_{min}$ Class III Single cell
PC5H *Load cell tested	2000 kg*	0.154 kg

Temperature Range: -10 °C to 40 °C (14 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.

Jerry Buendel  
Chairman, NCWM, Inc.

Ronald Hayes  
Chairman, National Type Evaluation Program Committee  
Issued: August 21, 2015

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



## Flintec UK Ltd.

Load Cell / PC5H

**Application:** The load cells may be used in Class III scales for single and multiple cell applications consistent with the model designations, number of scale divisions, and parameters specified in this certificate. Load cells of a given accuracy class may be used in applications with lower accuracy class requirements provided the number of scale divisions, the  $v_{\min}$  value, and temperature range are suitable for the application. The manufacturer may market the load cell with fewer divisions ( $n_{\max}$ ) and with greater  $v_{\min}$  values than those listed on the certificate. However, the load cells must be marked with the appropriate  $n_{\max}$  and  $v_{\min}$  for which the load cell may be used.

**Identification:** A pressure sensitive identification label located on the cell, states manufacturer name, model, serial number, rated capacity, class and NTEP certificate number. Other pertinent information will be specified on the Calibration Certificate accompanying the cell.

**Test Conditions:** Model PC5H, 2000 kg capacity load cell was tested by the NMi Certain B.V. at The Netherlands facility. Testing was conducted in accordance with the OIML DoMC Mutual Acceptance Arrangement, signed by the NCWM as a utilizing participant for load cell testing. Testing was conducted using deadweights as the reference standard. The load cell was tested over a temperature range of -10 °C to 40 °C with tests run on each cell at each temperature. The temperature effect on zero was measured and a time dependence (creep) test was performed. The barometric pressure test to determine sensitivity of the load cell design to changes in barometric pressure was conducted. The data were analyzed for single load cell applications. OIML R60 selection criteria were used to determine cells tested.

**Evaluated By:** E. van der Grinten, M.M.J. Meijer (NMi)

**Type Evaluation Criteria Used:** NIST, Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices, 2015. NCWM, Publication 14: Weighing Devices, 2015.

**Conclusion:** The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

**Information Reviewed By:** J. Truex (NCWM)

### **Examples of Device:**

