

Emission Test Certificate

Wednesday 16th October 2019

Supplier: Godfrey Hirst Australia (7 Factories Road, Geelong, VIC 3220, Australia)

Sample Description: Moduleo 2.5mm Vinyl Plank 1320 x 196 x 2.5mm

Date Tested: October 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours):

Global GreenTag	Moduleo 2.5mm Vinyl Plank 1320 x 196 x 2.5mm
Total Volatile Organic Compound Emission Rate Limit: <math><0.500 \text{ mg/m}^2/\text{hr}</math>	Total Volatile Organic Compound Emission Rate: 0.015 mg/m ² /hr
4-phenylcyclohexene Emission Rate Limit: <math><0.05 \text{ mg/m}^2/\text{hr}</math>	4-phenylcyclohexene Emission Rate: <math><0.003 \text{ mg/m}^2/\text{hr}</math>
Formaldehyde Emission Rate Limit: <math><0.1 \text{ mg/m}^2/\text{hr}</math>	Formaldehyde Emission Rate: 0.011 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Luke Morley
BSc(Tech)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V1910007