

Emission Test Certificate

Monday 23rd August 2021

Supplier: Godfrey Hirst Australia (7 Factories Road, Geelong, VIC 3220, Australia)

Sample Description: KLVP 2.5mm/0.5mm Wear Layer

Date Tested: August 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data (24 hours):

Global Green Tag	KLVP 2.5mm/0.5mm Wear Layer
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.009 mg/m ² /hr
4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m ² /hr	4-phenylcyclohexene Emission Rate: <0.003 mg/m ² /hr
Formaldehyde Emission Rate Limit: <0.1 mg/m ² /hr	Formaldehyde Emission Rate: <0.004 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Luke Morley
BSc (Tech)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

V2108017