

Certificate

C10/11 revision June 4, 2012

Manufacturer declaration and Type testing of compliance with the regulations of Belgium on connection of photovoltaic installations to the low voltage network.

Type reference number	Zeverlution 2000S Zeverlution 1500S Zeverlution 1000S		
Type	Photovoltaic Inverter		
Manufacturer:	Jiangsu Zeversolar New Energy CO., LTD.		
Address	No. 198 Xiangyang Road, Suzhou, 215011 China		
Tel	+86 512 6937 0998	Fax	+86 512 6937 0630
E:mail	service.china@zeversolar.com	Web site	www.zeversolar.com

Test house details:	Jiangsu Zeversolar New Energy CO., LTD. R&D Department, Suzhou
---------------------	---


Type reference	Nominal AC power	Max.AC power
Zeverlution 2000S	2.0kW	2.2kW
Zeverlution 1500S	1.5kW	1.65kW
Zeverlution 1000S	1.0kW	1.1kW

Jiangsu Zeversolar New Energy CO., LTD hereby declares that the inverter listed above meet the regulations of the Belgium on connection of photovoltaic installations to the low voltage network.

The inverters conforming to the regulations of the Belgium are characterized, along with the specification in the datasheet and the CE declaration, by the following features:

- There is a certificate of VDE 0126-1-1/A1:2012 issued by an accredited institute. The certificate can be downloaded from the website <http://www.zeversolar.com/>.
- The automatic disconnection devices integrated within the inverters meet the requirements of DIN VDE 0126-1-1/A1:2012 with the deviation of C10/11, as required in Annex 4 of C10/11..
- These parameters can't be changed by user, an installer or by any person other than Zeversolar (password protected).

The results of VDE 0126-1-1/A1:2012 and the deviation of C10/11 tests for 2000S are summarized in this certificate. Complete documentation on test details is available at Zeversolar on demand.
The model 1000S and 1500S is same as 2000S on hardware except that the output power and the size of the heat sink.

Name of signatory and title	Sandy Gong Manager of Safety Dept	Date and Place	18.03.2016 Suzhou
Signed		On behalf of	Jiangsu Zeversolar New Energy CO., LTD.

POWER QUALITY

Harmonic current emissions as per EN 61000-3-2			
Harmonic	Test Value in Amps	% of fund	Limit in Amps
2	0.014	0.16	1.080
3	0.099	1.14	2.300
4	0.009	0.10	0.430
5	0.040	0.46	1.140
6	0.015	0.17	0.300
7	0.006	0.07	0.770
8	0.010	0.11	0.230
9	0.016	0.19	0.400
10	0.006	0.07	0.184
11	0.005	0.06	0.330
12	0.004	0.05	0.153
13	0.020	0.23	0.210
14	0.004	0.04	0.131
15	0.004	0.05	0.150
16	0.006	0.07	0.115
17	0.019	0.22	0.132
18	0.009	0.10	0.102
19	0.006	0.07	0.118
20	0.012	0.13	0.092
21	0.012	0.14	0.107
22	0.016	0.18	0.084
23	0.009	0.11	0.098
24	0.018	0.21	0.077
25	0.007	0.08	0.090
26	0.021	0.24	0.071
27	0.008	0.10	0.083
28	0.021	0.25	0.066
29	0.008	0.09	0.078
30	0.022	0.25	0.061
31	0.015	0.17	0.073
32	0.018	0.20	0.058
33	0.010	0.12	0.068
34	0.011	0.13	0.054
35	0.016	0.18	0.064
36	0.003	0.03	0.051
37	0.005	0.06	0.061
38	0.009	0.10	0.048
39	0.010	0.11	0.058
40	0.015	0.17	0.046
THDI	NA	1.57	5%

Voltage Fluctuations and Flicker as per EN 61000-3-3

	Starting			Stopping			Running	
	dmax	dc	d(t)	dmax	dc	d(t)	Pst	Plt 2 hours
Measured Values	2.00%	0.00%	2.00%	1.97%	0.00%	1.97%	0.126	0.123
Limits set under EN 61000-3-3	4%	3.3%	3.3% 500ms	4%	3.3%	3.3% 500ms	1.0	0.65
Test start date	09/06/2015			Test end date			09/06/2015	
Test location	Audix Technology (Wujiang) Co., Ltd. EMC Dept							

Power factor *

Test Voltage level	210 V	230 V	253 V
Measured value at 100%Pn	0.995	0.998	0.998
Limit	>0.95	>0.95	>0.95

* Measured at three voltage levels and at full output. The voltage maintained within $\pm 1.5\%$ of the stated level during the test.

UNDER / OVER FREQUENCY PROTECTION

Function	Limit		Actual setting		Trip test	
	Frequency[Hz]	Time[s]	Frequency[Hz]	Time[s]	Frequency[Hz]	Time[s]
U/F Stage 1	47.5	0.1	47.5	0.06	47.50	0.098
O/F Stage 1	51.5	0.1	51.5	0.06	51.51	0.095

ACTIVE POWER FEED-IN AT OVER FREQUENCY

PM =100% of Prated				
Freq. (Hz)	Actual frequency (Hz)	Measured active output power Pnow(W)	ΔP as per measured data (=PM- Pnow) (W)	Actual gradient (%/Hz)
50,00	50.001	1997.4	-	-
50,25	50.251	1943.9	-	-
50,70	50.700	1601.2	396.2	39.7
51,15	51.150	1249.4	748.0	39.4
50,70	50.700	1601.5	395.9	39.7
50,25	50.250	1950.6	-	-
50,00	50.001	2000.4	-	-

The max. gradient over the whole power derating transient is $39,7P_M$ % per Hz.

PM =50% of Prated				
Freq. (Hz)	Actual frequency (Hz)	Measured active output power Pnow(W)	ΔP as per measured data (=PM- Pnow) (W)	Actual gradient (%/Hz)
50,00	50.001	1005.8	-	-

50,25	50.251	977.9	-	-
50,70	50.700	804.8	201.0	40.0%
51,15	51.150	630.1	.375.7	39.3%
50,70	50.700	804.8	201.0	40.0%
50,25	50.250	978.4	-	-
50,00	50.001	1025.5	-	-

The max. gradient over the whole power derating transient is 40.0 P_M% per Hz.

UNDER / OVER VOLTAGE PROTECTION

Function	Limit		Actual setting		Trip test	
	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
U/V Stage 1	184.0	0.1	184.0	0.06	185.2	0.069
O/V Stage 1*	253.0	600	253.0	600	257.6	598
O/V Stage 2	264.5	0.1	264.5	0.06	265.7	0.091

*Over voltage – stage 1: 10 min mean value corresponding to EN 50160. The voltage is set to 100%U_n and held for 600s. After that, the voltage is set to 112%U_n. It must be switched off within 600s.

LOSS OF MAINS TEST

Method used	Active frequency drift method		
	25% Prated	50% Prated	100% Prated
Limit according to VDE 0126-1-1	5s	5s	5s
Trip time (L:+5%)	0.365s	0.286s	0.293s
Trip time (L:+4%)	0.612s	0.298s	0.323s
Trip time (L:+3%)	0.382s	0.319s	0.546s
Trip time (L:+2%)	0.422s	0.301s	0.352s
Trip time (L:+1%)	0.329s	0.378s	0.329s
Trip time (L:+0%)	0.396s	0.427s	0.374s
Trip time (L:-1%)	0.362s	0.359s	0.378s
Trip time (L:-2%)	0.306s	0.365s	0.289s
Trip time (L:-3%)	0.345s	0.356s	0.278s
Trip time (L:-4%)	0.307s	0.307s	0.266s
Trip time (L:-5%)	0.312s	0.340s	0.252s

RECONNECTION TIME MEASUREMENT

Reconnection time	Under/over Voltage		Under / over Frequency		Loss of Mains	
	time	gradient	time	gradient	time	gradient
Limit	60s	10%P _n /min	60s	10%P _n /min	60s	10%P _n /min
Actual setting	60s	8% P _n /min	60s	8% P _n /min	60s	8% P _n /min
Recorded value	68s	8.7% P _n /min	68s	8.8% P _n /min	67s	8.8%P _n /min

DC CURRENT MONITORING

A direct current feed to the low voltage grid due to a defective generator operation must lead to a disconnection within 0.2 s. (the current limit is 1%In according to C10/11)

Function	Limit		Trip test	
	DC current [A]	Time [ms]	DC current [A]	Time [ms]
Positive DC current	0.1	200	0.09	160
Negative DC current	0.1	200	0.09	144

RESIDUAL CURRENT MONITORING

Test for correct triggering in event of steadily rising residual current

PV connection	Limit		Trip test	
	Fault current [mA]	Time [ms]	Test Current [mA]	Time [ms]
PV+	300	300	89	136
PV-	300	300	97	116

Test for correct triggering in event of steadily rising residual current

PV connection	Limit		Trip test	
	Fault current [mA]	Time [ms]	Test Current [mA]	Time [ms]
PV+	30	300	29.7	143
PV+	60	150	58.8	108
PV+	150	40	150.0	35
PV-	30	300	30.1	145
PV-	60	150	59.8	115
PV-	150	40	149.0	29

ARRAY INSULATION RESISTANCE DETECTION

The value of the total resistance, including the intentional resistance for array functional grounding, the expected insulation resistance of the array to ground, and the resistance of any other networks connected to ground (for example measurement networks) must not be lower than $R = (V_{MAX} PV/30 \text{ mA})$ ohms. (according to EN 62109-2)

PV connector	Test resistance value	Activation(Yes/No)	Display
PV+	200k Ω	Yes	Isolation Fault
PV-	200k Ω	Yes	Isolation Fault